



**CONTRACT NO: SD 6/2020**

**CONSTRUCTION OF SAN SHEK WAN SEWAGE TREATMENT WORKS  
ASSOCIATED SUBMARINE OUTFALL AND PUI O SEWERAGE WORKS**

**UNDER ENVIRONMENTAL PERMIT NO. EP-538/2017**

**MONTHLY ENVIRONMENTAL MONITORING & AUDIT REPORT**

**MAY 2022  
REVISION 3**

**CLIENTS:**

**Drainage Services Department**

**PREPARED BY:**

**Lam Environmental Services Limited**

19/F Remex Centre,  
42 Wong Chuk Hang Road,  
Hong Kong

Telephone: (852) 2882-3939  
Facsimile: (852) 2882-3331  
E-mail: [info@lamenviro.com](mailto:info@lamenviro.com)  
Website: <http://www.lamenviro.com>

**CERTIFIED BY:**

---

Melody Cheng  
Environmental Team Leader

**DATE:**

14 June 2022

Our ref: 7076811/L28723/AW/KL/TK/rw

14 June 2022

Drainage Services Department  
Sewage Services Branch  
Special Duty Division Group 3  
42/F Revenue Tower  
5 Gloucester Road  
Wan Chai, Hong Kong

**By Email and Post**  
(kschan04@dsd.gov.hk)

Attention: Mr Silas CHAN

Dear Sir

**Contract No. SD 7/2020**  
**Independent Environmental Checker ("IEC") for Environmental Monitoring Work for**  
**South Lantau Sewerage Works**  
**Verification of Updated Monthly EM&A Report (May 2022)**

With reference to the Monthly EM&A Report (May 2022) Revision 3 dated and certified by the ET Leader on 14 June 2022, please note that we have no adverse comments on the captioned and we hereby verify the captioned in accordance with Condition 3.4 of the Environmental Permit No. EP-538/2017.

Should you have questions please do not hesitate to contact the undersigned at tel. 3995-8140 or by email to [kitty.lee@smec.com](mailto:kitty.lee@smec.com).

Yours faithfully



**Kitty LEE**  
Independent Environmental Checker

cc	Binnies	-	Mr Clarence CHAK	by email
	Lam	-	Ms Melody CHENG / Mr Raymond DAI	by email
	KLCW-JV	-	Mr Charles TSE	by email



## TABLE OF CONTENTS

<b>1</b>	<b>INTRODUCTION.....</b>	<b>6</b>
1.1	Scope of the Report.....	6
1.2	Structure of the Report .....	6
<b>2</b>	<b>ENVIRONMENTAL STATUS .....</b>	<b>8</b>
2.1	Construction Programme .....	8
2.2	Works undertaken during the month.....	8
2.3	Drawing showing the project area, environmental sensitive receivers and monitoring locations .....	8
<b>3.</b>	<b>IMPLEMENTATION STATUS .....</b>	<b>9</b>
3.1	Advice on the implementation status of environmental protection and pollution control/mitigation measures.....	9
3.2	Environmental Mitigation Measures .....	9
3.3	Environmental monitoring requirements and contractual requirements	10
3.4	Site Inspection and Audit Reports .....	10
<b>5.</b>	<b>MONITORING RESULTS .....</b>	<b>12</b>
4.1	Noise Monitoring .....	12
4.2	Water Quality Monitoring.....	15
4.3	Ecology .....	22
4.4	Waste Management.....	23
<b>6.</b>	<b>COMPLAINTS, NOTIFICATION OF SUMMONS AND PROSECUTION .....</b>	<b>24</b>
<b>7.</b>	<b>OTHERS .....</b>	<b>26</b>
<b>7</b>	<b>CONCLUSION .....</b>	<b>28</b>

**LIST OF TABLES**

<b>Table 3.1</b>	<b><i>Summary of submission status under EP-538/2017</i></b>
<b>Table 3.2</b>	<b><i>Summary of the current status on licences and/or permits on environmental protection pertinent to the Project</i></b>
<b>Table 3.3</b>	<b><i>Summary of Environmental Inspections</i></b>
<b>Table 4.1</b>	<b><i>Noise Monitoring Equipment</i></b>
<b>Table 4.2</b>	<b><i>Noise Monitoring Station</i></b>
<b>Table 4.3</b>	<b><i>Water Quality Monitoring Equipment</i></b>
<b>Table 4.4</b>	<b><i>Marine Water Quality Stations for Water Quality Monitoring</i></b>
<b>Table 4.5</b>	<b><i>Action and Limit Levels of Water Quality</i></b>
<b>Table 4.6</b>	<b><i>Summary of Marine Water Quality Exceedances (EM&amp;A manual)</i></b>
<b>Table 4.7</b>	<b><i>Review of Exceedances in Turbidity and SS (proposed “and” approach)</i></b>
<b>Table 4.8</b>	<b><i>Summary of Quantities of Waste Material (as of April 2022)</i></b>
<b>Table 5.1</b>	<b><i>Summary of Complaints in the Reporting Month</i></b>
<b>Table 5.2</b>	<b><i>Cumulative Statistics on Complaints</i></b>
<b>Table 5.3</b>	<b><i>Cumulative Statistics on Successful Prosecutions</i></b>
<b>Table 6.1</b>	<b><i>Construction Activities and Recommended Mitigation Measures in Coming Reporting 3 Months</i></b>

**LIST OF FIGURES**

<b>Figure 2.1</b>	<b><u>Master Layout Plan</u></b>
<b>Figure 2.2</b>	<b><u>Contract Layout Plan</u></b>
<b>Figure 2.3</b>	<b><u>Locations of Noise Monitoring Station</u></b>
<b>Figure 2.4</b>	<b><u>Locations of Water Quality Monitoring Stations</u></b>
<b>Figure 2.5</b>	<b><u>Mark up Figure 5.4i extracted from approved EIA Report (AEIAR-210/2017)</u></b>
<b>Figure 2.6</b>	<b><u>Location Plan for Temporary Holding Nursery</u></b>

**LIST OF APPENDICES**

<b>Appendix 4.1</b>	<b><u>Copies of Calibration Certificates</u></b>
<b>Appendix 4.2</b>	<b><u>Impact Monitoring Schedule</u></b>
<b>Appendix 4.3</b>	<b><u>Noise Monitoring Results and Graphical Presentations</u></b>
<b>Appendix 4.4</b>	<b><u>Marine Water Quality Monitoring Results and Graphical Presentations</u></b>
<b>Appendix 4.5</b>	<b><u>Monthly Summary Waste Flow Table</u></b>
<b>Appendix 6.1</b>	<b><u>3 Months Rolling Programme – May 2022 to July 2022</u></b>



## EXECUTIVE SUMMARY

- i. This is the Environmental Monitoring and Audit (EM&A) Monthly Report – **May 2022** of Outlying Islands Sewerage Stage 2 – South Lantau Sewerage Works under Environmental Permit no. EP-538/2017 (Hereafter as “the Project”). The construction works of the Project was commenced on **3 November 2021** and the tentative completion date is **Q1 2026**. The EM&A report presenting the environmental monitoring findings and information recorded during the period of **01 May 2022 to 31 May 2022**. The cut-off date of reporting is at the end of each reporting month.
- ii. In the reporting month, the principal work activities conducted are as follow:
  - **Excavation and site formation works at San Shek Wan Sewage Treatment Works (SSWSTW) and Pui O Sewage Pumping Station (POSPS)**
  - **Tree pruning at POSPS**
  - **Maintenance works for trees in holding nursery and construction site**
  - **Excavation, sewer laying, construction of manhole at Pui O Lo Uk Tsuen**
  - **Excavation at South Lantau Road**
  - **HDD works**

### Exceedances of Action/Limit Levels

#### Noise Monitoring

- iii. Noise monitoring was conducted at **five (5)** noise monitoring stations N12a, N12b, N13, N14 and N17 once per week in the reporting month.
- iv. **No action or limit level exceedance was recorded in construction noise level in this reporting period.**

#### Water Quality Monitoring

- v. **Marine-based construction works commenced on 19 April 2022.** Water quality monitoring had been commenced on 12 April 2022 at **seven (7)** monitoring stations three days per week.
- vi. **Based on criteria in EM&A Manual, 118 action level and 0 limit level exceedances on DO, 11 action level and 55 limit level exceedances on turbidity, 8 action level and 52 limit level exceedances on SS were recorded in the reporting month.**
- vii. **Overall exceedances on turbidity and SS (i.e. SR4, SR15 downstream to the construction site during mid-ebb, SR5, SR6, SR9, SR10 and SR12 exceedances downstream to the construction site during mid-flood,) in the reporting month were referred to the 20% / 30% of control station criteria only whereas there were no exceedance 95%-ile / 99%-ile, indicating that the exceedance is due to the localized water quality better than baseline range were captured at the control station whereas the impact station are still within the baseline ranges.**

Co-related the monitoring dates with the marine works activities that only steel works, barge mobilization and general site housekeeping were conducted with no marine dredging works in the reporting month, it can be concluded that all these turbidity and SS exceedances were possibly due to natural runoff from streams to the sea as a result of frequent rainfall as recorded in the reporting month (Heavy showers, rainstorm and squally thunderstorms from 10 to 16 May 2022 and from 25 to 31 May 2022, Amber rainstorm warning signal recorded on 12 May 2022; Amber and Red rainstorm warning signals recorded on 13 May 2022).

- viii. For Action level exceedances on DO were generally recorded at control station CE on most monitoring dates except 3, 5, 7 and 10 May 2022 and at control station CF on most monitoring dates except 3 and 7 May 2022 such that these recorded exceedance could be the background contribution to overall DO exceedances at the impact stations in general in the reporting month. Therefore, the exceedances could be the fluctuation around background ranges and hence considered as non-project related.
- ix. No exceedance would be recorded if adopts the proposed change of Action and Limit Level criteria that proposed in the Baseline Monitoring Report.

#### Ecological Impact Monitoring

- x. Transplanting of the trees of *Aquilaris sinensis* was completed on 26 April 2022. Maintenance works for trees in holding nursery have commenced.
- xi. Preservation of retain tree of *Aquilaris sinensis* on Project Site.

#### Complaint log

- xii. One environmental complaint regarding the construction works was recorded in the reporting period.

#### Notifications of Any Summons and Successful Prosecutions

- xiii. No environmental notification of any summons and successful prosecution regarding the construction works was recorded in the reporting period.

#### Reporting Changes

- xiv. There are no particular reporting changes.

Future Key Issues

- xv. In coming reporting 3 months, the scheduled construction activities and the recommended mitigation measures are listed as follows:

Key Construction Works	Recommended Mitigation Measures
<ul style="list-style-type: none"> <li>Maintenance and establishment works for transplanted trees in holding nursery.</li> <li>Preservation of existing trees on Project Site</li> <li>Village sewers (excavation, sewer laying, construction of manhole) at Pui O Lo Uk Tsuen</li> <li>Construction of POSPS</li> <li>Horizontal directional drilling (HDD) works for SSWSTW land side</li> <li>HDD works at sea side</li> </ul>	<ul style="list-style-type: none"> <li>Provide caring measures for the health, form and structural conditions for transplant trees including <i>Aquilaris sinensis</i> in holding nursery;</li> <li>Fully implement tree preservation works on site and holding nursery to ensure compliance of relevant legislation and guidelines stated in EM&amp;A Manual.</li> <li>Implementation of noise pollution control in accordance with Construction Noise Mitigation Plan;</li> <li>Dust control during dust generating works;</li> <li>Adopt surface drainage and sediment control facilities for sewage installation in village and public roads;</li> <li>Adopt temporary drainage and sediment control facilities on Site;</li> <li>Vehicle wheel-washing and body washing facilities should be provided at the site entrance;</li> <li>Regular water spraying on drilling and excavation works for dust control; and</li> <li>Proper waste handling, recycling and storage.</li> <li>To inspect the condition of silt curtains on regular basis, and after adverse weather including any rainstorms and typhoons in wet season.</li> </ul>

## 1 Introduction

### 1.1 Scope of the Report

1.1.1. Lam Environmental Services Limited (LES) has been appointed to work as the Environmental Team (ET) under Environmental Permit (EP) no. EP-538/2017 to implement the Environmental Monitoring and Audit (EM&A) programme as stipulated in the EM&A Manual of the approved Environmental Impact Assessment (EIA) Report for Outlying Islands Sewerage Stage 2 - South Lantau Sewerage Works (Register No.: AEIAR-210/2017).

1.1.2. In accordance with Clause 3.4 stated in EP-538/2017, 4 hard copies and 1 electronic copy of Monthly EM&A Report shall be submitted to the Director within 2 weeks after the end of each reporting month.

1.1.3. According to Section 12.2 of the Project EM&A Manual, the Monthly EM&A Report should be submitted within 10 working days of the end of each reporting month, with the first report due in the month after construction commences.

### 1.2 Structure of the Report

**Section 1**      ***Introduction*** – details the scope and structure of the report.

**Section 2**      ***Environmental Status*** – construction programme, works undertaken during the month with illustrations, drawing showing the project area, environmental sensitive receivers and monitoring locations.

**Section 3**      ***Implementation Status*** – Advice on the implementation status of environmental protection and pollution control/mitigation measures, as recommended in the EIA Report and summarised in the updated implementation schedule.

**Section 4**      ***Monitoring Results*** – summarizes the monitoring results obtained in the reporting period, including monitoring methodology, name of laboratory and equipment used and calibration details, parameters monitored, monitoring locations (and depth), monitoring date, frequency, and duration.

**Section 5**      ***Report on Complaints, Notification of Summons and Successful Prosecutions***

Record of all complaints received (written or verbal) for each media, including locations and nature of complaints investigation, liaison and consultation undertaken, actions and follow-up procedures taken, results and summary;



Record of notifications of summons and successful prosecutions for breaches of the current environmental protection/pollution control legislations, including locations and nature of the breaches, investigation, follow-up actions taken, results and summary;

Review of the reasons for and the implications of non-compliance, complaints, summons and prosecutions including review of pollution sources and working procedures; and

Description of the actions taken in the event of non-compliance and deficiency reporting and any follow-up procedures related to non-compliance.

**Section 6**      ***Others*** – An account of the future key issues as reviewed from the works programme and work method statements.

**Section 7**      ***Conclusion***

## **2 Environmental Status**

### **2.1 Construction Programme**

- 2.1.1 The proposed sewerage works will collect the sewage generated from the unsewered areas of Shui Hau, Tong Fuk, Cheung Sha, San Shek Wan, Pui O and Ham Tin in South Lantau (i.e. within the Project Catchment Area) and convey it to a proposed sewage treatment works at San Shek Wan for treatment and disposal into outer bay of Pui O/ Chi Ma Wan via a submarine outfall.
- 2.1.2 The entire Project are divided into three contracts. Contract No. DC/2020/20 (the Contract) would have the following implementations as demonstrated in [Figure 2.1](#).
- 2.1.3 The major components of the Project under Environmental Permit (EP) (EP No. EP-538/2017) comprises: (i) construction of sewage treatment works at San Shek Wan (SSWSTW) and associated submarine outfall; (ii) construction of sewage pumping station at Pui O (POSPS); (iii) village sewage works at Pui O; and (iv) trunk sewers and rising mains on carriageways.
- 2.1.4 **No** construction programme with fine tuning of construction activities showing the inter-relationship with environmental protection/ mitigation measures for the month.

### **2.2 Works undertaken during the month**

- 2.2.1 In the reporting month, the principal work activities conducted are as follow:
- Excavation and site formation works at San Shek Wan Sewage Treatment Works (SSWSTW) and Pui O Sewage Pumping Station (POSPS)
  - Tree pruning at POSPS
  - Maintenance works for trees in holding nursery and construction site
  - Excavation, sewer laying, construction of manhole at Pui O Lo Uk Tsuen
  - Excavation at South Lantau Road
  - HDD works

The locations of works are shown in [Figure 2.2](#).

### **2.3 Drawing showing the project area, environmental sensitive receivers and monitoring locations**

- 2.3.1 Noise and water monitoring location plans with sensitive receivers are shown in [Figure 2.3](#) and [Figure 2.4](#).

### 3. Implementation Status

#### 3.1 Advice on the implementation status of environmental protection and pollution control/mitigation measures

3.1.1 Mitigation measures according to the environmental mitigation implementation schedule in Annex A of EM&A Manual were generally implemented by the Contractor. Hence, the EM&A programme was considered effective and shall be maintained.

#### 3.2 Environmental Mitigation Measures

3.2.1 Environmental mitigation measures mentioned the EIA Report were weekly reviewed and recorded in Weekly Environmental Site Audit Checklist. Also, a summary of the current status on submissions and measures mentioned in Environmental Permit (EP-538/2017) are shown in **Table 3.1**.

**Table 3.1 Summary of submission status under EP-538/2017**

EP Condition	Submission	Date of Latest Submission to EPD^ / EPD Approval#
Condition 2.10	Waste Management Plan (Rev. 5) (electronic copy)	4 April 2022#
Condition 2.11	Submission of Preservation and/or Transplantation Plan for Plant Species of Conservation Importance (Rev. 12)	11 May 2022^
Condition 2.12	Submission of Compensatory Woodland Planting Plan (Rev. 5)	2 July 2021^
Condition 2.13	Silt Curtain Deployment Plan (Rev. 11)	29 April 2022^
Condition 2.14	Landscape Mitigation Plan	To be confirmed
Condition 2.15	Construction Noise Mitigation Plan (Rev. 14)	8 April 2022^

### 3.3 Environmental monitoring requirements and contractual requirements

3.3.1 A summary of the current status on licences and/or permits on environmental protection pertinent to the Project is shown in **Table 3.2**.

**Table 3.2 Summary of the current status on licences and/or permits on environmental protection pertinent to the Project**

Permits and/or Licences	Permit. No. / Account No.	Issued Date	Valid Period & Expiry Date (dd-mm-yyyy to dd-mm-yyyy)	Status
Notification of Works Under APCO	466408	14 Apr 2021	N/A	Valid
Discharge Licence	POPS: WT00039820-2021	31 Dec 2021	31-12-2021 to 31-12-2026	Valid
	SSWSTW: WT00039636-2021	30 Dec 2021	30-12-2021 to 31-12-2026	
Billing account under Waste Disposal Ordinance	Account No.: 7040411	05 May 2021	N/A	Valid
Registration as a Chemical Waste Producer	0000-931-K3428-01	13 May 2021	N/A	Valid
Construction Noise Permit	GW-RS0921-21	26 Nov 2021	29-11-2021 to 28-05-2022	Valid
	GW-RS0428-22	26 May 2022	29-05-2022 to 28-11-2022	Valid

Note: Only include those valid or under application; fill in “N/A” for non-applicable item(s).

### 3.4 Site Inspection and Audit Reports

- 3.4.1 Within this reporting month, weekly environmental site inspections were conducted on [03, 10, 17, 23 May 2022](#) and [31 May 2022](#). IEC attended the SSEMC meeting held on [23 May 2022](#). Holding nursery visit for transplanted trees on [31 May 2022](#).
- 3.4.2 No non-compliance was found during the site inspection while reminders on environmental measures were recommended. Results and findings of these inspections in this reporting month are listed below in **Table 3.3**.

**Table 3.3 Summary of Environmental Inspections**

Inspection Date	Reminder and Recommendations	Close-out Date / Status
3 May 2022	<a href="#">Pui O Sewage Pumping Station</a>	10 May 2022
	<ol style="list-style-type: none"> <li>To apply regular water spraying on exposed area</li> </ol> <a href="#">San Shek Wan Sewage Treatment Works</a> <ol style="list-style-type: none"> <li>Stockpiled material should be covered with impervious sheet to reduce dust nuisance</li> </ol>	





10 May 2022	Site conditions are generally in order	-
17 May 2022	<u>Pui O Sewage Pumping Station</u> 1. Deposit silt and grit should be removed regularly. 2. Temporary drainage for surface runoff should be strengthened 3. The effectiveness vehicle wheel-washing facilities should be enhanced  <u>San Shek Wan Sewage Treatment Works</u> 4. Exposed stockpile should be covered	23 May 2022 Mid of June 2022 Mid of June 2022   23 May 2022
23 May 2022	<u>Pui O Sewage Pumping Station</u> Reminder: Exposed area near Site entrance should be mitigated 1. Cable on tree should be removed 2. Tree Protection Zone should be enlarged  <u>San Shek Wan Sewage Treatment Works</u> 3. Enhance housekeeping on Site  <u>Lo Uk Tsuen Sewer works</u> 4. Stockpile should be covered 5. Dust and soil on ground to be cleared	25 May 2022 31 May 2022   25 May 2022   31 May 2022 25 May 2022
31 May 2022	<u>Pui O Sewage Pumping Station</u> 1. Site temporary drainage is under construction  <u>San Shek Wan Sewage Treatment Works</u> 2. Site temporary drainage is under construction  <u>Transplant trees in holding nursery</u> 3. To carry out pest control for Transplant trees no. T113, T114.	Early June 2022  Early June 2022   31 May 2022

#### 4. Monitoring Results

##### 4.1 Noise Monitoring

###### MONITORING METHODOLOGY

###### 4.1.1 Monitoring Procedure

- (a) The impact noise monitoring should be carried out at all the designated monitoring stations when there are project-related construction activities undertaken within a radius of 300m from the monitoring stations.
- (b) The monitoring station shall normally be at a point 1m from the exterior of the sensitive receiver's building façade and be at a position 1.2m above the ground.
- (c) Façade measurements were made at the monitoring locations. For free-field measurement, a correction factor of +3 dB (A) would be applied.
- (d) The battery condition was checked to ensure the correct functioning of the meter.
- (e) Parameters such as frequency weighting, the time weighting and the measurement time were set as follows:
- (f) Frequency weighting: A, Time weighting: Fast, Measurement time set: continuous 5 mins
- (g) Prior and after to the noise measurement, the meter was checked using the acoustic calibrator for 94dB (A) at 1000 Hz. If the difference in the calibration level before and after measurement was more than  $\pm 1$  dB (A), the measurement would be considered invalid and repeat of noise measurement would be required after re-calibration or repair of the equipment.

###### NAME OF LABORATORY AND EQUIPMENT USED AND CALIBRATION DETAILS

- 4.1.2 Noise monitoring was performed using sound level meter at the designated monitoring locations. The sound level meters shall comply with the International Electrotechnical Commission Publications 651:1979 (Type 1) and 804:1985 (Type 1) specifications. Acoustic calibrator shall be deployed to check the sound level meters at a known sound pressure level. Brand and model of the equipment is given in **Table 4.1**.

**Table 4.1 Noise Monitoring Equipment**

Equipment	Brand and Model	Series Number
Integrated Sound Level Meter	Larson Davis LxT1	0006346
Acoustic Calibrator	Honglim HLES-02	2016611465

- 4.1.3 The calibration certificates of the noise monitoring equipment are attached in [Appendix 4.1](#).

###### 4.1.4 Calibration Details

- (a) The microphone head of the sound level meter was cleaned with soft cloth at regular intervals.

- (b) The sound level meter and calibrator were calibrated at yearly intervals.

#### PARAMETERS MONITORED

- 4.1.5 The construction noise level shall be measured in terms of the A-weighted equivalent continuous sound pressure level ( $L_{eq}$ ).  $L_{eq}$  (30min) should be used as the monitoring parameter. Supplementary information for data auditing, statistical results such as  $L_{10}$  and  $L_{90}$  shall also be obtained for reference.
- 4.1.6 For impact monitoring for construction of village sewers / rising main, noise monitoring should be undertaken on weekly basis. One set of  $L_{eq}$  (30min) noise level as six consecutive  $L_{eq}$  (5min) between 07:00-19:00 hours on normal weekdays.

#### MONITORING STATIONS

- 4.1.7 The noise monitoring stations for the Project are listed and shown in **Table 4.2**, impact noise monitoring was conducted at five (5) noise monitoring stations N12a, N12b, N13, N14 and N17 once per week in the reporting month.

**Table 4.2 Noise Monitoring Station**

Monitoring Station ID <sup>(1)</sup>	Monitoring Location	Measurement Type	Level (in terms of no. of floor)
N01a	Shui Hau Village	Free-Field	G/F
N01c	Shui Hau Village	Free-Field	G/F
N03a	Tong Fuk Village	Free-Field	G/F
N05a	Residences at Cheung Fu Street	Free-Field	G/F
N07	Government Holiday Bungalows	Free-Field	G/F
N08	Cheung Sha Ha Tsuen	Free-Field	G/F
N10	Cheung Sha Sheung Tsuen	Façade	G/F
N11b	San Shek Wan – Ming Garden	Free-Field	G/F
N12a	Lo Uk Tsuen	Free-Field	G/F
N12b	Lo Uk Tsuen	Façade	G/F
N13	Pui O San Wai Tsuen	Façade	G/F
N14	South Lantau Community Centre	Free-Field	G/F
N15b	Pui O Lo Wai Tsuen	Façade	G/F
N16a	Residences at Ham Tin	Free-Field	G/F
N16b	Residences at Ham Tin	Free-Field	G/F
N17	Bui O Public School	Façade	R/F

Remarks (1): Fine adjustment of noise monitoring stations at all locations was proposed as per EP Condition 3.1.



#### MONITORING DATE, TIME, FREQUENCY AND DURATION

- 4.1.8 For daytime construction work on normal weekdays, monitoring of  $L_{eq(30min)}$  should be carried out at each station at 0700-1900 hours on normal weekdays at a frequency of once a week. Impact monitoring schedule can be referred to [Appendix 4.2](#).

#### NOISE MONITORING RESULTS

- 4.1.9 Noise monitoring results measured in this reporting period are reviewed and summarized. Details of noise monitoring results and graphical presentation can be referred in [Appendix 4.3](#).
- 4.1.10 No action or limit level exceedance was recorded in construction noise level in this reporting period.

## **4.2 Water Quality Monitoring**

### MONITORING METHODOLOGY

#### **4.2.1 Monitoring Procedure**

- (a) The condition near the monitoring stations shall be observed and recorded on the data log sheet.
- (b) Check of sensors and electrodes with certified standard solutions before each use.
- (c) Wet bulb calibration for a DO meter should be carried out before measurement.
- (d) Water depth should be recorded by detector before sampling.
- (e) Sample would be taken using bucket sampler at surface level.
- (f) Transfer the sampled water carefully into cleaned water bottles (2x 1000ml) provided by the laboratory at the spot after the collection of the water sample for the subsequent laboratory Suspended Solid testing.
- (g) Transfer the sampled water from the bucket sampler to the rinsed water container for in-situ measurement (In case of the in-situ measurement cannot be carried at spot due to safety and adverse weather condition, sampled water from the bucket sampler will be transfer to cleaned water bottles provided by laboratory. Then, In-situ measurement will be conducted at a safe location which sampled water inside cleaned water bottle will be transfer to the rinsed water container for in-situ measurement) In-situ measurement shall be measured in duplicate.
- (h) Parameters including Water Temperature (°C), pH (units), Salinity (ppt), DO (mg/L), DO saturation (%) will be measured by the Multifunctional Meter and Turbidity (NTU) will be measured by turbid meter. (Water Temperature and Salinity will be measured as reference parameters)
- (i) Record the result on the data log sheet and record any special finding during / after in-situ measurement.
- (j) The water sample bottles will be stored in a cool box (at cooled to 4°C without being frozen), which shall be delivered to HOKLAS laboratory (ALS Technichem (HK) Pty Ltd) for further testing to determine the level of SS.

### NAME OF LABORATORY AND EQUIPMENT USED AND CALIBRATION DETAILS

#### LABORATORY MEASUREMENT / ANALYSIS

- 4.2.2 Analysis of suspended solids will be carried out in a HOKLAS accredited laboratory, which is ALS Technichem (HK) Pty Ltd.

#### EQUIPMENT USED

##### Dissolved Oxygen, pH And Temperature Measuring Equipment

- 4.2.3 Multifunctional Meter and Turbid Meter are used at each designated monitoring station. They are capable of measuring:

- (a) a dissolved oxygen level in the range of 0-20mg/L and 0-200% saturation (Detection

Limit: 0.1mg/L)

- (b) a temperature of 0-45 degree Celsius (Detection Limit: 0.1 degree Celsius)
- (c) turbidity level between 0-1000NTU (Detection Limit: 0.1NTU)
- (d) salinity in the range of 0-40ppt (Detection Limit: 0.1ppt)
- (e) pH value in range of 0.0 – 14.0 (Detection Limit: 0.1units)

Other monitoring equipment namely water depth meter, water current meter, dGPS positioning device, water sampler listed below were also deployed,

- (a) Water depth meter (Range: 0.6 -100m, Resolution: 0.1m)
- (b) Water current meter (Range: 0-360°, Detection Limit: 1mm/s)
- (c) dGPS positioning device (Resolution: Horizontal: 0.25m; Vertical: 0.50 m )
- (d) Water sampler (Horizontal discrete type, Capacity: 2.2L)

#### Sampler Container and Storage

- 4.2.4 A water sampler, Water samples for suspended solids measurement should be collected in high-density polythene bottles, packed in ice (cooled to 4°C without being frozen), and delivered to ALS Technichem (HK) Pty Ltd. as soon as possible after collection for analysis.

#### Water Depth Detector

- 4.2.5 A portable, battery-operated echo sounder shall be used for the determination of water depth at each designated monitoring station. This unit can either be handheld or affixed to the bottom of the workboat, if the same vessel is to be used throughout the monitoring programme.

#### CALIBRATION DETAILS

- 4.2.6 Maintenance and Calibration

- (a) The responses of sensors and electrodes of the water quality monitoring equipment were cleaned and checked at regular intervals.
- (b) DO meter (Multifunctional Meter) and turbid meter was certified by a laboratory accredited under HOKLAS or any other international accreditation scheme, and subsequently re-calibrated at three monthly intervals.

- 4.2.7 Brand and model of the equipment are given in **Table 4.3**.

**Table 4.3 Water Quality Monitoring Equipment**

Equipment	Brand and model	Series Number
Multifunctional Meter	Sonde YSI Professional Plus	17F100236
Turbid meter	Xin Rui WGZ-3B	2005060

The calibration certificates of the water quality monitoring equipment are attached in [Appendix 4.1](#).

- 4.2.8 Marine-based construction works commenced on 19 April 2022, HDD casing works commenced on 30 May 2022.

#### PARAMETERS MONITORED

- 4.2.9 In construction phase, the levels of dissolved oxygen (DO), temperature, turbidity and salinity should be measured in situ while suspended solids (SS) is determined by laboratory analysis.

#### MONITORING STATIONS

- 4.2.10 Water quality monitoring involves 9 monitoring stations. The locations of water quality monitoring station are shown in **Table 4.4**.

**Table 4.4 Marine Water Quality Stations for Water Quality Monitoring**

Station	Description	Easting	Northing
CE	Upstream control station at ebb tide	810838	807538
CF	Upstream control station at flood tide	815886	808081
SR4 <sup>(1)</sup>	Ecological Sensitive Receiver (Coral Communities) at Pui O Wan	814938	810975
SR5	Ecological Sensitive Receiver (Coral Communities) at Pui O Wan	814326	810540
SR6	Gazetted Bathing Beach at Lower Cheung Sha	810553	810475
SR9 <sup>(1)</sup>	Ecological Important Stream at Tong Fuk	811325	809787
SR10	Secondary Contact Recreational Zones at South Lantau	810561	809494
SR12 <sup>(1)</sup>	Proposed Special Site of Scientific Interest (SSSI) at Shui Hau Wan	810359	808989
SR15	Gazetted Bathing Beach at Pui O and Ecologically Important Stream at Pui O	816037	810722

Remarks (1): Fine adjustment of water quality monitoring stations at SR4, SR9 and SR12 was proposed as per EP Condition 3.1, and baseline monitoring was conducted at corresponding fine adjusted locations.

#### MONITORING DATE, TIME, FREQUENCY AND DURATION

- 4.2.11 The levels of dissolved oxygen (DO), temperature, turbidity and salinity were measured in situ while suspended solids (SS) is determined by laboratory analysis at all the monitoring stations in **Table 4.4** three times a week. Impact monitoring schedule can be referred to [Appendix 4.2](#).
- 4.2.12 In association with the water quality parameters, other relevant data shall also be recorded, such as monitoring location / position, time, water temperature, DO saturation, weather conditions, and any special phenomena underway near the monitoring station.
- 4.2.13 Impact Monitoring shall be carried out three days per week, at mid-flood and mid-ebb tides (within  $\pm 1.75$  hour of the predicted time). The interval between two sets of monitoring shall not be less than 36 hours. The monitoring period should avoid concurrent marine project in the vicinity.

- 4.2.14 The sampling frequency of at least three days per week should be undertaken when the highest dust impact occurs. Upon completion of the construction works, the monitoring exercise at the designated monitoring locations should be continued for four weeks in the same manner as the impact monitoring. In case exceedance of Action/Limit Level is recorded, the frequency shall be increased as per the Event and Action Plan.
- 4.2.15 To ensure the robustness of in-situ measurement, parameters shall be measured in duplicate. In case the difference between duplicates is larger than 25%, a third set of measurement shall be carried out.

#### MONITORING RESULTS

- 4.2.16 Marine water quality monitoring results measured in this reporting period are reviewed and summarized. Details of marine water quality monitoring results and graphical presentation can be referred in [Appendix 4.4](#)
- 4.2.17 Water quality monitoring is evaluated against Action and Limit Levels. Note that derived Action and Limit Level was proposed in Baseline Monitoring Report for approval. Action and Limit Levels of marine water quality monitoring have been set with reference to the EM&A Manual criteria and derived criteria as shown in **Table 4.5** below.

**Table 4.5 Action and Limit Levels of Water Quality**

Parameters	Action Level	Limit Level
<i>Construction Phase Marine Water Monitoring - EM&amp;A Manual criteria</i>		
DO in mg/L	Surface and Middle: 5.8 mg/L Bottom: 5.9 mg/L	Surface and Middle: 4 mg/L Bottom: 2 mg/L
Turbidity in NTU (Depth-averaged <sup>A</sup> ) <sup>C</sup>	14.4 NTU, <b>or</b> 20% exceedance of value at any impact station compared with corresponding data from control station	23.5 NTU, <b>or</b> 30% exceedance of value at any impact station compared with corresponding data from control station
SS in mg/L (Depth-averaged <sup>A</sup> ) <sup>C</sup>	13.1 mg/L, <b>or</b> 20% exceedance of value at any impact station compared with corresponding data from control station	30.4 mg/L, <b>or</b> 30% exceedance of value at any impact station compared with corresponding data from control station
<i>Construction Phase Marine Water Monitoring - derived criteria</i>		
DO in mg/L <sup>B</sup>	Surface and Middle: 5.8 mg/L Bottom: 5.9 mg/L	Surface and Middle: 4 mg/L Bottom: 2 mg/L
Turbidity in NTU (Depth-averaged <sup>A</sup> ) <sup>C</sup>	14.4 NTU <b>and</b> 20% exceedance of value at any impact station compared with corresponding data from control station <sup>D</sup>	23.5 NTU <b>and</b> 30% exceedance of value at any impact station compared with corresponding data from control station <sup>D</sup>
SS in mg/L (Depth-averaged <sup>A</sup> ) <sup>C</sup>	13.1 mg/L <b>and</b> 20% exceedance of value at any impact station compared with corresponding data from control station <sup>D</sup>	30.4 mg/L <b>and</b> 30% exceedance of value at any impact station compared with corresponding data from control station <sup>D</sup>

Notes (with proposed amendments in AL/LL in underlined text):

- A. "Depth-averaged" is calculated by taking the arithmetic means of reading of all three depths.
- B. For DO, non-compliance of the water quality limits occurs when monitoring result is lower than the limits.
- C. For SS and turbidity, non-compliance of the water quality limits occurs when monitoring result is higher than the limits.
- D. Action Level and Limit Level with 95%-ile / 99%-ile derived from baseline data "and" 20% / 30% exceedance of control station proposed in Baseline Monitoring Report.



4.2.18 Number of exceedances recorded during the reporting month are summarized in **Table 4.6**.

**Table 4.6 Summary of Marine Water Quality Exceedances (EM&A manual)**

Station	Parameter	DO (S&M)		DO (Bottom)		Turbidity		SS		Exceedance count	
	Level exceeded	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood
SR4	Action	10/5/2022 16/5/2022 18/5/2022 20/5/2022 23/5/2022 25/5/2022 27/5/2022	18/5/2022 20/5/2022 25/5/2022 27/5/2022	3/5/2022 10/5/2022 14/5/2022 16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	3/5/2022 10/5/2022 16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	-	-	-	18/5/2022 23/5/2022	15	13
	Limit	-	-	-	-	3/5/2022 7/5/2022 10/5/2022 14/5/2022 16/5/2022 18/5/2022 31/5/2022	3/5/2022 5/5/2022 10/5/2022 18/5/2022	3/5/2022 5/5/2022 10/5/2022 14/5/2022 16/5/2022 31/5/2022	3/5/2022 10/5/2022 16/5/2022	13	7
SR5	Action	14/5/2022 16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	10/5/2022 14/5/2022 16/5/2022 20/5/2022 25/5/2022 27/5/2022	3/5/2022 10/5/2022 16/5/2022 18/5/2022 20/5/2022 23/5/2022 25/5/2022 27/5/2022	16/5/2022 23/5/2022	18/5/2022 23/5/2022	-	-	14	15
	Limit	-	-	-	-	7/5/2022 10/5/2022 14/5/2022 31/5/2022	5/5/2022 7/5/2022 10/5/2022 16/5/2022	5/5/2022 10/5/2022 14/5/2022 23/5/2022 25/5/2022 31/5/2022	-	10	4
SR6	Action	16/5/2022 18/5/2022 20/5/2022 23/5/2022 25/5/2022 27/5/2022	14/5/2022 16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	-	-	-	-	14/5/2022	-	7	6
	Limit	-	-	-	-	7/5/2022 10/5/2022 23/5/2022 25/5/2022 31/5/2022	5/5/2022 7/5/2022 16/5/2022 23/5/2022	5/5/2022 10/5/2022 23/5/2022 25/5/2022	3/5/2022 5/5/2022 10/5/2022 16/5/2022 23/5/2022	9	9
SR9	Action	16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022 31/5/2022	14/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	10/5/2022 16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	31/5/2022	27/5/2022	-	-	13	11
	Limit	-	-	-	-	10/5/2022 18/5/2022 25/5/2022	5/5/2022 7/5/2022 10/5/2022 16/5/2022 23/5/2022	5/5/2022 10/5/2022 14/5/2022 25/5/2022 31/5/2022	23/5/2022	9	6
SR10	Action	16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022 31/5/2022	14/5/2022 18/5/2022 23/5/2022 25/5/2022 27/5/2022 31/5/2022	-	-	-	-	-	18/5/2022	6	7
	Limit	-	-	-	-	23/5/2022 25/5/2022	5/5/2022 23/5/2022 31/5/2022	5/5/2022 10/5/2022 14/5/2022 23/5/2022 25/5/2022	5/5/2022 10/5/2022	7	6

Station	Parameter	DO (S&M)		DO (Bottom)		Turbidity		SS		Exceedance count	
	Level exceeded	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood
SR12	Action	18/5/2022 20/5/2022 25/5/2022 27/5/2022	14/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	-	-	7/5/2022 25/5/2022	-	-	3/5/2022	6	6
	Limit	-	-	-	-	23/5/2022	5/5/2022 7/5/2022 10/5/2022 23/5/2022	5/5/2022 10/5/2022 25/5/2022	10/5/2022 18/5/2022 23/5/2022	4	7
SR15	Action	14/5/2022 16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	3/5/2022 16/5/2022 18/5/2022 20/5/2022 25/5/2022 27/5/2022	-	-	7/5/2022	23/5/2022 31/5/2022	31/5/2022	5/5/2022 7/5/2022	8	10
	Limit	-	-	-	-	3/5/2022 10/5/2022 16/5/2022 18/5/2022 31/5/2022	3/5/2022 7/5/2022 16/5/2022 18/5/2022	5/5/2022 7/5/2022 10/5/2022 27/5/2022	3/5/2022 10/5/2022 16/5/2022 23/5/2022	8	8
Total	Action	41	37	20	20	6	5	2	6	137	
	Limit	0	0	0	0	27	28	33	19	107	

4.2.19 In accordance with the EM&A Manual, 118 action level and 0 limit level exceedances on DO, 11 action level and 55 limit level exceedances on turbidity, 8 action level and 52 limit level exceedances on SS were recorded in the reporting month.

4.2.20 SR4 and SR15 located at upstream of construction site during mid-flood such that the Action and Limit Level exceedances on turbidity and SS along these stations in general were contributed by upstream sources before entering the submarine outfall construction location. Similarly, SR5, SR6, SR9, SR10 and SR12 located at upstream of construction site during mid-ebb, such that the Action and Limit Level exceedances on turbidity and SS along these stations in general were contributed by upstream sources before entering the submarine outfall construction location.

4.2.21 Checked with contractor and RSS on the marine works activities in the reporting month, the following activities were recorded:

- 3/5/2022 - Cut off pipe pile of steel platform, Maintain silt curtain around marine platform
- 5/5/2022 - Weld safety fence on steel platform; Maintain silt curtain around marine platform
- 10/5/2022 - Working barge mobilized to site
- 25/5/2022 - Assemble and install steel casing for HDD works on the board
- 27/5/2022 - General site housekeeping (general cleansing on the board)
- 30/5/2022 - Install steel casing for HDD works to seabed
- 31/5/2022 - General site housekeeping (general cleansing on the board)

4.2.22 Overall exceedances on turbidity and SS (i.e. SR4, SR15 downstream to the construction site during mid-ebb, SR5, SR6, SR9, SR10 and SR12 exceedances downstream to the construction site during mid-flood,) in the reporting month were referred to the 20% / 30% of control station criteria only whereas there were no exceedance as referred to 95%-ile / 99%-ile criteria,

indicating that the exceedance is due to the localized water quality better than baseline range were captured at the control station whereas the impact station are still within the baseline ranges.

- 4.2.23 Co-related the monitoring dates with the marine works activities that only steel works, barge mobilization and general site housekeeping were conducted with no marine dredging works in the reporting month, it can be concluded that all these turbidity and SS exceedances were possibly due to natural runoff from streams to the sea as a result of frequent rainfall as recorded in the reporting month (Heavy showers, rainstorm and squally thunderstorms from 10 to 16 May 2022 and from 25 to 31 May 2022, Amber rainstorm warning signal recorded on 12 May 2022; Amber and Red rainstorm warning signals recorded on 13 May 2022).
- 4.2.24 For Action level exceedances on DO were generally recorded at control station CE on most monitoring dates except 3, 5, 7 and 10 May 2022 and at control station CF on most monitoring dates except 3 and 7 May 2022 such that these recorded exceedance could be the background contribution to overall DO exceedances at the impact stations in general in the reporting month. Therefore, the exceedances could be the fluctuation around background ranges and hence considered as non-project related.
- 4.2.25 Reviewing the “and” approach, no exceedance is recorded if it is based on the ‘AND’ criteria proposed in Baseline Monitoring Report v7.3 Section 3.8.2 submitted in May 2022 (**Table 4.7**). Majority of the exceedance were considered to be false alarm with review of the “and” approach for counteracting the over-sensitivity of control station criteria as proposed in the baseline report.

**Table 4.7 Review of Exceedances in Turbidity and SS (proposed “and” approach)**

Station	Parameter	Turbidity		SS		Exceedance count	
	Level exceeded	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood	Mid Ebb	Mid Flood
SR4	Action	-	-	-	-	0	0
	Limit	-	-	-	-	0	0
SR5	Action	-	-	-	-	0	0
	Limit	-	-	-	-	0	0
SR6	Action	-	-	-	-	0	0
	Limit	-	-	-	-	0	0
SR9	Action	-	-	-	-	0	0
	Limit	-	-	-	-	0	0
SR10	Action	-	-	-	-	0	0
	Limit	-	-	-	-	0	0
SR12	Action	-	-	-	-	0	0
	Limit	-	-	-	-	0	0
SR15	Action	-	-	-	-	0	0
	Limit	-	-	-	-	0	0
Total	Action	0	0	0	0	0	0
	Limit	0	0	0	0	0	0

### 4.3 Ecology

#### MONITORING METHODOLOGY

- 4.3.1 The weekly site audit to be carried out by the ET should include checking whether good site practices are being properly implemented by the Contractor.
- 4.3.2 Impact monitoring of the transplanted *Aquilaris sinensis* at holding nursery and one retain tree of *Aquilaris sinensis* in SSWSTW Project Site, establishment and after-establishment caring measures of the compensatory mixed woodland to ensure the affected tree would not be affected by any unacceptable construction works. The trees would be treated with establishment works immediately after transplanting.

#### PARAMETERS MONITORED

- 4.3.3 The extent of the work site boundaries should be checked by the ET during the weekly site audit. Any disturbance by the Contractor outside the works area especially any damage to the vegetation and surrounding habitats outside the Project area shall be reported to ER and IEC.
- 4.3.4 To identify any unacceptable construction works for the trees of *Aquilaris sinensis* during transplanting, establishment and after-establishment caring measures of the compensatory mixed woodland.

#### MONITORING LOCATION

- 4.3.5 The original location of *Aquilaris sinensis* is at SSWSTW ([Figure 2.5](#)). The tree is transplanted to temporary holding nursery ([Figure 2.6](#)) for establishment.
- 4.3.6 Retain tree of *Aquilaris sinensis* at SSWSTW Project Site.

#### MONITORING DATE, TIME, FREQUENCY AND DURATION

- 4.3.7 The recommended good site practices to be audited once every week as part of the site audit programme. The weekly site audit to be carried out by the ET includes checking whether good site practices are being properly implemented by the Contractor. Results are recorded in Weekly Environmental Site Audit Checklist.
- 4.3.8 Monitoring programme for post-transplantation will be conducted once per month ([31 May 2022](#)).

#### MONITORING RESULTS

- 4.3.9 Results and findings of site audit in this reporting month are listed in **Table 3.3**.

#### 4.4 Waste Management

4.4.1 The quantities of waste for disposal in the Reporting Period are summarized in Table 4.6. The Monthly Summary Waste Flow Table is shown in [Appendix 4.5](#).

**Table 4.8 Summary of Quantities of Waste Material (as of April 2022)**

Waste Type	Quantity this month	Quantity (the end of last month)	Cumulative Quantity-to-Date
Hard Rock and Large Broken Concrete (Inert) (in '000m <sup>3</sup> )	0	0	0
Reused in this Contract (Inert) (in '000m <sup>3</sup> )	0	0	0
Reused in other Projects (Inert) (in '000m <sup>3</sup> )	0	0	0
Disposal as Public Fill (Inert) (in '000m <sup>3</sup> )	0.21077	0.62390	6.58375
Metals (in '000kg)	0.00000	0.00450	1.56170
Paper / Cardboard Packing (in '000kg)	0.00000	0.04600	0.07048
Plastics (in '000kg)	0.00000	0.00350	0.01046
Chemical Wastes (in '000kg)	0	0	0
General Refuses (in '000kg)	17.38 <sup>#</sup>	9.74	293.49

\*: Further breakdown into sub-group if considered applicable;

\*: Please also provide daily dumping report for our records.

\*: Delete as appropriate

<sup>#</sup>: 5000kg of timber recycled.

## 5. Complaints, Notification of Summons and Prosecution

5.1.1 One environmental complaint, notification of summons and successful prosecution regarding construction works was recorded in the reporting period.

**Table 5.1 Summary of Complaints in the Reporting Month**

Date of Notification from EPD	Date of Complaint	Description of Complaint	Close-Out Date / Status
26 May 2022	22 May 2022	A complaint is regarding to a resident listened the construction noise within restricted hours (around 3 p.m. on 22/5/2022) at marine site from San Shek Wan, Lantau Island received.	The interim report to be submitted to EPD in Early June 2022.  The investigation, subsequent actions and the results will be recorded in the Monthly EM&A Report for June 2022

5.1.2 Cumulative statistic on complaints and successful prosecutions are summarized in **Table 5.2** and **Table 5.3** respectively.

**Table 5.2 Cumulative Statistics on Complaints**

Reporting Period	No. of Complaints
May 2022	1
Project commencement to the end of last reporting month	-
<b>Total</b>	<b>0</b>

**Table 5.3 Cumulative Statistics on Successful Prosecutions**

Environmental Parameters	Cumulative No. Brought Forward	No. of Successful Prosecutions this month (Offence Date)	Cumulative No. Project-to-Date
Air	-	0	0
Noise	-	0	0
Water	-	0	0
Waste	-	0	0



<b>Environmental Parameters</b>	<b>Cumulative No. Brought Forward</b>	<b>No. of Successful Prosecutions this month (Offence Date)</b>	<b>Cumulative No. Project-to-Date</b>
Other	-	0	0
<b>Total</b>	<b>-</b>	<b>0</b>	<b>0</b>

## 6. Others

6.1.1 In coming reporting 3 months, the scheduled construction activities are listed as follows:

- Maintenance and establishment works for transplanted trees in holding nursery.
- Preservation of existing trees on Project Site
- Village sewers (excavation, sewer laying, construction of manhole) at Pui O Lo Uk Tsuen
- Construction of POSPS
- Horizontal directional drilling (HDD) works for SSWSTW land side
- HDD works

6.1.2 The scheduled construction activities and the recommended mitigation measures for the coming 3 months are listed in **Table 6.1**. The major construction activities for the next 3 months are summarized in Three Months Rolling Programme - June 2022 to August 2022 in [Appendix 6.1](#).

**Table 6.1 Construction Activities and Recommended Mitigation Measures in Coming Reporting 3 Months**

Key Construction Works	Recommended Mitigation Measures
<ul style="list-style-type: none"> <li>• Maintenance and establishment works for transplanted trees in holding nursery.</li> <li>• Preservation of existing trees on Project Site</li> <li>• Village sewers (excavation, sewer laying, construction of manhole) at Pui O Lo Uk Tsuen</li> <li>• Construction of POSPS</li> <li>• Horizontal directional drilling (HDD) works for SSWSTW land side</li> </ul>	<ul style="list-style-type: none"> <li>• Provide caring measures for the health, form and structural conditions for transplant trees including <i>Aquilaris sinensis</i> in holding nursery;</li> <li>• Fully implement tree preservation works on site and holding nursery to ensure compliance of relevant legislation and guidelines stated in EM&amp;A Manual.</li> <li>• Implementation of noise pollution control in accordance with Construction Noise Mitigation Plan;</li> <li>• Dust control during dust generating works;</li> <li>• Adopt surface drainage and sediment control facilities for sewage installation in village and public roads;</li> <li>• Adopt temporary drainage and sediment control facilities on Site;</li> <li>• Vehicle wheel-washing and body washing facilities should be provided at the site entrance;</li> <li>• Regular water spraying on drilling and excavation works for dust control; and</li> <li>• Proper waste handling, recycling and storage.</li> </ul>





Key Construction Works	Recommended Mitigation Measures
<ul style="list-style-type: none"><li>HDD works at sea side</li></ul>	<ul style="list-style-type: none"><li>To inspect the condition of silt curtains on regular basis, and after adverse weather including any rainstorms and typhoons in wet season.</li></ul>

## **7 Conclusion**

### **7.1 Noise Monitoring.**

- 7.1.1 No action or limit level exceedance was recorded in construction noise level in this reporting period.

### **7.2 Water Quality Monitoring**

- 7.2.1 Marine-based construction works commenced on 19 April 2022, water quality monitoring was commenced on 12 April 2022.
- 7.2.2 Based on criteria in EM&A Manual, 118 action level and 0 limit level exceedances on DO, 11 action level and 55 limit level exceedances on turbidity, 8 action level and 52 limit level exceedances on SS were recorded in the reporting month. No exceedance would be recorded if adopts the proposed change of Action and Limit Level criteria that proposed in the Baseline Monitoring Report.

### **7.3 Ecological Impact Monitoring**

- 7.3.1 Maintenance works for transplanted *Aquilaris sinensis* have commenced, preservation and protection of retain tree *Aquilaris sinensis* at SSWSTW.

### **7.4 Review of the Reasons for and the Implications of Non-compliance**

- 7.4.1 No environmental non-compliance was recorded in the reporting month.

### **7.5 Summary of action taken in the event of and follow-up on non-compliance**


- 7.5.1 There was no particular action taken since no non-compliance was recorded in the reporting period.





***Figure 2.1***

***Master Layout Plan***





SITE PLAN  
1:100000



© Copyright by Black & Veatch Hong Kong Limited

D	11/20	TENDER ADDENDUM NO.6	BL
C	11/20	TENDER ADDENDUM NO.5	BL
B	11/20	TENDER ADDENDUM NO.4	BL
A	09/20	TENDER ADDENDUM NO.2	TFL
Revision	Date	Description	Initial
	Designed	Checked	Drawn
Initial	TFL	BL	SZ
Date	04/20	04/20	04/20

Approved

Contract no.  
DC/2020/02

Contract title  
CONSTRUCTION OF SAN SHEK WAN  
SEWERAGE TREATMENT WORKS,  
ASSOCIATED SUBMARINE OUTFALL  
AND PUI O SEWERAGE WORKS

Drawing title  
SOUTH LANTAU SEWERAGE  
WORKS – MASTER LAYOUT PLAN

Drawing no. 178711/B&V/GN/001	Revision D
----------------------------------	---------------

Scale  
1 : 15000

香港特別行政區政府渠務署  
THE GOVERNMENT OF THE  
HONG KONG  
SPECIAL ADMINISTRATIVE REGION  
DRAINAGE SERVICES DEPARTMENT


BLACK & VEATCH HONG KONG LIMITED  
博威工程顧問有限公司






***Figure 2.2***

***Contract Layout Plan***




圖則名稱 drawing title	繪畫 drawn		日期 date	圖則編號 drawing no.	比例 scale
	SIGNED W. H. CHAN		27 APR 2020	DVD/2020/001	1:12 500
	核對 checked		日期 date		
	SIGNED Ir K. S. CHAN		27 APR 2020	保留版權 COPYRIGHT RESERVED	
	批核 approved		日期 date	 <div>香港特別行政區政府渠務署 DRAINAGE SERVICES DEPARTMENT GOVERNMENT OF THE HONG KONG SPECIAL ADMINISTRATIVE REGION</div>	
SIGNED Ir L. CHEN		27 APR 2020			
部門 office 特別職務部 SPECIAL DUTY DIVISION					



***Figure 2.3***

***Locations of Noise Monitoring Station***










***Figure 2.4***

***Locations of Water Quality Monitoring Stations***






***Figure 2.5***

***Mark up Figure 5.4i extracted from approved EIA Report (AEIAR-210/2017)***



Figure 2.5 - Mark up Figure 5.4i extracted from approved EIA Report (AEIAR-210/2017)






***Figure 2.6***


***Location Plan for Temporary Holding Nursery***



Figure 2.6 Date : 2020-10-15  
Prepared by Daniel Ho



COPY RIGHT®

<b>Project :</b> Contract No.: DC/2020/02 Construction of San Shek Wan Sewage Treatment Works, Associated Submarine Outfall and Pui O Sewerage Works		 <b>Toyo Greenland Co., Ltd.</b>	
<b>Drawing Title :</b> Location Plan for 6 nos. Trees on Kam Tin Nursery		<b>Check :</b> Ho Tat Pui, Daniel	<b>Scale :</b> N.T.S.
		<b>Ref:</b> C3109/22/TGD0164	<b>Date :</b> 10 January 2022
			<b>Rev.</b> 00



***Appendix 4.1***

***Copies of Calibration Certificates***





## CERTIFICATE OF CALIBRATION

Certificate No.: 22CA0412 03

Page 1 of 2

### Item tested

Description:	Sound Level Meter (Class 1)	Microphone	Preamp
Manufacturer:	Larson Davis	PCB	PCB
Type/Model No.:	LxT1	377B02	PRMLxT1L
Serial/Equipment No.:	0006346	326425	069995
Adaptors used:	-	-	-

### Item submitted by

Customer Name:	Lam Environmental Services Limited
Address of Customer:	-
Request No.:	-
Date of receipt:	12-Apr-2022

Date of test: 17-Apr-2022

### Reference equipment used in the calibration

Description:	Model:	Serial No.	Expiry Date:	Traceable to:
Multi function sound calibrator	B&K 4226	2288444	23-Aug-2022	CIGISMEC
Signal generator	DS 360	33873	27-May-2022	CEPREI

### Ambient conditions

Temperature:	22 ± 1 °C
Relative humidity:	55 ± 10 %
Air pressure:	1005 ± 5 hPa

### Test specifications

- 1, The Sound Level Meter has been calibrated in accordance with the requirements as specified in BS 7580: Part 1: 1997 and the lab calibration procedure SMTP004-CA-152.
- 2, The electrical tests were performed using an electrical signal substituted for the microphone which was removed and replaced by an equivalent capacitance within a tolerance of ±20%.
- 3, The acoustic calibration was performed using an B&K 4226 sound calibrator and corrections was applied for the difference between the free-field and pressure responsiveness of the Sound Level Meter.

### Test results

This is to certify that the Sound Level Meter conforms to BS 7580: Part 1: 1997 for the conditions under which the test was performed.

Details of the performed measurements are presented on page 2 of this certificate.

Actual Measurement data are documented on worksheets.


Approved Signatory:



Feng Junqi

Date: 19-Apr-2022

Company Chop:



Comments: The results reported in this certificate refer to the condition of the instrument on the date of calibration and carry no implication regarding the long-term stability of the instrument. The results apply to the item as received.





## CERTIFICATE OF CALIBRATION

(Continuation Page)

Certificate No.: 22CA0412 03 Page 2 of 2

## 1, Electrical Tests

The electrical tests were performed using an equivalent capacitance substituted for the microphone. The results are given in below with test status and the estimated uncertainties. The "Pass" means the result of the test is inside the tolerances stated in the test specifications. The "-" means the result of test is outside these tolerances.

Test:	Subtest:	Status:	Expanded Uncertainty (dB)	Coverage Factor
Self-generated noise	A	Pass	0.3	
	C	Pass	0.8	2.1
	Lin	Pass	1.6	2.2
Linearity range for Leq	At reference range, Step 5 dB at 4 kHz	Pass	0.3	
	Reference SPL on all other ranges	Pass	0.3	
	2 dB below upper limit of each range	Pass	0.3	
	2 dB above lower limit of each range	Pass	0.3	
Linearity range for SPL	At reference range, Step 5 dB at 4 kHz	Pass	0.3	
Frequency weightings	A	Pass	0.3	
	C	Pass	0.3	
	Lin	Pass	0.3	
Time weightings	Single Burst Fast	Pass	0.3	
	Single Burst Slow	Pass	0.3	
Peak response	Single 100µs rectangular pulse	Pass	0.3	
R.M.S. accuracy	Crest factor of 3	Pass	0.3	
Time weighting I	Single burst 5 ms at 2000 Hz	Pass	0.3	
	Repeated at frequency of 100 Hz	Pass	0.3	
Time averaging	1 ms burst duty factor 1/10 <sup>3</sup> at 4kHz	Pass	0.3	
	1 ms burst duty factor 1/10 <sup>4</sup> at 4kHz	Pass	0.3	
Pulse range	Single burst 10 ms at 4 kHz	Pass	0.4	
Sound exposure level	Single burst 10 ms at 4 kHz	Pass	0.4	
Overload indication	SPL	Pass	0.3	
	Leq	Pass	0.4	

## 2, Acoustic tests

The complete sound level meter was calibrated on the reference range using a B&K 4226 acoustic calibrator with 1000Hz and SPL 94 dB. The sensitivity of the sound level meter was adjusted. The test result at 125 Hz and 8000 Hz are given in below with test status and the estimated uncertainties.

Test:	Subtest	Status	Expanded Uncertainty (dB)	Coverage Factor
Acoustic response	Weighting A at 125 Hz	Pass	0.3	
	Weighting A at 8000 Hz	Pass	0.5	

## 3, Response to associated sound calibrator

N/A

The expanded uncertainties have been calculated in accordance with the ISO Publication "Guide to the expression of uncertainty in measurement", and gives an interval estimated to have a level of confidence of 95%. A coverage factor of 2 is assumed unless explicitly stated.

Calibrated by:

Date:

Fung Chi Yip  
17-Apr-2022

- End -

Checked by:

Date:

Chan Yuk Yiu  
19-Apr-2022

The standard(s) and equipment used in the calibration are traceable to national or international recognised standards and are calibrated on a schedule to maintain the required accuracy level.



Test Data for Sound Level Meter

Page 1 of 5

Sound level meter type: LxT1 Serial No. 0006346 Date 17-Apr-2022  
Microphone type: 377B02 Serial No. 326425  
Preamp type: PRMLxT1L Serial No. 069995 Report: 22CA0412 03

### SELF GENERATED NOISE TEST

The noise test is performed in the most sensitive range of the SLM with the microphone replaced by an equivalent impedance.

Noise level in A weighting 9.3 dB  
Noise level in C weighting 12.5 dB  
Noise level in Lin 19.1 dB

### LINEARITY TEST

The linearity is tested relative to the reference sound pressure level using a continuous sinusoidal signal of frequency 4 kHz. The measurement is made on the reference range for indications at 5 dB intervals starting from the 94 dB reference sound pressure level. And until within 5 dB of the upper and lower limits of the reference range, the measurements shall be made at 1 dB intervals. (SLM set to LEQ/SPL)

Reference/Expected level	Actual level		Tolerance	Deviation	
	non-integrated	integrated		non-integrated	integrated
dB	dB	dB	+/- dB	dB	dB
94.0	94.0	94.0	0.7	0.0	0.0
99.0	99.0	99.0	0.7	0.0	0.0
104.0	104.0	104.0	0.7	0.0	0.0
109.0	109.0	109.0	0.7	0.0	0.0
114.0	114.0	114.0	0.7	0.0	0.0
115.0	115.0	115.0	0.7	0.0	0.0
116.0	116.0	116.0	0.7	0.0	0.0
117.0	117.0	117.0	0.7	0.0	0.0
118.0	118.0	118.0	0.7	0.0	0.0
119.0	119.0	119.0	0.7	0.0	0.0
120.0	120.0	120.0	0.7	0.0	0.0
89.0	89.0	89.0	0.7	0.0	0.0
84.0	84.0	84.0	0.7	0.0	0.0
79.0	79.0	79.0	0.7	0.0	0.0
74.0	74.0	74.0	0.7	0.0	0.0
69.0	69.0	69.0	0.7	0.0	0.0
64.0	64.0	64.0	0.7	0.0	0.0
59.0	59.0	59.0	0.7	0.0	0.0
54.0	54.0	54.0	0.7	0.0	0.0
49.0	48.9	48.9	0.7	-0.1	-0.1
44.0	44.0	44.0	0.7	0.0	0.0
39.0	39.0	39.0	0.7	0.0	0.0
34.0	34.0	34.0	0.7	0.0	0.0
33.0	33.0	33.0	0.7	0.0	0.0





Test Data for Sound Level Meter

Page 2 of 5

Sound level meter type: LxT1 Serial No. 0006346 Date 17-Apr-2022  
Microphone type: 377B02 Serial No. 326425  
Preamp type: PRMLxT1L Serial No. 069995 Report: 22CA0412 03

32.0	31.9	31.9	0.7	-0.1	-0.1
31.0	30.9	30.9	0.7	-0.1	-0.1
30.0	29.9	29.9	0.7	-0.1	-0.1

Measurements for an indication of the reference SPL on all other ranges which include it

Other ranges	Expected level	Actual level	Tolerance	Deviation
dB	dB	dB	+/- dB	dB
20-120	94.0	94.0	0.7	0.0

Measurements on all level ranges for indications 2 dB below the upper limit and 2 dB above the lower limit

Ranges	Reference/Expected level	Actual level	Tolerance	Deviation
dB	dB	dB	+/- dB	dB
20-120	30.0	29.9	0.7	-0.1
	118.0	118.0	0.7	0.0

## FREQUENCY WEIGHTING TEST

The frequency response of the weighting networks are tested at octave intervals over the frequency ranges 31.5 Hz to 12500 Hz. The signal level at 1000 Hz is set to give an indication of the reference SPL.

Frequency weighting A:

Frequency	Ref. level	Expected level	Actual level	Tolerance(dB)		Deviation
Hz	dB	dB	dB	+	-	dB
1000.0	94.0	94.0	94.0	0.0	0.0	0.0
31.6	94.0	54.6	54.6	1.5	1.5	0.0
63.1	94.0	67.8	67.8	1.5	1.5	0.0
125.9	94.0	77.9	77.9	1.0	1.0	0.0
251.2	94.0	85.4	85.4	1.0	1.0	0.0
501.2	94.0	90.8	90.8	1.0	1.0	0.0
1995.0	94.0	95.2	95.2	1.0	1.0	0.0
3981.0	94.0	95.0	95.0	1.0	1.0	0.0
7943.0	94.0	92.9	92.9	1.5	3.0	0.0
12590.0	94.0	89.7	89.7	3.0	6.0	0.0

Frequency weighting C:

Frequency	Ref. level	Expected level	Actual level	Tolerance(dB)		Deviation
Hz	dB	dB	dB	+	-	dB
1000.0	94.0	94.0	94.0	0.0	0.0	0.0
31.6	94.0	91.0	91.0	1.5	1.5	0.0
63.1	94.0	93.2	93.2	1.5	1.5	0.0
125.9	94.0	93.8	93.8	1.0	1.0	0.0
251.2	94.0	94.0	94.0	1.0	1.0	0.0
501.2	94.0	94.0	94.0	1.0	1.0	0.0



Test Data for Sound Level Meter

Page 3 of 5

Sound level meter type: LxT1 Serial No. 0006346 Date 17-Apr-2022  
Microphone type: 377B02 Serial No. 326425  
Preamp type: PRMLxT1L Serial No. 069995 Report: 22CA0412 03

1995.0	94.0	93.8	93.9	1.0	1.0	0.1
3981.0	94.0	93.2	93.3	1.0	1.0	0.1
7943.0	94.0	91.0	91.0	1.5	3.0	0.0
12590.0	94.0	87.8	87.8	3.0	6.0	0.0

Frequency weighting Lin:

Frequency	Ref. level	Expected level	Actual level	Tolerance(dB)		Deviation
Hz	dB	dB	dB	+	-	dB
1000.0	94.0	94.0	94.0	0.0	0.0	0.0
31.6	94.0	94.0	94.0	1.5	1.5	0.0
63.1	94.0	94.0	94.0	1.5	1.5	0.0
125.9	94.0	94.0	94.0	1.0	1.0	0.0
251.2	94.0	94.0	94.0	1.0	1.0	0.0
501.2	94.0	94.0	94.0	1.0	1.0	0.0
1995.0	94.0	94.0	94.0	1.0	1.0	0.0
3981.0	94.0	94.0	94.0	1.0	1.0	0.0
7943.0	94.0	94.0	94.1	1.5	3.0	0.1
12590.0	94.0	94.0	94.0	3.0	6.0	0.0

TIME WEIGHTING FAST TEST

Time weighting F is tested on the reference range with a single sinusoidal burst of duration 200 ms at a frequency 2000 Hz and an amplitude which produces an indication 4 dB below the upper limit of the primary indicator range when the signal is continuous. (Weight A, Maximum hold)

Ref. level	Expected level	Actual level	Tolerance(dB)		Deviation
dB	dB	dB	+	-	dB
116.0	115.0	114.9	1.0	1.0	-0.1

TIME WEIGHTING SLOW TEST

Time weighting S is tested on the reference range with a single sinusoidal burst of duration 500 ms at a frequency 2000 Hz and an amplitude which produces an indication 4 dB below the upper limit of the primary indicator range when the signal is continuous. (Weight A, Maximum hold)

Ref. level	Expected level	Actual level	Tolerance(dB)		Deviation
dB	dB	dB	+	-	dB
116.0	111.9	111.8	1.0	1.0	-0.1

PEAK RESPONSE TEST

The onset time of the peak detector is tested on the reference range by comparing the response to a 100 us rectangular test pulse with the response to a 10 ms reference pulse of the same amplitude. The amplitude of the 10 ms reference pulse is such as to produce an indication 1 dB below the upper limit of the primary indicator range.

Positive polarities: (Weighting Z, set the generator signal to single, Lzpeak)

Ref. level	Response to 10 ms	Response to 100 us	Tolerance	Deviation
dB	dB	dB	+/- dB	dB
119.0	119.0	119.3	2.0	0.3





Test Data for Sound Level Meter

Page 4 of 5

Sound level meter type: LxT1 Serial No. 0006346 Date 17-Apr-2022  
Microphone type: 377B02 Serial No. 326425  
Preamp type: PRMLxT1L Serial No. 069995 Report: 22CA0412 03

Negative polarities:

Ref. level	Response to 10 ms	Response to 100 us	Tolerance	Deviation
dB	dB	dB	+/- dB	dB
119.0	119.0	119.3	2.0	0.3

RMS ACCURACY TEST

The RMS detector accuracy is tested on the reference range for a crest factor of 3.

Test frequency: 2000 Hz  
Amplitude: 2 dB below the upper limit of the primary indicator range.  
Burst repetition frequency: 40 Hz  
Tone burst signal: 11 cycles of a sine wave of frequency 2000 Hz. (Set to INT)

	Ref. Level	Expected level	Tone burst signal	Tolerance	Deviation
Time weighting	dB	dB	indication(dB)	+/- dB	dB
Slow	114.0+6.6	114.0	113.9	0.5	-0.1

TIME WEIGHTING IMPULSE TEST

Time weighting I is tested on the reference range (Set the SLM to LAImax)

Test frequency: 2000 Hz  
Amplitude: The upper limit of the primary indicator range.

Single sinusoidal burst of duration 5 ms:

Ref. Level	Single burst indication		Tolerance	Deviation
dB	Expected (dB)	Actual (dB)	+/- dB	dB
120.0	111.2	111.1	2.0	-0.1

Repeated at 100 Hz

Ref. Level	Repeated burst indication		Tolerance	Deviation
dB	Expected (dB)	Actual (dB)	+/- dB	dB
120.0	117.3	117.1	1.0	-0.2

TIME AVERAGING TEST

This test compares the SLM reading for continuous sine signals with readings obtained from a sine tone burst sequence having the same RMS level. The test level is 30 dB below the upper limit of the linearity range and repeated for Type 1 SLM with 40 dB below the upper limit of the linearity.

Frequency of tone burst: 4000 Hz

Duration of tone burst: 1 ms

Repetition Time	Level of tone burst	Expected Leq	Actual Leq	Tolerance	Deviation	Remarks
msec	dB	dB	dB	+/- dB	dB	
1000	90.0	90.0	89.9	1.0	-0.1	60s integ.
10000	80.0	80.0	79.9	1.0	-0.1	6min. integ.

PULSE RANGE AND SOUND EXPOSURE LEVEL TEST

The test tone burst signal is superimposed on a baseline signal corresponding to the lower limit of reference range

Test frequency: 4000 Hz

Integration time: 10 sec



Test Data for Sound Level Meter

Page 5 of 5

Sound level meter type: LxT1 Serial No. 0006346 Date 17-Apr-2022  
Microphone type: 377B02 Serial No. 326425  
Preamp type: PRMLxT1L Serial No. 069995 Report: 22CA0412 03

The integrating sound level meter set to Leq:

Duration	Rms level of	Expected	Actual	Tolerance	Deviation
msec	tone burst (dB)	dB	dB	+/- dB	dB
10	90.0	60.0	60.0	1.7	0.0

The integrating sound level meter set to SEL:

Duration	Rms level of	Expected	Actual	Tolerance	Deviation
msec	tone burst (dB)	dB	dB	+/- dB	dB
10.0	90.0	70.0	70.0	1.7	0.0

OVERLOAD INDICATION TEST

For SLM capable of operating in a non-integrating mode.

Test frequency: 2000 Hz  
Amplitude: 2 dB below the upper limit of the primary indicator range.  
Burst repetition frequency: 40 Hz  
Tone burst signal: 11 cycles of a sine wave of frequency 2000 Hz.

Level	Level reduced by	Further reduced	Difference	Tolerance	Deviation
at overload (dB)	1 dB	3 dB	dB	dB	dB
114.2	113.2	110.2	3.0	1.0	0.0

For integrating SLM, with the instrument indicating Leq.

For integrating SLM, with the instrument indicating Leq and set to the reference range. The test signal as following:

The test tone burst signal is superimposed on a baseline signal corresponding to the lower limit of reference range

Test frequency: 4000 Hz  
Integration time: 10 sec  
Single burst duration: 1 msec

Rms level	Level reduced by	Expected level	Actual level	Tolerance	Deviation
at overload (dB)	1 dB	dB	dB	dB	dB
120.9	119.9	79.9	79.9	2.2	0.0

ACOUSTIC TEST

The acoustic test of the complete SLM is tested at the frequency 125 Hz and 8000 Hz using a B&K type 4226 Multifunction Acoustic Calibrator. The test is performed in A weighting.

Frequency	Expected level	Actual level	Tolerance (dB)		Deviation
Hz	dB	Measured (dB)	+	-	dB
1000	94.0	94.0	0.0	0.0	0.0
125	77.9	77.9	1.0	1.0	0.0
8000	92.9	90.8	1.5	3.0	-2.1

-----END-----



## CERTIFICATE OF CALIBRATION

Certificate No.: 21CA1021 05-01

Page: 1 of 2

### Item tested

Description: Acoustical Calibrator (Class 1)  
Manufacturer: Honglim Co., Ltd.  
Type/Model No.: HLES-02  
Serial/Equipment No.: 2016611465  
Adaptors used: -

### Item submitted by

Customer: Lam Environmental Services Limited.  
Address of Customer: -  
Request No.: -  
Date of receipt: 21-Oct-2021

Date of test: 25-Oct-2021

### Reference equipment used in the calibration

Description:	Model:	Serial No.	Expiry Date:	Traceable to:
Lab standard microphone	B&K 4180	2341427	04-May-2022	SCL
Preamplifier	B&K 2673	2239857	31-May-2022	CEPREI
Measuring amplifier	B&K 2610	2346941	01-Jun-2022	CEPREI
Signal generator	DS 360	33873	27-May-2022	CEPREI
Digital multi-meter	34401A	US36087050	27-May-2022	CEPREI
Audio analyzer	8903B	GB41300350	28-May-2022	CEPREI
Universal counter	53132A	MY40003662	02-Jun-2022	CEPREI

### Ambient conditions

Temperature:  $22 \pm 1$  °C  
Relative humidity:  $55 \pm 10$  %  
Air pressure:  $1005 \pm 5$  hPa

### Test specifications


- The Sound Calibrator has been calibrated in accordance with the requirements as specified in IEC 60942 1997 Annex B and the lab calibration procedure SMTP004-CA-156.
- The calibrator was tested with its axis vertical facing downwards at the specific frequency using insert voltage technique.
- The results are rounded to the nearest 0.01 dB and 0.1 Hz and have not been corrected for variations from a reference pressure of 1013.25 hectoPascals as the maker's information indicates that the instrument is insensitive to pressure changes.

### Test results

This is to certify that the sound calibrator conforms to the requirements of annex B of IEC 60942: 1997 for the conditions under which the test was performed. This does not imply that the sound calibrator meets IEC 60942 under any other conditions.


Details of the performed measurements are presented on page 2 of this certificate.

Approved Signatory:

  
Feng Junqi

Date: 26-Oct-2021

Company Chop:



Comments: The results reported in this certificate refer to the condition of the instrument on the date of calibration and carry no implication regarding the long-term stability of the instrument. The results apply to the item as received.





## CERTIFICATE OF CALIBRATION

(Continuation Page)

Certificate No.: 21CA1021 05-01

Page: 2 of 2

## 1, Measured Sound Pressure Level

The output Sound Pressure Level in the calibrator head was measured at the setting and frequency shown using a calibrated laboratory standard microphone and insert voltage technique. The results are given in below with the estimated uncertainties.

(Output level in dB re 20 $\mu$ Pa)			
Frequency Shown Hz	Output Sound Pressure Level Setting dB	Measured Output Sound Pressure Level dB	Estimated Expanded Uncertainty dB
1000	94.00	94.01	0.10

## 2, Sound Pressure Level Stability - Short Term Fluctuations

The Short Term Fluctuations was determined by measuring the maximum and minimum of the fast weighted DC output of the B&K 2610 measuring amplifier over a 20 second time interval as required in the standard. The Short Term Fluctuation was found to be:

At 1000 Hz STF = 0.017 dB

Estimated expanded uncertainty 0.005 dB

## 3, Actual Output Frequency

The determination of actual output frequency was made using a B&K 4180 microphone together with a B&K 2673 preamplifier connected to a B&K 2610 measuring amplifier. The AC output of the B&K 2610 was taken to an universal counter which was used to determine the frequency averaged over 20 second of operation as required by the standard. The actual output frequency at 1 KHz was:

At 1000 Hz Actual Frequency = 1003.7 Hz

Estimated expanded uncertainty 0.1 Hz Coverage factor k = 2.2

## 4, Total Noise and Distortion

For the Total Noise and Distortion measurement, the unfiltered AC output of the B&K 2610 measuring amplifier was connected to an Agilent Type 8903 B distortion analyser. The TND result at 1 KHz was:

At 1000 Hz TND = 1.5 %

Estimated expanded uncertainty 0.7 %

The expanded uncertainties have been calculated in accordance with the ISO Publication "Guide to the expression of uncertainty in measurement", and gives an interval estimated to have a level of confidence of 95%. A coverage factor of 2 is assumed unless explicitly stated.

Calibrated by:

Date:

Fung Chi Yip

25-Oct-2021

- End -

Checked by:

Date:

Chan Yuk Yiu

26-Oct-2021

The standard(s) and equipment used in the calibration are traceable to national or international recognised standards and are calibrated on a schedule to maintain the required accuracy level.





## CERTIFICATE OF CALIBRATION

Certificate No.: 21CA1021 05-02

Page: 1 of 2

### Item tested

Description: Acoustical Calibrator (Class 1)  
Manufacturer: Honglim Co., Ltd.  
Type/Model No.: HLES-02  
Serial/Equipment No.: 2019612534  
Adaptors used:

### Item submitted by

Customer: Lam Environmental Services Limited  
Address of Customer:  
Request No.:  
Date of receipt: 21-Oct-2021

Date of test: 25-Oct-2021

### Reference equipment used in the calibration

Description:	Model:	Serial No.	Expiry Date:	Traceable to:
Lab standard microphone	B&K 4180	2341427	04-May-2022	SCL
Preamplifier	B&K 2673	2239857	31-May-2022	CEPREI
Measuring amplifier	B&K 2610	2346941	01-Jun-2022	CEPREI
Signal generator	DS 360	33873	27-May-2022	CEPREI
Digital multi-meter	34401A	US36087050	27-May-2022	CEPREI
Audio analyzer	8903B	GB41300350	28-May-2022	CEPREI
Universal counter	53132A	MY40003662	02-Jun-2022	CEPREI

### Ambient conditions

Temperature:  $22 \pm 1$  °C  
Relative humidity:  $55 \pm 10$  %  
Air pressure:  $1005 \pm 5$  hPa

### Test specifications

- The Sound Calibrator has been calibrated in accordance with the requirements as specified in IEC 60942 1997 Annex B and the lab calibration procedure SMTP004-CA-156.
- The calibrator was tested with its axis vertical facing downwards at the specific frequency using insert voltage technique.
- The results are rounded to the nearest 0.01 dB and 0.1 Hz and have not been corrected for variations from a reference pressure of 1013.25 hectoPascals as the maker's information indicates that the instrument is insensitive to pressure changes.

### Test results

This is to certify that the sound calibrator conforms to the requirements of annex B of IEC 60942: 1997 for the conditions under which the test was performed. This does not imply that the sound calibrator meets IEC 60942 under any other conditions.


Details of the performed measurements are presented on page 2 of this certificate.

Approved Signatory:

  
Feng Junqi

Date: 26-Oct-2021

Company Chop:



Comments: The results reported in this certificate refer to the condition of the instrument on the date of calibration and carry no implication regarding the long-term stability of the instrument. The results apply to the item as received.

**CERTIFICATE OF CALIBRATION**

(Continuation Page)

Certificate No.: 21CA1021 05-02

Page: 2 of 2

**1, Measured Sound Pressure Level**

The output Sound Pressure Level in the calibrator head was measured at the setting and frequency shown using a calibrated laboratory standard microphone and insert voltage technique. The results are given in below with the estimated uncertainties.

(Output level in dB re 20 $\mu$ Pa)			
Frequency Shown Hz	Output Sound Pressure Level Setting dB	Measured Output Sound Pressure Level dB	Estimated Expanded Uncertainty dB
1000	94.00	94.02	0.10

**2, Sound Pressure Level Stability - Short Term Fluctuations**

The Short Term Fluctuations was determined by measuring the maximum and minimum of the fast weighted DC output of the B&K 2610 measuring amplifier over a 20 second time interval as required in the standard. The Short Term Fluctuation was found to be:

At 1000 Hz STF = 0.011 dB

Estimated expanded uncertainty 0.005 dB

**3, Actual Output Frequency**

The determination of actual output frequency was made using a B&K 4180 microphone together with a B&K 2673 preamplifier connected to a B&K 2610 measuring amplifier. The AC output of the B&K 2610 was taken to an universal counter which was used to determine the frequency averaged over 20 second of operation as required by the standard. The actual output frequency at 1 KHz was:

At 1000 Hz Actual Frequency = 998.27 Hz

Estimated expanded uncertainty 0.1 Hz Coverage factor k = 2.2

**4, Total Noise and Distortion**

For the Total Noise and Distortion measurement, the unfiltered AC output of the B&K 2610 measuring amplifier was connected to an Agilent Type 8903 B distortion analyser. The TND result at 1 KHz was:

At 1000 Hz TND = 0.4 %

Estimated expanded uncertainty 0.7 %

The expanded uncertainties have been calculated in accordance with the ISO Publication "Guide to the expression of uncertainty in measurement", and gives an interval estimated to have a level of confidence of 95%. A coverage factor of 2 is assumed unless explicitly stated.

Calibrated by:

Fung Chi Yip

Date: 25-Oct-2021

- End -

Checked by:

Chan Yuk Yiu

Date: 26-Oct-2021

The standard(s) and equipment used in the calibration are traceable to national or international recognised standards and are calibrated on a schedule to maintain the required accuracy level.



## **REPORT OF EQUIPMENT PERFORMANCE CHECK/CALIBRATION**

**CONTACT:** ALAN NG  
**CLIENT:** LAM GEOTECHNICS LIMITED  
**ADDRESS:** 19/F, REMEX CENTRE,  
42 WONG CHUK HANG ROAD  
HONG KONG

**WORK ORDER:** HK2212773  
**SUB- BATCH:** 0  
**LABORATORY:** HONG KONG  
**DATE RECEIVED:** 11-Apr-2022  
**DATE OF ISSUE:** 19-Apr-2022

### **SPECIFIC COMMENTS**

Equipment information (Brand name, Model No., Serial No. and Equipment No.) is provided by client. The performance of the equipment stated in this report is checked with independent reference material and results compared against a calibrated secondary source.

The "Tolerance Limit" quoted is the acceptance criteria applicable for similar equipment used by the laboratory or quoted from relevant international standards.

The "Next Calibration Date" is recommended according to best practice principle as practised by the laboratory or quoted from relevant international standards.

The validity of equipment/ meter performance only applies to the result(s) stated in the report.

Equipment Type: Multifunctional Meter  
Service Nature: Performance Check  
Scope: Dissolved Oxygen, pH Value, Salinity and Temperature  
Brand Name/ Model No.: [YSI]/ [Professional Plus]  
Serial No./ Equipment No.: [16J104708/17F100236]/ [N/A]  
Date of Calibration: 19-April-2022

### **GENERAL COMMENTS**

This report superseded any previous report(s) with same work order number.

Ms. Lin Wai Yu, Iris  
Assistant Manager - Inorganics

*This report may not be reproduced except with prior written approval from ALS Technichem (HK) Pty Ltd.*

# REPORT OF EQUIPMENT PERFORMANCE CHECK/CALIBRATION



WORK ORDER: HK2212773  
SUB- BATCH: 0  
DATE OF ISSUE: 19-Apr-2022  
CLIENT: LAM GEOTECHNICS LIMITED

Equipment Type: Multifunctional Meter  
Brand Name/ Model No.: [YSI]/ [Professional Plus]  
Serial No./ Equipment No.: [16J104708/17F100236]/ [N/A]  
Date of Calibration: 19-April-2022

Date of Next Calibration: 19-July-2022

## PARAMETERS:

### Temperature

Method Ref: Section 6 of International Accreditation New Zealand Technical Guide No. 3 Second edition March 2008: Working Thermometer Calibration Procedure.

Expected Reading (°C)	Displayed Reading (°C)	Tolerance (°C)
8.0	8.0	+0.0
24.0	23.8	-0.2
38.0	37.1	-0.9
	Tolerance Limit (°C)	±2.0

Reference Thermometer:

\* The calibration solutions do not have Certificate of Analysis.

Remark: "Displayed Reading" presents the figures shown on item under calibration / checking regardless of equipment precision or significant figures.

Ms. Lin Wai Yu, Iris  
Assistant Manager - Inorganics



## REPORT OF EQUIPMENT PERFORMANCE CHECK / CALIBRATION

### Information supplied by customer:

**CONTACT:** MR. DEREK LO **JOB REFERENCE NO.:** 22777053-C31C3403  
**CLIENT:** LAM ENVIRONMENTAL SERVICES LTD.  
**DATE RECEIVED:** 31/03/2022  
**DATE OF ISSUE:** 11/04/2022  
**ADDRESS:** 19/F, REMAX CENTRE, 42 WONG CHUK HANG ROAD,  
HONG KONG  
**PROJECT:** ---

### METHOD OF PERFORMANCE CHECK/ CALIBRATION:

Ref: APHA22nd ed 2130B

### COMMENTS

It is certified that the item under performance check/calibration has been calibrated/checked by corresponding calibrated equipment in the laboratory.


Maximum Tolerance and calibration frequency stated in the report, unless otherwise stated, the internal acceptance criteria of FT Laboratories Ltd will be followed.

<b>Scope of Test:</b>	Turbidity
<b>Equipment Type:</b>	Turbidimeter
<b>Brand Name:</b>	Xin Rui
<b>Model No.:</b>	WGZ-3B
<b>Serial No.:</b>	2005060
<b>Equipment No.:</b>	---
<b>Date of Calibration:</b>	09/04/2022

### Remarks:

This is the Final Report. Results apply to sample(s) as submitted. All pages of this report have been checked and approved for release.

Certified By:

  
WONG Chi Wai Sanio  
Senior Chemist

Issue Date:

11/04/2022

This report may not be reproduced except with prior written approval from FT Laboratories Ltd.

Form No.: HG022-002 Rev 0 20190101

Page 1 of 2



## REPORT OF EQUIPMENT PERFORMANCE CHECK / CALIBRATION

**WORK ORDER:** 22777053-C31C3403  
**DATE OF ISSUE:** 11/04/2022  
**CLIENT:** LAM ENVIRONMENTAL SERVICES LTD.

<b>Equipment Type:</b>	Turbidimeter
<b>Brand Name:</b>	Xin Rui
<b>Model No.:</b>	WGZ-3B
<b>Serial No.:</b>	2005060
<b>Equipment No.:</b>	---
<b>Date of Calibration:</b>	09/04/2022
<b>Date of next Calibration:</b>	10/07/2022
<b>Lab I.D.:</b>	H220017-03

### Parameters:

#### Turbidity

Method Ref: APHA 22<sup>nd</sup> ed. 2130B

Expected Reading (NTU)	Display Reading (NTU)	Tolerance
0	0.00	---
4	3.99	-0.2%
10	9.99	-0.1%
40	40.00	0.0%
100	100.20	0.2%
400	399	-0.2%
1000	1000	0.0%
	Tolerance Limit ( $\pm$ )	10%

Remark: "Displayed Reading" presents the figures shown on item under calibration/checking regardless of equipment precision or significant figures.



***Appendix 4.2***

***Impact Monitoring Schedule***



Contract No. SD 6/2020  
Construction of San Shek Wan Sewage Treatment Works, Associated Submarine Outfall and Pui O Sewerage Works  
Environmental Team Services (2021 - 2022)  
Impact Monitoring Schedule  
May 2022

	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday
01 May	02 May	03 May	04 May	05 May	06 May	07 May
		Noise Monitoring				
		WQM		WQM		WQM
		Mid-Flood 7:05		Mid-Flood 7:04		Mid-Flood* 7:34
		Mid-Ebb 13:48		Mid-Ebb 14:34		Mid-Ebb 16:11
08 May	09 May	10 May	11 May	12 May	13 May	14 May
		Noise Monitoring				
		WQM		Amber rainstorm Canceled WQM		WQM
		Mid-Ebb 19:51		Mid-Ebb 9:59		Mid-Ebb 11:02
		Mid-Flood 7:25		Mid-Flood 15:26		Mid-Flood 17:24
15 May	16 May	17 May	18 May	19 May	20 May	21 May
				Noise Monitoring		
	WQM		WQM		WQM	
	Mid-Ebb 12:17		Mid-Flood 6:56		Mid-Flood 8:14	
	Mid-Flood 19:10		Mid-Ebb 13:45		Mid-Ebb 15:35	
22 May	23 May	24 May	25 May	26 May	27 May	28 May
				Noise Monitoring		
	WQM		WQM		WQM	
	Mid-Flood 11:41		Mid-Ebb 9:25		Mid-Ebb 10:43	
	Mid-Ebb 18:54		Mid-Flood 14:50		Mid-Flood 16:50	
29 May	30 May	31 May	01 Jun	02 Jun	03 Jun	04 Jun
		WQM				
		Mid-Ebb 12:55				
		Mid-Flood 19:55				

Remark:

Noise Monitoring to be conducted at the designated monitoring stations when there are project-related construction activities undertaken within a radius of 300m from the monitoring stations; and  
Water Quality Monitoring to be scheduled upon the commencement of marine construction work site and conducted during marine construction works.










***Appendix 4.3***

***Noise Monitoring Results and Graphical Presentations***

**Graphic Presentation of Noise Monitoring Result**

Day Time (0700 - 1900hrs on normal weekdays)





# Noise Monitoring Result

## Day Time (0700 - 1900hrs on normal weekdays)

Location: N12a - Light Pole in front of 47 Lo Uk Tsuen

Date	Weather	Time	Measurement Noise Level			Average Noise Level	Baseline Level	Construction Noise Level	Limit Level
			Leq	L10	L90	Leq	Leq	Leq	Leq
			Unit: dB(A), (5-min)			Unit: dB(A), (30-min)			
3 May 2022	Sunny	11:36	71.2	72.3	47.5	69.8	73.3	<Baseline Level	75
		11:41	71.2	74.1	47.1				
		11:46	69.4	73.4	50.6				
		11:51	68.4	69.1	48.0				
		11:56	69.0	72.5	45.7				
		12:01	68.5	70.5	48.7				
10 May 2022	Cloudy	10:26	72.0	74.3	47.7	70.0	73.3	<Baseline Level	75
		10:31	69.3	74.0	52.3				
		10:36	69.7	73.7	49.3				
		10:41	68.6	71.7	47.2				
		10:46	70.5	74.8	46.9				
		10:51	69.1	72.9	44.8				
19 May 2022	Sunny	11:41	73.8	77.9	51.4	72.3	73.3	<Baseline Level	75
		11:46	72.2	74.9	51.3				
		11:51	68.4	71.0	54.2				
		11:56	71.2	75.1	54.4				
		12:01	72.5	75.6	53.8				
		12:06	73.6	76.3	54.2				
26 May 2022	Cloudy	10:06	70.3	74.4	55.3	70.7	73.3	<Baseline Level	75
		10:11	68.1	71.9	53.8				
		10:16	70.8	75.0	53.1				
		10:21	71.5	76.0	51.7				
		10:26	70.6	74.6	51.2				
		10:31	72.1	75.0	50.8				



**Noise Monitoring Result**

**Day Time (0700 - 1900hrs on normal weekdays)**

Location: N12b - 11B Lo Uk Tsuen

Date	Weather	Time	Measurement Noise Level			Average Noise Level	Baseline Level	Construction Noise Level	Limit Level
			Leq	L10	L90	Leq	Leq	Leq	Leq
			Unit: dB(A), (5-min)			Unit: dB(A), (30-min)			
3 May 2022	Sunny	11:01	57.4	62.6	45.3	59.8	76.8	<Baseline Level	75
		11:06	61.7	62.5	42.5				
		11:11	63.3	65.0	46.3				
		11:16	57.7	61.1	45.9				
		11:21	59.5	63.0	44.9				
		11:26	59.1	63.7	41.9				
10 May 2022	Cloudy	11:01	58.2	62.5	48.0	62.9	76.8	<Baseline Level	75
		11:06	64.0	67.5	50.3				
		11:11	66.0	67.0	47.9				
		11:16	69.8	75.1	57.2				
		11:21	59.5	62.7	47.7				
		11:26	59.7	62.8	47.7				
19 May 2022	Sunny	11:06	64.4	69.5	51.3	63.9	76.8	<Baseline Level	75
		11:11	62.9	64.7	51.5				
		11:16	62.9	64.2	51.5				
		11:21	66.2	68.5	57.2				
		11:26	64.2	66.1	54.8				
		11:31	61.2	64.9	51.5				
26 May 2022	Cloudy	10:41	58.6	62.1	48.3	61.4	76.8	<Baseline Level	75
		10:46	60.7	63.6	49.1				
		10:51	61.8	63.5	49.8				
		10:56	62.0	63.9	58.5				
		11:01	62.7	64.6	50.9				
		11:06	61.5	63.9	49.3				



# Noise Monitoring Result

## Day Time (0700 - 1900hrs on normal weekdays)

Location: N13 - 74 Pui O San Wai Tsuen

Date	Weather	Time	Measurement Noise Level			Average Noise Level	Baseline Level	Construction Noise Level	Limit Level
			Leq	L10	L90	Leq	Leq	Leq	Leq
			Unit: dB(A), (5-min)			Unit: dB(A), (30-min)			
3 May 2022	Sunny	14:01	58.5	62.7	51.0	62.1	73.6	<Baseline Level	75
		14:06	61.3	64.8	51.4				
		14:11	59.4	62.7	50.7				
		14:16	64.3	67.4	51.4				
		14:21	62.4	66.4	50.9				
		14:26	63.7	67.6	51.3				
10 May 2022	Cloudy	11:31	58.6	61.9	52.1	64.7	73.6	<Baseline Level	75
		11:36	63.9	67.5	53.2				
		11:41	61.5	65.2	52.9				
		11:46	62.7	65.0	52.5				
		11:51	62.6	65.1	52.3				
		11:56	69.7	70.8	54.0				
19 May 2022	Sunny	13:51	66.7	69.0	52.5	64.4	73.6	<Baseline Level	75
		13:56	65.9	69.9	51.6				
		14:01	64.1	68.6	51.6				
		14:06	58.8	62.2	51.5				
		14:11	62.1	65.7	51.7				
		14:16	64.7	69.3	53.2				
26 May 2022	Cloudy	11:16	66.5	66.8	53.8	64.7	73.6	<Baseline Level	75
		11:21	64.3	68.1	55.3				
		11:26	61.9	65.8	52.2				
		11:31	64.1	67.6	52.7				
		11:36	63.6	67.5	52.6				
		11:41	66.1	68.7	56.2				





# Noise Monitoring Result

## Day Time (0700 - 1900hrs on normal weekdays)

Location: N14 - Fence in front of South Lantau Community Centre

Date	Weather	Time	Measurement Noise Level			Average Noise Level	Baseline Level	Construction Noise Level	Limit Level
			Leq	L10	L90	Leq	Leq	Leq	Leq
			Unit: dB(A), (5-min)			Unit: dB(A), (30-min)			
3 May 2022	Sunny	12:51	68.9	68.3	51.0	65.5	62.2	63	75
		12:56	57.9	59.7	45.0				
		13:01	61.7	61.1	44.9				
		13:06	66.4	69.4	48.2				
		13:11	63.4	65.3	47.6				
		13:16	67.0	68.3	49.7				
10 May 2022	Cloudy	14:26	62.8	65.4	42.4	61.8	62.2	<Baseline Level	75
		14:31	58.2	58.5	43.4				
		14:36	56.0	58.2	44.2				
		14:41	66.1	67.9	46.2				
		14:46	60.1	62.0	45.4				
		14:51	60.2	61.9	44.7				
19 May 2022	Sunny	12:41	60.7	61.5	46.7	61.5	62.2	<Baseline Level	75
		12:46	62.1	59.9	44.9				
		12:51	60.2	62.5	45.6				
		12:56	59.8	63.8	46.3				
		13:01	62.0	65.6	47.9				
		13:06	63.4	66.4	48.8				
26 May 2022	Cloudy	13:51	57.7	59.8	51.1	59.7	62.2	<Baseline Level	75
		13:56	58.4	61.4	51.4				
		14:01	58.9	63.9	50.3				
		14:06	62.6	64.0	49.8				
		14:11	57.6	59.4	50.3				
		14:16	60.4	63.2	47.1				



Noise Monitoring Result

Day Time (0700 - 1900hrs on normal weekdays)

Location: N17 - Bui O Public School




Date	Weather	Time	Measurement Noise Level			Average Noise Level	Baseline Level	Construction Noise Level	Limit Level
			Leq	L10	L90	Leq	Leq	Leq	Leq
			Unit: dB(A), (5-min)			Unit: dB(A), (30-min)			
3 May 2022	Sunny	13:26	49.8	51.8	44.0	49.1	62.3	<Baseline Level	70
		13:31	47.1	49.6	43.2				
		13:36	50.9	53.2	44.6				
		13:41	48.0	51.4	42.1				
		13:46	49.3	52.1	42.5				
		13:51	48.7	51.0	45.3				
10 May 2022	Cloudy	13:01	53.8	55.4	46.0	54.7	62.3	<Baseline Level	70
		13:06	54.9	56.9	45.2				
		13:11	53.7	56.4	46.4				
		13:16	53.3	55.2	47.6				
		13:21	56.3	58.0	51.3				
		13:26	55.4	57.7	51.6				
19 May 2022	Sunny	13:16	55.0	58.7	49.0	53.4	62.3	<Baseline Level	70
		13:21	52.3	54.5	48.9				
		13:26	50.5	52.7	46.0				
		13:31	53.1	55.2	48.9				
		13:36	55.2	58.7	49.0				
		13:41	52.3	54.4	48.0				
26 May 2022	Cloudy	13:16	50.3	52.0	48.0	51.1	62.3	<Baseline Level	70
		13:21	50.8	52.7	47.6				
		13:26	50.0	51.9	47.6				
		13:31	50.8	53.4	46.9				
		13:36	52.2	55.2	48.0				
		13:41	51.8	53.4	47.9				






***Appendix 4.4***

***Marine Water Quality Monitoring Results and Graphical Presentations***

### Graphic Presentation of WQM Result






### Graphic Presentation of WQM Result








### Graphic Presentation of WQM Result






### Graphic Presentation of WQM Result






Graphic Presentation of WQM Result






Graphic Presentation of WQM Result


Station SR9 - DO



Station SR9 - Turbidity (Depth-average)




Station SR9 - Suspended Solid (Depth Average)






Graphic Presentation of WQM Result


Station SR10 - DO



Station SR10 - Turbidity (Depth-average)



Station SR10 - Suspended Solid (Depth-average)









Graphic Presentation of WQM Result


Station SR12 - DO



Station SR12 - Turbidity (Depth-average)




Station SR12 - Suspended Solid (Depth-average)




### Graphic Presentation of WQM Result


#### Station SR15 - DO



#### Station SR15 - Turbidity (Depth-average)



#### Station SR15 - Suspended Solid (Depth-average)



### Baseline Water Quality Monitoring at Station SR4 (surface) - Ebb Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR4	3/5/2022	Sunny	12:51	3.8	1.0	22.90	22.95	8.41	8.41	32.76	32.82	90.80	88.45	6.46	6.29	4.63	4.54	6.0	5.8
			12:53	3.8	1.0	23.00		8.40		32.87		86.10		6.11		4.45		5.5	
	5/5/2022	Sunny	12:50	3.7	1.0	24.20	24.38	8.53	8.53	32.65	32.56	111.10	111.15	7.73	7.72	0.01	0.01	2.3	2.4
			12:52	3.7	1.0	24.56		8.52		32.47		111.20		7.71		0.01		2.5	
	7/5/2022	Cloudy	12:50	3.3	1.0	25.20	25.25	8.60	8.60	32.36	32.39	102.30	108.65	7.02	7.44	2.33	2.34	2.4	2.6
			12:52	3.3	1.0	25.30		8.60		32.42		115.00		7.86		2.31		2.8	
	10/5/2022	Rain	13:40	3.3	1.0	26.16	26.17	8.37	8.37	28.65	28.42	81.70	81.75	5.62	5.64	0.07	0.06	1.6	1.8
			13:42	3.3	1.0	26.18		8.37		28.19		81.80		5.65		0.04		1.9	
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	9:31	3.2	1.0	24.40	24.40	8.10	8.11	25.95	25.95	88.50	86.75	6.38	6.26	1.20	1.39	2.4	2.3
			9:33	3.2	1.0	24.40		8.12		25.95		85.00		6.13		1.57		2.2	
	16/5/2022	Rain	9:25	3.9	1.0	22.90	22.90	8.10	8.11	30.34	30.35	66.30	63.80	4.82	4.63	5.95	5.99	8.9	8.7
			9:27	3.9	1.0	22.90		8.12		30.35		61.30		4.43		6.03		8.5	
	18/5/2022	Cloudy	12:52	3.1	1.0	23.40	23.80	8.42	8.42	31.68	31.64	79.10	78.80	5.61	5.55	3.62	3.37	3.3	3.3
			12:54	3.1	1.0	24.20		8.41		31.60		78.50		5.49		3.11		3.2	
	20/5/2022	Fine	12:45	3.5	1.0	25.80	26.30	8.42	8.42	30.43	30.47	81.80	80.85	5.61	5.50	1.58	1.64	4.4	4.2
			12:47	3.5	1.0	26.80		8.42		30.50		79.90		5.39		1.69		4.0	
	23/5/2022	Cloudy	12:53	3.5	1.0	24.90	24.90	8.54	8.53	29.27	29.40	77.20	73.65	5.41	5.16	0.38	1.44	2.7	2.9
			12:55	3.5	1.0	24.90		8.52		29.52		70.10		4.90		2.49		3.0	
	25/5/2022	Rain	8:55	3.7	1.0	24.60	24.60	8.20	8.22	30.56	30.59	75.60	76.35	5.29	5.34	0.46	0.73	2.4	2.4
			8:57	3.7	1.0	24.60		8.23		30.61		77.10		5.39		1.00		2.4	
	27/5/2022	Rain	9:19	3.6	1.0	26.10	26.15	8.13	8.15	30.05	29.98	76.80	78.30	5.25	5.35	2.09	2.10	3.2	3.4
			9:21	3.6	1.0	26.20		8.17		29.90		79.80		5.45		2.11		3.5	
	31/5/2022	Rain	9:16	3.5	1.0	27.30	17.30	8.27	8.30	24.13	23.80	88.40	86.45	6.12	6.00	6.48	4.50	10.9	11.1
			9:18	3.5	1.0	7.30		8.33		23.46		84.50		5.87		2.52		11.2	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station SR4 (surface) - Flood Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR4	3/5/2022	Sunny	9:23	3.9	1.0	22.50	22.55	8.22	8.23	32.86	32.86	77.00	82.70	5.52	5.92	4.67	5.67	3.4	3.6
			9:25	3.9	1.0	22.60		8.23		32.85		88.40		6.31		6.67		3.8	
	5/5/2022	Sunny	9:30	3.9	1.0	23.60	23.65	8.29	8.31	32.54	32.60	101.00	104.35	7.11	7.34	2.55	2.97	3.1	3.0
			9:32	3.9	1.0	23.70		8.32		32.66		107.70		7.56		3.39		2.8	
	7/5/2022	cloudy	9:21	3.1	1.0	24.70	24.80	8.46	8.47	32.35	32.39	112.30	115.90	7.75	7.99	1.25	1.21	3.0	3.2
			9:23	3.1	1.0	24.90		8.47		32.42		119.50		8.22		1.19		3.4	
	10/5/2022	Rain	10:53	3.0	1.0	26.26	26.25	8.44	8.41	28.95	28.85	85.70	90.75	5.88	6.23	0.01	0.01	1.5	1.6
			10:55	3.0	1.0	26.23		8.37		28.75		95.80		6.58		0.01		1.6	
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	12:59	3.3	1.0	24.70	24.70	8.38	8.39	25.79	25.80	83.40	83.05	5.98	5.96	1.60	1.35	<1.0	1.0
			13:01	3.3	1.0	24.70		8.39		25.81		82.70		5.93		1.09		<1.0	
	16/5/2022	Rain	12:50	3.1	1.0	21.90	22.40	8.33	8.33	30.96	30.92	84.50	80.50	6.19	5.85	6.03	5.87	4.9	4.8
			12:52	3.1	1.0	22.90		8.32		30.88		76.50		5.50		5.71		4.7	
	18/5/2022	Cloudy	9:26	3.2	1.0	23.20	23.30	8.20	8.22	31.62	31.67	80.60	73.60	5.74	5.24	3.93	3.88	4.3	4.2
			9:28	3.2	1.0	23.40		8.23		31.72		66.60		4.73		3.82		4.1	
	20/5/2022	Fine	9:12	3.4	1.0	24.70	24.70	8.17	8.19	30.54	30.54	69.90	71.25	4.88	4.98	1.51	1.52	3.7	3.6
			9:14	3.4	1.0	24.70		8.20		30.53		72.60		5.07		1.52		3.4	
	23/5/2022	Cloudy	9:11	3.4	1.0	24.60	24.65	8.22	8.25	29.38	29.41	87.50	86.70	6.16	6.10	0.89	0.78	2.6	2.5
			9:13	3.4	1.0	24.70		8.28		29.43		85.90		6.04		0.66		2.4	
	25/5/2022	Rain	12:56	3.2	1.0	24.90	24.95	8.38	8.39	30.51	30.51	69.00	70.60	4.80	4.91	1.51	1.52	2.4	2.6
			12:58	3.2	1.0	25.00		8.39		30.51		72.20		5.01		1.52		2.8	
	27/5/2022	Rain	12:50	4.0	1.0	26.20	26.20	8.45	8.45	29.94	30.09	80.60	79.00	5.50	5.39	1.63	1.83	4.0	3.9
			12:52	4.0	1.0	26.20		8.44		30.24		77.40		5.28		2.03		3.7	
	31/5/2022	Rain	12:50	3.2	1.0	26.70	27.05	6.59	6.62	23.46	23.08	78.50	84.05	5.51	5.88	1.04	1.21	2.9	3.1
			12:52	3.2	1.0	27.40		6.64		22.69		89.60		6.24		1.38		3.3	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station SR4 (Bottom) - Ebb Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR4	3/5/2022	Sunny	12:55	3.8	2.8	23.00	23.00	8.40	8.40	32.87	32.90	86.10	82.40	6.11	5.85	4.45	4.77	8.2	8.4
			12:57	3.8	2.8	23.00		8.40		32.93		78.70		5.58		5.09		8.5	
			12:54	3.7	2.7	24.10	23.80	8.54	8.50	32.64	32.79	116.90	103.70	8.14	7.25	0.01	0.01	5.3	5.1
	5/5/2022	Sunny	12:56	3.7	2.7	23.50		8.45		32.93		90.50		6.36		0.01		4.8	
			12:54	3.3	2.3	25.20	25.20	8.61	8.61	32.42	32.42	123.10	121.70	8.43	8.34	2.46	2.43	3.7	4.0
	7/5/2022	Cloudy	12:56	3.3	2.3	25.20		8.61		32.42		120.30		8.24		2.41		4.2	
			12:54	3.3	2.3	25.20		8.61		32.42		120.30		8.24		2.41		4.2	
	10/5/2022	Rain	13:44	0.0	2.3	26.16	26.17	8.37	8.38	28.92	28.91	82.00	85.15	5.64	5.86	0.30	0.44	2.2	2.3
			13:46	3.3	2.3	26.18		8.38		28.90		88.30		6.07		0.58		2.3	
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	9:35	3.2	2.2	24.50	24.50	8.13	8.14	27.63	27.67	77.00	77.25	5.49	5.51	2.05	2.07	2.7	2.9
			9:37	3.2	2.2	24.50		8.14		27.70		77.50		5.52		2.09		3.1	
	16/5/2022	Rain	9:29	3.1	2.9	22.90	22.90	8.13	8.14	30.19	30.27	71.30	69.20	5.15	5.00	5.69	5.80	10.0	9.9
			9:31	3.9	2.9	22.90		8.14		30.34		67.10		4.84		5.90		9.7	
	18/5/2022	Cloudy	12:56	3.1	2.1	23.60	23.65	8.42	8.42	31.69	31.68	80.30	80.05	5.39	5.52	3.21	3.00	3.0	2.9
			12:58	3.1	2.1	23.70		8.42		31.66		79.80		5.64		2.79		2.8	
	20/5/2022	Fine	12:50	3.5	2.5	26.10	25.85	8.42	8.43	30.64	30.61	79.30	82.70	5.52	5.72	1.69	1.68	3.3	3.5
			12:52	3.5	2.5	25.60		8.43		30.58		86.10		5.92		1.66		3.6	
	23/5/2022	Cloudy	12:57	3.5	2.5	24.80	24.75	8.55	8.56	29.36	29.36	81.00	84.10	5.68	5.91	0.01	0.03	3.7	3.9
			12:59	3.5	2.5	24.70		8.56		29.35		87.20		6.13		0.05		4.0	
	25/5/2022	Rain	9:00	3.7	2.7	24.60	24.60	8.25	8.27	30.62	30.61	77.70	78.60	5.43	5.50	0.47	1.86	1.4	1.3
			9:02	3.7	2.7	24.60		8.28		30.60		79.50		5.56		3.24		1.2	
	27/5/2022	Rain	9:23	3.6	2.6	26.20	26.20	8.23	8.22	29.97	29.98	81.20	80.30	5.54	5.49	3.17	2.44	2.9	2.7
			9:25	3.6	2.6	26.20		8.20		29.99		79.40		5.43		1.70		2.5	
	31/5/2022	Rain	9:20	3.5	2.5	27.30	27.30	8.35	8.37	24.46	24.43	87.80	87.90	6.07	6.08	7.48	7.83	13.1	13.4
			9:22	3.5	2.5	27.30		8.38		24.40		88.00		6.08		8.18		13.6	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station SR4 (Bottom) - Flood Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR4	3/5/2022	Sunny	9:27	3.9	2.9	22.60	22.55	8.26	8.26	32.88	32.88	66.20	75.90	4.73	5.43	4.18	4.83	5.3	5.2
			9:29	3.9	2.9	22.50		8.26		32.88		85.60		6.12		5.47		5.0	
			9:34	3.9	2.9	23.80	23.80	8.34	8.35	32.69	32.69	97.60	100.95	6.84	7.08	8.88	5.62	<1.0	1.0
	5/5/2022	Sunny	9:36	3.9	2.9	23.80		8.35		32.69		104.30		7.31		2.35		<1.0	
			9:24	3.1	2.1	24.70	24.75	8.51	6.01	32.42	32.39	114.80	112.90	7.92	7.79	1.34	1.38	4.7	4.9
	7/5/2022	cloudy	9:26	3.1	2.1	24.80		3.50		32.35		111.00		7.66		1.39		5.0	
			10:57	3.0	2.0	20.20	23.22	8.36	8.40	38.49	32.98	116.20	117.75	3.00	5.60	0.01	0.01	5.7	5.6
	10/5/2022	Rain	10:59	3.0	2.0	26.24		8.43		27.46		119.30		8.20		0.01		5.4	
			10:59	3.0	2.0	26.24		8.43		27.46		119.30		8.20		0.01		5.4	
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	13:03	3.3	2.3	24.80	24.75	8.39	8.39	26.10	26.02	81.70	82.95	5.85	5.94	1.22	1.47	1.1	1.2
			13:05	3.3	2.3	24.70		8.39		25.93		84.20		6.03		1.72		1.3	
	16/5/2022	Rain	12:54	3.1	2.1	23.50	23.50	8.30	8.30	31.00	31.01	67.80	70.35	4.82	5.00	5.70	5.78	6.5	6.3
			12:56	3.1	2.1	23.50		8.30		31.02		72.90		5.18		5.85		6.1	
	18/5/2022	Cloudy	9:30	3.2	2.2	23.60	23.60	8.25	8.25	31.72	31.72	73.30	73.30	5.18	5.18	4.22	4.22	4.9	4.7
			9:32	3.2	2.2	-		-		-		-		-		-		4.5	
	20/5/2022	Fine	9:16	3.4	2.4	24.60	24.60	8.24	8.24	30.63	30.62	63.50	71.90	4.44	5.03	1.50	1.65	4.1	4.3
			9:18	3.4	2.4	24.60		8.24		30.61		80.30		5.61		1.80		4.5	
	23/5/2022	Cloudy	9:15	3.4	2.4	24.80	24.80	8.31	8.33	29.45	29.46	86.90	84.15	6.10	5.91	0.83	0.92	5.4	5.5
			9:17	3.4	2.4	24.80		8.34		29.46		81.40		5.71		1.00		5.5	
	25/5/2022	Rain	13:00	3.2	2.2	24.80	24.80	8.39	8.40	30.62	30.61	76.40	77.00	5.32	5.36	2.26	1.75	4.8	4.6
			13:02	3.2	2.2	24.80		8.40		30.60		77.60		5.40		1.23		4.4	
	27/5/2022	Rain	12:54	4.0	3.0	26.20	26.20	8.47	8.47	29.95	29.95	74.20	74.55	5.07	5.09	1.00	1.77	4.8	4.6
			12:56	4.0	3.0	26.20		8.46		29.95		74.90		5.11		2.54		4.4	
	31/5/2022	Rain	12:55	3.2	2.2	27.60	27.55	6.65	7.66	22.66	22.66	93.20	94.35	6.48	6.56	1.26	1.52	15.5	15.3
			12:57	3.2	2.2	27.50		6.66		22.66		95.50		6.64		1.78		15.0	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

**Baseline Water Quality Monitoring at Station SR5 (surface) - Ebb Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR5	3/5/2022	Sunny	12:43	4.7	1.0	24.50	23.70	8.40	8.41	32.75	32.82	92.50	88.05	6.39	6.17	4.16	3.31	2.6	2.9
			12:45	4.7	1.0	22.90		8.42		32.88		83.60		5.95		2.46		3.1	
	5/5/2022	Sunny	12:41	4.7	1.0	24.10	24.15	8.50	8.51	32.48	32.52	109.50	111.35	7.64	7.76	0.01	0.01	4.5	4.7
			12:43	4.7	1.0	24.20		8.51		32.55		113.20		7.88		0.01		4.8	
	7/5/2022	Cloudy	12:42	4.4	1.0	25.00	25.15	8.59	8.59	32.53	32.44	85.60	96.70	5.88	6.63	2.14	2.18	4.0	3.9
			12:44	4.4	1.0	25.30		8.58		32.35		107.80		7.37		2.18		3.8	
	10/5/2022	Rain	13:31	4.5	1.0	26.08	26.09	8.38	8.36	28.59	28.74	87.10	87.25	6.01	6.02	0.12	0.09	1.3	1.5
			13:33	4.5	1.0	26.09		8.34		28.88		87.40		6.02		0.06		1.7	
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	9:39	4.3	1.0	24.50	24.50	8.19	8.20	25.47	25.44	78.20	80.00	5.64	5.78	1.91	1.80	2.8	3.0
			9:41	4.3	1.0	24.50		8.20		25.41		81.80		5.91		1.69		3.2	
	16/5/2022	Rain	9:33	3.6	1.0	23.30	23.35	8.19	8.18	30.29	30.21	81.30	77.75	5.83	5.57	5.51	5.05	7.8	8.0
			9:35	3.6	1.0	23.40		8.17		30.12		74.20		5.31		4.58		8.2	
	18/5/2022	Cloudy	12:43	4.9	1.0	25.00	24.25	8.41	8.42	31.10	31.21	81.30	82.05	5.63	5.76	2.37	2.18	1.8	1.7
			12:45	4.9	1.0	23.50		8.43		31.32		82.80		5.88		1.99		1.6	
	20/5/2022	Fine	12:37	3.8	1.0	25.40	25.20	8.40	8.42	30.56	30.60	73.20	77.95	5.05	5.40	1.23	1.57	2.5	2.5
			12:39	3.8	1.0	25.00		8.43		30.64		82.70		5.74		1.90		2.5	
	23/5/2022	Cloudy	12:43	4.7	1.0	24.70	24.75	8.56	8.56	29.24	29.27	87.40	86.45	6.15	6.08	0.50	0.26	4.0	4.2
			12:45	4.7	1.0	24.80		8.56		29.29		85.50		6.00		0.01		4.4	
	25/5/2022	Rain	9:04	3.8	1.0	24.70	24.70	8.32	8.32	30.54	30.54	73.10	74.75	5.11	5.23	1.10	1.10	2.4	2.3
			9:06	3.8	1.0	24.70		8.31		30.54		76.40		5.35		1.10		2.1	
	27/5/2022	Rain	9:27	4.2	1.0	26.20	26.25	8.22	8.24	30.35	30.28	73.20	75.50	4.99	5.14	1.91	2.71	1.6	1.8
			9:29	4.2	1.0	26.30		8.25		30.21		77.80		5.29		3.51		1.9	
	31/5/2022	Rain	9:25	4.7	1.0	27.40	27.30	8.48	8.46	23.99	24.54	80.70	85.70	5.59	5.92	2.95	5.90	5.6	5.8
			9:27	4.7	1.0	27.20		8.44		25.09		90.70		6.25		8.84		6.0	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

**Baseline Water Quality Monitoring at Station SR5 (surface) - Flood Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR5	3/5/2022	Sunny	9:31	4.7	1.0	22.50	22.60	8.29	8.30	32.74	32.74	90.10	86.30	6.45	6.17	4.10	3.74	3.6	3.5
			9:33	4.7	1.0	22.70		8.30		32.73		82.50		5.89		3.37		3.4	
	5/5/2022	Sunny	9:39	4.4	1.0	24.10	23.95	8.34	8.34	32.61	32.61	80.40	93.05	5.61	6.41	3.98	4.18	5.0	5.3
			9:41	4.4	1.0	23.80		8.34		32.61		105.70		7.21		4.37		5.6	
	7/5/2022	cloudy	9:28	4.3	1.0	25.30	25.05	8.48	8.48	32.42	32.39	84.70	101.70	5.80	7.00	1.69	1.68	3.1	3.2
			9:30	4.3	1.0	24.80		8.47		32.35		118.70		8.19		1.64		3.3	
	10/5/2022	Rain	11:03	4.1	1.0	26.33	26.33	8.48	8.42	28.83	28.86	114.30	104.50	7.83	7.16	0.84	0.45	1.5	1.6
			11:05	4.1	1.0	26.33		8.35		28.88		94.70		6.49		0.06		1.6	
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	12:49	3.5	1.0	24.80	24.80	8.38	8.39	25.06	25.04	83.50	82.80	6.00	5.95	1.63	1.80	1.7	1.7
			12:51	3.5	1.0	24.80		8.39		25.01		82.10		5.90		1.96		1.6	
	16/5/2022	Rain	12:41	4.2	1.0	22.80	22.50	8.34	8.34	29.97	30.20	77.80	78.10	5.63	5.68	3.51	3.36	3.4	3.6
			12:43	4.2	1.0	22.20		8.34		30.42		78.40		5.72		3.21		3.8	
	18/5/2022	Cloudy	9:35	5.0	1.0	23.10	23.20	8.29	8.30	31.66	31.65	72.10	74.85	5.15	5.34	1.99	2.65	3.0	3.2
			9:37	5.0	1.0	23.30		8.30		31.64		77.60		5.52		3.30		3.4	
	20/5/2022	Fine	9:21	3.6	1.0	24.60	24.60	8.27	8.26	30.83	30.82	79.20	78.05	5.53	5.45	-	1.60	3.1	3.3
			9:23	3.6	1.0	24.60		8.25		30.81		76.90		5.37		1.60		3.5	
	23/5/2022	Cloudy	9:20	2.9	1.0	24.80	24.70	8.35	8.37	29.24	29.30	87.80	87.55	6.17	6.16	1.42	1.34	3.4	3.2
			9:22	2.9	1.0	24.60		8.38		29.35		87.30		6.14		1.25		3.0	
	25/5/2022	Rain	12:46	3.9	1.0	25.20	25.10	8.37	8.38	30.41	29.85	72.60	74.25	5.03	5.17	1.90	1.95	2.6	2.7
			12:48	3.9	1.0	25.00		8.39		29.29		75.90		5.31		1.99		2.8	
	27/5/2022	Rain	12:41	3.8	1.0	26.20	26.20	8.42	8.42	30.29	30.28	79.00	79.65	5.39	5.43	1.98	2.14	1.5	1.7
			12:43	3.8	1.0	26.20		8.42		30.27		80.30		5.47		2.30		1.8	
	31/5/2022	Rain	12:42	4.5	1.0	26.40	26.70	8.63	8.62	21.94	22.25	92.40	90.85	6.58	6.43	1.71	1.96	5.3	5.2
			12:44	4.5	1.0	27.00		8.61		22.56		89.30		6.27		2.21		5.1	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.



**Baseline Water Quality Monitoring at Station SR5 (Bottom) - Ebb Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH		Salinity		DO Saturation		DO		Turbidity		SS		
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	mg/L
SR5	3/5/2022	Sunny	12:47	4.7	3.7	23.10	23.05	8.41	8.41	32.97	32.94	87.90	90.10	6.22	6.39	3.55	3.15	4.9	4.8	
			12:49	4.7	3.7	23.00		8.41		32.91		92.30		6.55		2.75		4.6		
	5/5/2022	Sunny	12:45	4.7	3.7	24.00	24.05	8.51	8.51	32.61	32.60	111.70	109.05	7.80	7.61	0.01	0.01	3.1	3.0	
			12:47	4.7	3.7	24.10		8.51		32.59		106.40		7.42		0.01		2.8		
	7/5/2022	Cloudy	12:46	4.4	3.4	25.00	25.00	8.59	8.59	32.40	32.42	120.80	118.20	8.30	8.12	2.33	2.33	2.6	2.6	
			12:48	4.4	3.4	25.00		8.59		32.43		115.60		7.94		2.32		2.6		
	10/5/2022	Rain	13:35	4.5	3.5	26.10	26.10	8.36	8.36	28.74	28.80	84.70	85.35	5.83	5.88	0.01	0.10	2.2	2.3	
			13:37	4.5	3.5	26.10		8.36		28.85		86.00		5.92		0.18		2.4		
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																	
	14/5/2022	Rain	9:43	4.3	3.3	24.50	24.50	8.18	8.19	27.58	27.65	80.70	80.90	5.75	5.76	2.81	2.64	4.0	4.2	
			9:45	4.3	2.6	24.50		8.19		27.71		81.10		5.77		2.47		4.4		
	16/5/2022	Rain	9:37	4.9	2.6	23.50	23.50	8.20	8.21	30.46	30.53	61.30	64.95	4.37	4.63	5.10	5.50	5.7	5.6	
			9:39	3.6	2.6	23.50		8.21		30.60		68.60		4.89		5.90		5.4		
	18/5/2022	Cloudy	12:48	4.9	3.9	23.60	23.55	8.42	8.42	31.36	31.34	81.30	84.65	5.76	6.01	1.99	2.09	4.8	4.6	
			12:50	4.9	3.9	23.50		8.41		31.31		88.00		6.25		2.19		4.4		
	20/5/2022	Fine	12:41	3.8	2.8	25.10	26.25	8.42	8.41	30.64	30.31	79.30	78.25	5.53	5.35	1.69	1.69	3.0	3.2	
			12:43	3.8	2.8	27.40		8.39		29.97		77.20		5.17		1.69		3.3		
	23/5/2022	Cloudy	12:47	4.7	3.7	24.90	24.90	8.52	8.52	29.46	29.51	87.20	86.35	6.11	6.05	2.10	2.86	6.2	6.0	
			12:49	4.7	3.7	24.90		8.51		29.56		85.50		5.99		3.61		5.8		
	25/5/2022	Rain	9:10	3.8	2.8	24.70	24.70	8.33	8.34	30.55	30.54	79.00	79.25	5.52	5.54	1.55	1.05	4.7	4.6	
			9:12	3.8	2.8	24.70		8.34		30.53		79.50		5.55		0.55		4.4		
	27/5/2022	Rain	9:30	4.2	3.2	26.30	26.30	8.28	8.28	30.02	30.05	80.50	80.85	5.49	5.52	1.97	1.80	2.7	2.9	
			9:32	4.2	3.2	26.30		8.27		30.07		81.20		5.54		1.63		3.0		
	31/5/2022	Rain	9:29	4.7	3.7	27.50	27.35	8.52	8.57	23.83	23.86	96.90	94.95	6.70	6.58	2.14	2.60	12.9	12.5	
			12:48	4.5	3.5	27.20		8.61		23.89		93.00		6.46		3.06		12.0		

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

**Baseline Water Quality Monitoring at Station SR5 (Bottom) - Flood Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR5	3/5/2022	Sunny	9:35	4.7	3.7	22.70	22.70	8.31	8.32	32.77	32.76	71.90	77.55	5.13	5.53	5.31	3.97	6.6	6.8
			9:37	4.7	3.7	22.70		8.32		32.75		83.20		5.93		2.63		7.0	
	5/5/2022	Sunny	9:43	4.4	3.4	23.70	23.70	8.36	8.36	32.58	32.59	96.80	101.65	6.79	7.13	3.54	4.00	4.5	4.3
			9:45	4.4	3.4	23.70		8.35		32.60		106.50		7.47		4.46		4.1	
	7/5/2022	cloudy	9:32	4.3	3.3	24.80	24.80	8.49	8.49	32.44	32.46	91.30	94.15	6.29	6.49	3.11	3.15	4.8	4.6
			9:34	4.3	3.3	24.80		8.49		32.47		97.00		6.68		3.16		4.4	
	10/5/2022	Rain	11:07	4.1	3.1	26.27	26.27	8.33	8.34	29.00	29.00	79.30	79.25	5.44	5.76	0.01	0.01	2.3	2.2
			11:09	4.1	3.1	26.27		8.35		29.00		79.20		6.07		0.01		2.1	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	12:53	3.5	2.5	24.80	24.80	8.39	8.40	25.64	25.45	83.60	83.95	6.00	6.03	1.80	1.65	1.8	1.9
			12:55	3.5	2.5	24.80		8.40		25.25		84.30		6.06		1.50		1.9	
	16/5/2022	Rain	12:45	4.2	3.2	23.10	23.10	8.34	8.34	31.03	31.07	74.70	74.10	5.35	5.31	4.03	4.57	4.4	4.4
			12:47	4.2	3.2	23.10		8.34		31.10		73.50		5.26		5.10		4.4	
	18/5/2022	Cloudy	9:40	5.0	4.0	23.40	23.35	8.31	8.31	31.61	31.62	73.20	71.35	5.20	5.07	2.16	2.28	2.6	2.7
			9:42	5.0	4.0	23.30		8.31		31.63		69.50		4.94		2.39		2.8	
	20/5/2022	Fine	9:25	3.6	2.6	24.60	24.60	8.28	8.29	30.84	30.84	87.70	82.75	6.13	5.78	1.81	1.72	4.4	4.6
			9:27	3.6	2.6	24.60		8.29		30.84		77.80		5.43		1.63		4.8	
	23/5/2022	Cloudy	9:24	2.9	1.9	24.80	24.80	8.40	8.42	29.28	29.28	82.20	82.30	5.77	5.78	1.29	1.25	4.1	4.3
			9:26	2.9	1.9	24.80		8.43		29.28		82.40		5.78		1.20		4.4	
	25/5/2022	Rain	12:50	3.9	2.9	24.90	24.90	8.35	8.36	30.63	30.63	74.60	74.45	5.18	5.17	3.26	2.91	4.4	4.3
			12:52	3.9	2.9	24.90		8.36		30.63		74.30		5.16		2.56		4.1	
	27/5/2022	Rain	12:45	3.8	2.8	26.10	26.10	8.43	8.43	30.30	30.30	80.80	80.10	5.52	5.47	3.06	2.99	3.0	2.8
12:47			3.8	2.8	26.10	8.42		30.29		79.40		5.42		2.92		2.8			
31/5/2022	Rain	12:46	4.5	3.5	27.20	27.20	8.61	8.61	23.77	23.83	90.70	91.85	6.31	6.39	2.34	2.70	12.3	12.0	
		12:48	4.5	3.5	27.20		8.61		23.89		93.00		6.46		3.06		12.0		

**Baseline Water Quality Monitoring at Station SR6 (Middle) - Ebb Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L			
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR6	3/5/2022	Sunny	12:34	2.9	1.5	23.30	23.10	8.42	8.42	32.79	32.65	88.40	92.05	6.24	6.53	2.56	3.22	2.4	2.5		
			12:36	2.9	1.5	22.90		8.42		32.51		95.70		6.82		3.88		2.5			
	5/5/2022	Sunny	12:32	2.6	1.3	24.10	23.95	8.49	8.49	32.49	32.53	96.20	101.80	6.71	7.12	0.01	0.01	3.2	3.1		
			12:34	2.6	1.3	23.80		8.49		32.57		107.40		7.53		0.01		2.9			
	7/5/2022	Cloudy	12:33	2.9	1.5	25.30	25.35	8.59	8.59	32.33	32.36	109.60	111.00	7.49	7.59	2.39	2.33	2.6	2.8		
			12:35	2.9	1.5	25.40		8.58		32.39		112.40		7.68		2.31		2.9			
	10/5/2022	Rain	13:22	2.8	1.4	25.95	25.95	8.31	8.32	27.99	28.31	84.70	84.90	5.87	5.88	0.67	0.60	2.9	2.8		
			13:24	2.8	1.4	25.95		8.32		28.63		85.10		5.88		0.53		2.6			
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																		
	14/5/2022	Rain	9:48	2.8	1.4	24.50	24.50	8.24	8.25	25.53	25.50	87.30	85.80	6.29	6.19	0.98	1.11	1.6	1.6		
			9:50	2.8	1.4	24.50		8.25		25.47		84.30		6.08		1.24		1.5			
	16/5/2022	Rain	9:42	3.3	1.4	23.00	22.55	8.24	8.25	30.43	30.48	75.60	75.85	5.44	5.50	4.46	4.38	4.0	3.9		
			9:44	2.8	1.4	22.10		8.26		30.53		76.10		5.56		4.29		3.7			
	18/5/2022	Cloudy	12:35	3.3	1.7	23.80	23.60	8.42	8.43	31.09	31.12	78.30	79.20	5.54	5.62	1.31	1.27	3.5	3.4		
			12:37	3.3	1.7	23.40		8.43		31.14		80.10		5.70		1.23		3.2			
	20/5/2022	Fine	12:30	3.1	1.6	25.70	25.90	8.40	8.40	29.97	29.94	76.10	73.70	5.24	5.06	1.51	1.57	2.7	2.9		
			12:32	3.1	1.6	26.10		8.39		29.91		71.30		4.87		1.62		3.0			
	23/5/2022	Cloudy	12:34	3.3	1.7	24.90	24.90	8.52	8.52	29.50	29.50	76.90	74.10	5.38	5.19	2.07	2.23	4.6	4.4		
			12:36	3.3	1.7	24.90		8.52		29.50		71.30		4.99		2.38		4.2			
	25/5/2022	Rain	9:23	2.8	1.4	24.70	24.80	8.30	8.30	30.35	30.40	76.60	76.10	5.33	5.30	2.48	3.24	3.6	3.7		
			9:25	2.8	1.4	24.90		8.30		30.44		75.60		5.26		3.99		3.8			
	27/5/2022	Rain	9:37	2.9	1.5	26.10	26.10	8.30	8.30	29.85	29.93	77.10	78.75	5.28	5.39	1.81	2.35	2.4	2.3		
			9:39	2.9	1.5	26.10		8.30		30.00		80.40		5.50		2.88		2.1			
	31/5/2022	Rain	9:35	2.9	1.5	27.80	27.65	8.46	8.48	23.30	23.63	83.80	86.80	5.78	5.99	6.20	4.63	3.6	3.5		
			9:37	2.9	1.5	27.50		8.50		23.95		89.80		6.20		3.06		3.3			

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

**Baseline Water Quality Monitoring at Station SR6 (Middle) - Flood Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L			
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR6	3/5/2022	Sunny	9:41	2.9	1.5	22.20	22.25	8.32	8.33	32.27	32.41	94.60	90.80	6.88	6.57	3.22	3.93	4.8	4.5		
			9:43	2.9	1.5	22.30		8.33		32.54		87.00		6.26		4.63		4.2			
	5/5/2022	Sunny	9:48	2.9	1.5	23.50	23.60	8.36	8.36	32.59	32.58	83.10	85.85	5.86	6.04	3.69	4.31	3.8	4.0		
			9:50	2.9	1.5	23.70		8.36		32.56		88.60		6.22		4.93		4.1			
	7/5/2022	cloudy	9:37	3.0	1.5	25.50	25.10	8.50	8.51	32.25	32.24	111.70	109.70	7.62	7.53	2.48	2.43	2.1	2.2		
			9:39	3.0	1.5	24.70		8.51		32.23		107.70		7.44		2.39		2.2			
	10/5/2022	Rain	11:13	2.7	1.4	26.15	26.15	8.37	8.35	28.50	28.51	82.90	82.30	5.71	7.02	0.01	0.01	2.6	2.5		
			11:15	2.7	1.4	26.14		8.33		28.51		81.70		8.33		0.01		2.4			
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																		
	14/5/2022	Rain	12:38	2.9	1.5	24.70	24.75	8.38	8.38	25.81	25.83	78.70	80.60	5.64	5.78	1.40	1.44	2.3	2.2		
			12:40	2.9	1.5	24.80		8.38		25.84		82.50		5.91		1.47		2.1			
	16/5/2022	Rain	12:32	2.9	1.5	23.10	22.60	8.35	8.36	30.87	30.93	78.10	78.05	5.60	5.65	4.97	5.02	4.8	5.0		
			12:34	2.9	1.5	22.10		8.36		30.99		78.00		5.69		5.06		5.2			
	18/5/2022	Cloudy	9:44	3.2	1.6	23.20	23.35	8.33	8.33	31.07	31.04	77.00	75.95	5.50	5.42	1.55	1.60	1.9	1.8		
			9:46	3.2	1.6	23.50		8.33		31.01		74.90		5.33		1.64		1.7			
	20/5/2022	Fine	9:30	2.5	1.3	24.50	24.65	8.29	8.30	30.22	29.89	72.10	75.00	5.06	5.26	1.52	1.56	3.3	3.5		
			9:32	2.5	1.3	24.80		8.30		29.55		77.90		5.46		1.60		3.7			
	23/5/2022	Cloudy	9:29	3.2	1.6	24.80	24.80	8.46	8.46	29.23	29.22	87.20	88.00	6.12	6.18	2.39	2.42	4.0	4.2		
			9:31	3.2	1.6	24.80		8.45		29.20		88.80		6.23		2.44		4.3			
	25/5/2022	Rain	12:37	2.9	1.5	25.00	24.95	8.40	8.40	30.47	30.46	77.00	76.20	5.35	5.30	2.09	1.94	1.4	1.4		
			12:39	2.9	1.5	24.90		8.39		30.44		75.40		5.25		1.79		1.3			
	27/5/2022	Rain	12:32	2.9	1.5	26.10	26.15	8.40	8.40	30.24	30.31	79.40	78.85	5.43	5.39	2.69	2.54	4.0	4.2		
12:34			2.9	1.5	26.20	8.40		30.38		78.30		5.34		2.39		4.4					
31/5/2022	Rain	12:33	2.9	1.5	27.50	27.20	8.63	8.61	22.07	22.78	90.70	91.15	6.33	6.37	0.90	1.71	3.0	2.9			
		12:35	2.9	1.5	26.90		8.59		23.48		91.60		6.41		2.51		2.8				

### Baseline Water Quality Monitoring at Station SR9 (surface) - Ebb Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR9	3/5/2022	Sunny	12:21	4.5	1.0	22.70	23.60	8.43	8.43	32.82	32.78	87.10	89.25	6.21	6.27	2.20	2.79	2.4	2.3
			12:23	4.5	1.0	24.50		8.42		32.74		91.40		6.32		3.37		2.1	
	5/5/2022	Sunny	12:19	4.3	1.0	23.70	23.90	8.50	8.50	32.48	32.53	111.30	110.70	7.82		0.01	0.01	2.9	2.9
			12:21	4.3	1.0	24.10		8.50		32.58		110.10		7.69		0.01		2.8	
	7/5/2022	Cloudy	12:21	3.2	1.0	25.60	25.60	8.59	8.59	31.99	31.99	121.80	121.80	8.30	8.30	1.06	1.04	1.8	1.8
			12:23	3.2	1.0	25.60		8.59		31.99		121.80		8.30		1.04		1.8	
	10/5/2022	Rain	13:09	4.3	1.0	25.87	25.84	8.36	8.34	27.90	28.13	85.00	85.60	5.90	5.94	0.42	0.31	2.4	2.3
			13:11	4.3	1.0	25.80		8.31		28.35		86.20		5.97		0.19		2.2	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	10:02	3.8	1.0	24.70	24.70	8.27	8.28	25.64	25.65	84.70	85.45	6.08	6.14	1.23	1.31	3.0	2.8
			10:04	3.8	1.0	24.70		8.28		25.66		86.20		6.19		1.38		2.6	
	16/5/2022	Rain	9:55	3.5	1.0	22.60	21.70	8.29	8.30	30.73	30.73	78.10	77.60	5.65	5.71	3.99	3.91	5.0	4.9
			9:57	4.0	1.0	20.80		8.31		30.72		77.10		5.76		3.82		4.8	
	18/5/2022	Cloudy	12:23	3.5	1.0	23.70	23.70	8.46	8.45	31.34	30.97	74.20	75.20	5.25	5.34	2.39	2.13	2.5	2.6
			12:25	3.5	1.0	23.70		8.44		30.60		76.20		5.42		1.87		2.7	
	20/5/2022	Fine	12:18	4.0	1.0	26.80	27.50	8.36	8.37	30.63	30.53	74.30	82.50	4.84	5.51	2.63	2.30	2.4	2.3
			12:20	4.0	1.0	26.20		8.38		30.43		90.70		6.18		1.97		2.1	
	23/5/2022	Cloudy	12:20	5.1	1.0	24.60	24.60	8.56	8.56	29.36	29.43	91.00	91.90	6.41	6.47	1.03	1.32	3.3	3.2
			12:22	5.1	1.0	24.60		8.55		29.49		92.80		6.53		1.60		3.0	
	25/5/2022	Rain	9:37	4.4	1.0	25.10	25.20	8.31	8.31	30.32	30.32	77.90	74.15	5.41	5.14	3.70	3.83	5.2	5.1
			9:39	4.4	1.0	25.30		8.31		30.32		70.40		4.87		3.95		4.9	
	27/5/2022	Rain	9:49	4.4	1.0	26.10	26.15	8.23	8.25	30.23	30.04	70.40	72.00	4.81	4.93	2.50	2.30	3.4	3.3
			9:51	4.4	1.0	26.20		8.26		29.85		73.60		5.04		2.09		3.1	
	31/5/2022	Rain	9:50	4.6	1.0	26.90	27.35	8.39	8.42	26.75	25.63	74.00	77.60	5.08	5.32	1.93	2.03	3.9	3.7
			9:52	4.6	1.0	27.80		8.45		24.50		81.20		5.56		2.13		3.4	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station SR9 (surface) - Flood Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR9	3/5/2022	Sunny	9:50	4.3	1.0	21.80	22.00	8.32	8.33	32.75	32.70	109.90	103.60	7.46	7.23	2.34	3.25	3.6	3.4
			9:52	4.3	1.0	22.20		8.34		32.65		97.30		7.00		4.16		3.1	
	5/5/2022	Sunny	9:58	4.5	1.0	23.70	23.80	8.38	8.39	32.61	32.61	106.00	103.65	7.44	7.27	4.21	4.87	3.5	3.5
			10:00	4.5	1.0	23.90		8.39		32.60		101.30		7.09		5.53		3.4	
	7/5/2022	cloudy	9:49	3.7	1.0	24.50	24.75	8.49	8.50	32.25	32.19	99.70	106.00	6.92	7.33	1.44	1.42	1.5	1.7
			9:51	3.7	1.0	25.00		8.50		32.13		112.30		7.73		1.40		1.8	
	10/5/2022	Rain	11:28	4.6	1.0	25.96	25.96	8.29	8.36	28.37	28.53	116.20	110.15	8.04	7.62	1.16	0.61	2.7	2.6
			11:30	4.6	1.0	25.95		8.43		28.68		104.10		7.19		0.06		2.4	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	12:22	4.3	1.0	24.90	24.95	8.36	8.37	25.59	25.54	77.50	80.10	5.55	5.74	1.60	1.63	<1.0	1.0
			12:24	4.3	1.0	25.00		8.37		25.49		82.70		5.93		1.65		<1.0	
	16/5/2022	Rain	12:20	3.7	1.0	21.60	22.35	8.38	8.38	29.85	30.02	82.20	81.90	6.08	5.98	2.78	3.29	4.1	3.9
			12:22	3.7	1.0	23.10		8.37		30.18		81.60		5.88		3.80		3.7	
	18/5/2022	Cloudy	9:58	4.0	1.0	23.30	23.50	8.32	8.33	31.05	31.04	79.90	78.85	5.70	5.61	1.60	1.65	1.6	1.7
			10:00	4.0	1.0	23.70		8.33		31.02		77.80		5.52		1.69		1.8	
	20/5/2022	Fine	9:43	3.5	1.0	24.40	24.55	8.29	8.30	30.48	30.38	75.30	76.80	5.03	5.25	1.45	1.55	2.8	3.0
			9:45	3.5	1.0	24.70		8.30		30.27		78.30		5.48		1.64		3.1	
	23/5/2022	Cloudy	9:42	4.6	1.0	24.80	24.80	8.42	8.43	29.21	29.25	86.60	86.75	6.08	6.09	2.89	2.69	6.6	6.4
			9:44	4.6	1.0	24.80		8.44		29.28		86.90		6.10		2.49		6.1	
	25/5/2022	Rain	12:23	4.3	1.0	24.80	24.85	8.38	8.38	30.38	30.41	77.00	76.25	5.44	5.35	2.35	2.33	3.0	2.9
			12:25	4.3	1.0	24.90		8.38		30.44		75.50		5.26		2.30		2.7	
	27/5/2022	Rain	20:20	4.0	1.0	26.00	26.15	8.39	8.38	30.48	30.55	77.00	76.45	5.26	5.21	4.25	3.52	2.8	2.7
			20:22	4.0	1.0	26.30		8.37		30.61		75.90		5.16		2.78		2.5	
	31/5/2022	Rain	12:20	4.4	1.0	23.80	25.40	8.59	8.61	23.13	22.65	92.10	93.40	6.47	6.57	1.39	2.23	3.0	3.0
			12:22	4.4	1.0	27.00		8.62		22.16		94.70		6.67		3.07		2.9	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

**Baseline Water Quality Monitoring at Station SR9 (Bottom) - Ebb Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH		Salinity		DO Saturation		DO		Turbidity		SS		
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	mg/L
SR9	3/5/2022	Sunny	12:25	4.5	3.5	22.90	22.85	8.42	8.42	32.94	32.88	89.80	91.75	6.39	6.35	3.21	2.69	2.6	2.7	
			12:27	4.5	3.5	22.80		8.42		32.82		93.70		6.30		2.17		2.7		
	5/5/2022	Sunny	12:25	4.3	3.3	23.80	23.80	8.50	8.50	32.63	32.62	104.60	103.70	7.33	7.27	0.01	0.01	4.5	4.9	
			12:27	4.3	3.3	23.80		8.50		32.60		102.80		7.21		0.01		4.9		
	7/5/2022	Cloudy	12:25	3.2	2.2	24.90	24.90	8.61	8.61	32.02	32.02	129.30	129.30	8.92	8.92	1.21	1.19	2.9	3.2	
			12:27	3.2	2.2	24.90		8.61		32.02		129.30		8.92		1.16		3.2		
	10/5/2022	Rain	11:14	4.3	3.3	25.84	25.83	8.32	8.32	28.56	28.38	84.60	84.90	5.86	5.89	0.03	0.02	1.9	1.9	
			11:16	4.3	3.3	25.81		8.32		28.19		85.20		5.91		0.01		1.9		
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																	
	14/5/2022	Rain	10:06	3.8	2.8	24.50	24.55	8.28	8.28	26.34	26.32	84.00	83.50	6.02	5.99	1.29	1.20	1.9	1.7	
			10:08	3.8	3.0	24.60		8.28		26.30		83.00		5.95		1.10		1.7		
	16/5/2022	Rain	9:59	3.5	3.0	22.50	22.45	8.32	8.32	30.77	30.70	78.20	76.60	5.63	5.54	3.85	3.99	5.2	5.4	
			10:01	4.0	3.0	22.40		8.32		30.63		75.00		5.45		4.13		5.6		
	18/5/2022	Cloudy	12:28	3.5	2.5	23.40	23.45	8.42	8.42	31.14	31.14	75.60	75.65	5.37	5.38	2.23	4.36	3.1	3.3	
			12:30	3.5	2.5	23.50		8.41		31.14		75.70		5.39		6.48		3.4		
	20/5/2022	Fine	12:22	4.0	3.0	25.30	25.30	8.40	8.40	30.39	30.41	76.00	75.85	5.26	5.25	1.62	1.70	2.5	2.7	
			12:24	4.0	3.0	25.30		8.39		30.42		75.70		5.24		1.78		2.8		
	23/5/2022	Cloudy	12:24	5.1	4.1	24.70	24.70	8.56	8.57	29.37	29.39	90.20	85.70	6.34	6.03	1.60	1.40	3.6	3.8	
			12:26	5.1	4.1	24.70		8.57		29.40		81.20		5.71		1.20		4.0		
	25/5/2022	Rain	9:42	4.4	3.4	25.10	25.10	8.32	8.32	30.22	30.28	73.60	73.10	5.13	5.09	3.10	3.46	4.1	4.4	
			9:44	4.4	3.4	25.10		8.32		30.34		72.60		5.04		3.82		4.4		
	27/5/2022	Rain	9:53	4.4	3.4	26.10	26.10	8.25	8.32	30.15	29.99	70.20	71.10	4.80	4.87	1.93	1.76	5.4	5.7	
			9:55	4.4	3.4	26.10		8.38		29.82		72.00		4.93		1.58		5.9		
	31/5/2022	Rain	9:56	4.6	3.6	27.20	27.05	8.44	8.43	25.82	26.23	85.90	84.10	5.91	5.91	2.03	2.03	4.8	4.6	
			9:58	4.6	3.6	26.90		8.42		26.63		82.30		-		-		4.4		

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

**Baseline Water Quality Monitoring at Station SR9 (Bottom) - Flood Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH		Salinity		DO Saturation		DO		Turbidity		SS			
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR9	3/5/2022	Sunny	9:55	4.3	3.3	22.30	22.30	8.35	8.36	32.67	58.89	88.90	87.00	6.39	6.26	3.54	2.82	4.1	4.0		
			9:57	4.3	3.3	22.30		8.36		85.10		85.10		6.13		2.09		3.8			
	5/5/2022	Sunny	10:02	4.5	3.5	23.70	23.70	8.41	8.41	32.65	32.71	101.20	92.50	7.10	6.67	3.54	4.32	3.2	3.1		
			10:04	4.5	3.5	23.70		8.40		32.77		83.80		6.23		5.09		3.1			
	7/5/2022	cloudy	9:55	3.7	2.7	24.25	24.38	8.52	8.52	32.17	32.19	117.90	115.90	8.18	8.04	2.01	1.96	2.3	2.1		
			9:57	3.7	2.7	24.50		8.52		32.20		113.90		7.90		1.90		2.1			
	10/5/2022	Rain	11:33	4.6	3.6	25.89	25.90	8.29	8.32	28.45	28.69	94.10	92.95	6.51	6.43	0.82	0.43	1.8	1.6		
			11:35	4.6	3.6	25.91		8.35		28.92		91.80		6.34		0.04		1.6			
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																		
	14/5/2022	Rain	12:26	4.3	3.3	24.90	24.90	8.38	8.38	25.61	25.53	82.60	82.75	5.91	5.93	1.50	1.55	1.4	1.5		
			12:28	4.3	3.3	24.90		8.37		25.44		82.90		5.94		1.60		1.6			
	16/5/2022	Rain	12:24	3.7	2.7	23.30	23.35	8.36	8.36	30.48	30.42	78.60	80.00	5.62	5.72	3.91	3.77	6.6	6.3		
			12:26	3.7	2.7	23.40		8.36		30.36		81.40		5.82		3.62		6.0			
	18/5/2022	Cloudy	10:02	4.0	3.0	23.70	23.70	8.34	8.34	31.04	31.03	78.50	76.90	5.56	5.43	1.81	1.71	3.1	3.3		
			10:04	4.0	3.0	23.70		8.34		31.02		75.30		5.30		1.61		3.4			
	20/5/2022	Fine	9:46	3.5	2.5	24.50	24.50	8.31	8.32	30.45	30.44	76.00	77.50	5.33	5.44	1.70	1.64	3.4	3.4		
			9:48	3.5	2.5	24.50		8.32		30.43		79.00		5.54		1.57		3.3			
	23/5/2022	Cloudy	9:46	4.6	3.6	24.80	24.80	8.46	8.47	29.18	29.23	87.50	85.65	6.14	6.02	2.98	2.89	3.7	3.9		
			9:48	4.6	3.6	24.80		8.47		29.27		83.80		5.89		2.79		4.0			
	25/5/2022	Rain	12:28	4.3	3.3	24.90	24.90	8.40	8.40	30.50	30.48	73.30	73.00	5.11	5.09	2.04	2.60	2.2	2.3		
			12:30	4.3	3.3	24.90		8.39		30.46		72.70		5.06		3.16		2.4			
27/5/2022	Rain	12:25	4.0	3.0	26.00	25.95	8.38	8.38	30.48	30.49	75.10	76.25	5.13	5.21	3.29	3.04	3.2	3.4			
		12:27	4.0	3.0	25.90		8.38		30.49		77.40		5.29		2.79		3.4				
31/5/2022	Rain	12:24	4.4	3.4	27.20	27.20	8.61	8.61	23.16	23.17	88.10	88.10	6.14	6.14	1.73	1.73	5.5	5.4			
		12:26	4.4	3.4	27.20		8.61		23.18		88.10		6.14		1.73		5.4				

**Baseline Water Quality Monitoring at Station SR10 (Middle) - Ebb Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR10	3/5/2022	Sunny	12:13	2.7	1.4	22.70		8.43		32.88		83.30		5.94		2.13		2.8	
			12:15	2.7	1.4	22.80	22.75	8.43	8.43	32.87	32.88	93.20	88.25	6.64	6.29	2.23	2.18	3.1	3.0
	5/5/2022	Sunny	12:14	2.6	1.3	23.80		8.50		31.56		106.20		7.48		0.01		3.4	
			12:16	2.6	1.3	23.90	23.85	8.50	8.50	31.65	31.61	90.90	98.55	6.39	6.94	0.01	0.01	3.2	3.3
	7/5/2022	Cloudy	12:16	2.9	1.5	25.00		8.59		31.99		123.00		8.48		1.39		2.6	
			12:18	2.9	1.5	25.10	25.05	8.59	8.59	31.97	31.98	129.60	126.30	8.92	8.70	1.44	1.41	3.0	2.8
	10/5/2022	Rain	0:00	0.0	0.0	25.83		8.32		28.20		112.60		7.81		0.01		1.7	
			12:58	2.7	1.4	25.81	25.82	8.45	8.39	25.93	27.07	112.40	112.50	7.90	7.86	0.01	0.01	1.5	1.6
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	10:10	2.7	1.4	24.60		8.30		25.61		77.20		5.55		1.20		1.9	
			10:12	2.7	1.5	24.60	24.60	8.30	8.30	25.60	25.61	85.60	81.40	6.15	5.85	1.53	1.37	1.7	1.8
	16/5/2022	Rain	10:04	2.7	1.5	22.40		8.34		29.93		78.00		5.69		2.44		3.3	
			10:06	2.9	1.5	22.80	22.60	8.33	8.34	29.76	29.85	79.40	78.70	5.76	5.73	2.19	2.32	3.7	3.5
	18/5/2022	Cloudy	12:16	2.7	1.4	24.80		8.37		31.06		76.70		5.32		1.84		2.9	
			12:18	2.7	1.4	24.80	24.80	8.38	8.38	31.09	31.08	78.30	77.50	5.44	5.38	2.39	2.12	3.2	3.1
	20/5/2022	Fine	12:13	2.8	1.4	26.20		8.37		30.52		86.60		5.89		1.98		4.2	
			12:15	2.8	1.4	26.10	26.15	8.37	8.37	30.48	30.50	78.70	82.65	5.36	5.63	1.50	1.74	4.0	4.1
	23/5/2022	Cloudy	12:16	2.6	1.3	24.60		8.61		28.31		85.50		6.08		1.79		4.4	
			12:18	2.6	1.3	24.30	24.45	8.60	8.61	28.30	28.31	79.40	82.45	5.65	5.87	1.99	1.89	4.9	4.7
	25/5/2022	Rain	9:48	2.8	1.4	25.40		8.34		29.13		75.00		5.21		4.96		4.4	
			9:50	2.8	1.4	25.40	25.40	8.33	8.34	29.15	29.14	74.70	74.85	5.20	5.21	5.22	5.09	4.7	4.6
	27/5/2022	Rain	9:58	2.9	1.5	26.10		8.33		30.18		82.40		5.62		3.11		2.7	
			10:00	2.9	1.5	26.10	26.10	8.33	8.32	29.99	30.09	80.30	81.35	5.49	5.56	1.94	2.53	3.1	2.9
	31/5/2022	Rain	10:02	2.9	1.5	27.30		8.50		24.92		80.40		5.54		1.54		3.4	
			10:04	2.9	1.5	28.00	27.65	8.48	8.49	24.80	24.86	80.50	80.45	5.49	5.52	2.03	1.79	3.6	3.5

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

**Baseline Water Quality Monitoring at Station SR10 (Middle) - Flood Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR10	3/5/2022	Sunny	10:02	2.6	1.3	21.70		8.34		32.67		82.80		6.01		4.13		2.3	
			10:04	2.6	1.3	22.10	21.90	8.34	8.34	32.57	32.62	80.80	81.80	5.84	5.93	3.44	3.79	2.5	2.4
	5/5/2022	Sunny	10:06	2.7	1.4	23.90		8.42		32.60		100.40		7.03		4.59		5.9	
			10:08	2.7	1.4	23.80	23.85	8.41	8.42	23.56	28.08	110.40	105.40	7.74	7.39	3.79	4.19	6.2	6.1
	7/5/2022	cloudy	10:00	2.7	1.4	24.90		8.50		32.16		92.20		6.35		1.20		2.8	
			10:02	2.7	1.4	24.90	24.90	8.50	8.50	32.15	32.16	83.10	87.65	5.73	6.04	1.17	1.19	3.0	2.9
	10/5/2022	Rain	11:37	2.7	1.4	26.02		8.27		28.32		104.40		7.22		0.10		2.6	
			11:39	2.7	1.4	26.00	26.01	8.28	8.28	28.67	28.50	101.70	103.05	7.02	7.12	0.26	0.18	2.4	2.5
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	12:17	2.7	1.4	24.60		8.29		29.65		77.80		5.47		3.70		1.2	
			12:19	2.7	1.4	24.60	24.60	8.28	8.29	29.78	29.72	72.20	75.00	5.07	5.27	3.24	3.47	1.5	1.4
	16/5/2022	Rain	12:16	2.6	1.3	23.00		8.39		29.43		80.30		5.85		2.11		3.6	
			12:18	2.6	1.3	22.90	22.95	8.39	8.39	29.51	29.47	80.00	80.15	5.80	5.83	2.19	2.15	3.0	3.3
	18/5/2022	Cloudy	10:06	2.8	1.4	23.30		8.34		31.14		73.90		5.27		2.17		2.8	
			10:08	2.8	1.4	22.90	23.10	8.34	8.34	31.08	31.11	79.00	76.45	5.67	5.47	2.05	2.11	3.1	3.0
	20/5/2022	Fine	9:51	2.3	1.2	24.70		8.31		30.40		81.60		5.70		1.61		4.2	
			9:53	2.3	1.2	24.60	24.65	8.32	8.32	30.48	30.44	84.90	83.25	5.94	5.82	1.59	1.60	3.8	4.0
	23/5/2022	Cloudy	9:50	2.3	1.2	25.00		8.51		28.26		81.70		5.74		1.96		2.8	
			9:52	2.3	1.2	25.10	25.05	8.53	8.52	28.27	28.27	81.20	81.45	5.70	5.72	1.95	1.96	3.2	3.0
	25/5/2022	Rain	12:16	2.5	1.3	25.00		8.42		28.40		72.90		5.13		2.99		3.6	
			12:18	2.5	1.3	25.00	25.00	8.42	8.42	28.44	28.42	70.70	71.80	4.97	5.05	3.79	3.39	3.3	3.5
	27/5/2022	Rain	12:16	2.5	1.3	26.10		8.42		30.34		76.30		5.21		1.95		1.9	
			12:18	2.5	1.3	26.10	26.10	8.42	8.42	30.35	30.35	77.20	76.75	5.27	5.24	1.99	1.97	1.6	1.8
	31/5/2022	Rain	12:16	2.7	1.4	25.80		8.58		25.00		75.90		5.36		6.33		3.9	
			12:18	2.7	1.4	25.90	25.85	8.59	8.59	24.99	25.00	84.20	80.05	5.95	5.66	6.33	6.33	3.6	3.8

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station SR12 (Middle) - Ebb Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature		pH		Salinity		DO Saturation		DO		Turbidity		SS	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR12	3/5/2022	Sunny	12:10	2.7	1.4	23.50	23.30	8.46	8.45	32.76	32.80	89.40	90.40	6.29	6.39	2.18	2.26	2.6	2.5
			12:12	2.7	1.4	23.10		8.44		32.84		91.40		6.48		2.33		2.4	
	5/5/2022	Sunny	12:12	2.7	1.4	23.70	24.00	8.35	8.30	32.44	32.46	104.30	102.95	7.33	7.20	0.01	0.01	3.0	3.3
			12:14	2.7	1.4	24.30		8.25		32.48		101.60		7.07		0.01		3.5	
	7/5/2022	Cloudy	12:12	2.6	1.3	25.00	25.40	8.57	8.57	31.88	31.89	108.10	110.80	7.46	7.59	1.66	1.71	3.2	3.3
			12:14	2.6	1.3	25.80		8.57		31.89		113.50		7.71		1.71		3.1	
	10/5/2022	Rain	0:00	0.0	0.0	25.91	25.91	8.36	8.35	28.19	28.41	89.60	87.00	6.21	6.02	0.01	0.01	2.2	2.3
			12:41	2.9	1.5	25.91		8.33		28.63		84.40		5.83		0.01		2.4	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	10:15	2.7	1.4	24.80	24.80	8.30	8.30	26.34	26.36	80.70	81.85	5.77	5.85	1.23	1.36	1.4	1.5
			10:17	2.7	1.4	24.80		8.30		26.38		83.00		5.93		1.49		1.5	
	16/5/2022	Rain	10:09	2.8	1.4	22.30	22.70	8.34	8.34	29.74	29.69	81.00	80.75	5.92	5.87	1.99	1.85	2.8	3.1
			10:11	2.7	1.4	23.10		8.33		29.63		80.50		5.81		1.71		3.3	
	18/5/2022	Cloudy	12:12	2.8	1.4	24.10	24.20	8.38	8.38	31.16	31.11	72.60	76.90	5.11	5.40	1.93	2.16	3.5	3.7
			12:14	2.8	1.4	24.30		8.38		31.05		81.20		5.68		2.39		3.9	
	20/5/2022	Fine	12:12	2.7	1.4	24.60	24.70	8.33	8.33	30.40	30.40	80.50	81.45	5.63	5.69	1.60	1.55	3.5	3.7
			12:14	2.7	1.4	24.80		8.33		30.39		82.40		5.74		1.50		3.8	
	23/5/2022	Cloudy	12:12	2.7	1.4	24.40	24.40	8.60	8.61	28.50	28.48	84.80	81.65	6.03	5.81	1.29	1.60	3.6	3.8
			12:14	2.7	1.4	24.40		8.61		28.46		78.50		5.58		1.90		4.0	
	25/5/2022	Rain	9:55	2.8	1.4	25.00	25.00	8.36	8.37	29.64	29.62	74.80	74.15	5.22	5.18	2.02	2.52	4.3	4.0
			9:57	2.8	1.4	25.00		8.37		29.60		73.50		5.13		3.01		4.0	
	27/5/2022	Rain	10:02	2.7	1.4	26.20	26.20	8.36	8.36	29.90	29.96	75.00	74.40	5.12	5.08	2.08	2.04	2.4	2.2
			10:04	2.7	1.4	26.20		8.35		30.02		73.80		5.04		1.99		2.2	
	31/5/2022	Rain	10:13	2.7	1.4	27.60	27.55	8.53	8.53	24.90	24.98	88.00	85.60	6.03	5.87	1.44	1.43	3.5	3.3
			10:15	2.7	1.4	27.50		8.52		25.06		83.20		5.71		1.41		3.1	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station SR12 (Middle) - Flood Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH		Salinity		DO Saturation %		DO		Turbidity NTU		SS mg/L			
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR12	3/5/2022	Sunny	10:07	2.6	1.3	22.30	22.40	8.35	8.35	32.99	32.89	76.60	86.90	5.50	6.23	3.64	3.67	3.4	3.6		
			10:09	2.6	1.3	22.50		8.34		32.79		97.20		6.96		3.70		3.8			
	5/5/2022	Sunny	10:10	2.4	1.2	23.60	23.70	8.43	8.43	32.61	32.56	80.30	84.25	5.64	5.89	4.22	3.95	2.6	2.8		
			10:12	2.4	1.2	23.80		8.43		32.50		88.20		6.13		3.68		2.8			
	7/5/2022	cloudy	10:05	2.4	1.2	24.50	24.50	8.56	8.55	31.81	31.80	108.10	110.10	7.51	7.66	2.26	2.30	2.4	2.1		
			10:07	2.4	1.2	24.50		8.54		31.79		112.10		7.80		2.33		2.1			
	10/5/2022	Rain	11:42	2.7	1.4	25.93	25.95	8.28	8.32	28.48	28.36	83.30	86.90	5.76	6.01	0.01	0.47	2.4	2.2		
			11:44	2.7	1.4	25.96		8.35		28.24		90.50		6.26		0.93		2.2			
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																		
	14/5/2022	Rain	12:12	2.6	1.3	24.70	24.65	8.38	8.38	24.30	24.30	79.50	78.25	5.76	5.67	1.23	1.23	1.2	1.3		
			12:14	2.6	1.3	24.60		8.37		24.30		77.00		5.57		1.23		1.4			
	16/5/2022	Rain	12:12	2.4	1.2	22.50	21.80	8.40	8.40	29.25	29.64	85.50	84.30	6.24	6.23	2.18	2.19	2.8	2.9		
			12:14	2.4	1.2	21.10		8.40		30.03		83.10		6.21		2.19		3.0			
	18/5/2022	Cloudy	10:11	2.6	1.3	22.70	24.10	8.34	8.34	31.21	30.90	65.20	68.30	4.70	4.81	1.91	2.31	3.2	3.4		
			10:13	2.6	1.3	25.50		8.34		30.59		71.40		4.92		2.71		3.6			
	20/5/2022	Fine	9:56	2.3	1.2	24.60	24.70	8.33	8.33	30.40	30.40	80.50	81.45	5.63	5.69	1.60	1.55	4.4	4.2		
			9:58	2.3	1.2	24.80		8.33		30.39		82.40		5.74		1.50		3.9			
	23/5/2022	Cloudy	9:56	2.5	1.3	24.90	24.95	8.55	8.55	28.41	28.41	82.40	82.90	5.80	5.84	2.15	2.25	4.5	4.3		
			9:58	2.5	1.3	25.00		8.54		28.41		83.40		5.87		2.35		4.0			
	25/5/2022	Rain	12:12	2.5	1.3	24.90	24.90	8.38	8.39	30.19	30.19	76.00	76.30	5.30	5.32	2.39	2.51	4.5	4.7		
			12:14	2.5	1.3	24.90		8.39		30.19		76.60		5.34		2.62		4.8			
	27/5/2022	Rain	12:12	2.5	1.3	26.10	26.10	8.42	8.42	29.83	29.84	79.10	78.85	5.42	5.40	3.00	2.32	1.5	1.2		
12:14	2.5	1.3	26.10	8.42	29.85	78.60		5.38		1.64		1.2									
31/5/2022	Rain	12:12	2.4	1.2	25.90	25.90	8.58	8.56	24.80	24.57	87.60	87.95	6.19	6.22	1.68	1.84	2.7	3.1			
		12:14	2.4	1.2	25.90		8.54		24.34		88.30		6.24		1.99		2.7				



### Baseline Water Quality Monitoring at Station SR15 (Middle) - Ebb Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR15	3/5/2022	Sunny	12:59	2.8	1.4	22.90	23.10	8.40	8.40	32.77	28.30	84.30	85.10	6.00	6.03	5.49	5.08	#N/A	1.0
			13:01	2.8	1.4	23.30		8.40		32.83		85.90		6.06		4.66		#N/A	
	5/5/2022	Sunny	12:58	2.5	1.3	24.50	24.20	8.52	8.52	32.55	32.57	109.60	108.05	7.60	7.53	0.01	0.01	7.6	7.7
			13:00	2.5	1.3	23.90		8.52		32.58		106.50		7.45		0.01		7.8	
	7/5/2022	Cloudy	13:00	2.6	1.3	24.90	24.90	8.61	8.62	32.36	32.28	112.70	108.95	7.76	7.51	1.69	1.69	3.1	2.9
			13:02	2.6	1.3	24.90		8.62		32.19		105.20		7.25		1.68		2.7	
	10/5/2022	Rain	13:49	2.8	1.4	26.44	26.48	8.36	8.36	29.00	29.01	87.60	87.00	5.99	5.95	0.27	0.57	2.3	2.2
			13:51	2.8	1.4	26.51		8.36		29.01		86.40		5.90		0.87		2.1	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	9:25	2.8	1.4	24.30	24.35	8.07	8.05	26.37	26.39	75.50	78.00	5.43	5.58	1.63	1.37	<1.0	1.0
			9:27	2.8	1.4	24.40		8.03		26.40		80.50		5.73		1.10		<1.0	
	16/5/2022	Rain	9:19	2.6	1.3	23.30	23.15	8.07	8.06	30.88	30.82	65.80	67.30	4.69	4.82	6.66	6.04	5.4	5.2
			9:21	2.6	1.3	23.00		8.05		30.76		68.80		4.94		5.42		5.0	
	18/5/2022	Cloudy	13:00	2.7	1.4	23.70	23.90	8.41	8.41	31.54	31.50	75.80	73.65	5.35	5.19	3.69	3.60	3.6	3.8
			13:02	2.7	1.4	24.10		8.41		31.45		71.50		5.02		3.51		4.0	
	20/5/2022	Fine	12:55	2.5	1.3	25.90	25.65	8.45	8.45	30.24	30.28	83.10	83.05	5.69	5.71	1.50	1.56	3.0	3.3
			12:57	2.5	1.3	25.40		8.44		30.31		83.00		5.73		1.61		3.5	
	23/5/2022	Cloudy	13:02	2.6	1.3	24.70	24.75	8.52	8.52	29.44	29.44	84.70	84.55	5.94	5.93	1.14	1.26	2.6	2.8
			13:04	2.6	1.3	24.80		8.52		29.43		84.40		5.92		1.38		3.0	
	25/5/2022	Rain	8:47	2.8	1.4	24.70	24.65	8.12	8.09	30.51	30.49	78.70	76.75	5.50	5.37	0.40	0.59	1.2	1.3
			8:49	2.8	1.4	24.60		8.06		30.47		74.80		5.24		0.78		1.3	
	27/5/2022	Rain	9:14	2.8	1.4	26.10	26.10	7.97	8.01	29.71	29.69	77.10	75.45	5.28	5.17	1.99	2.00	7.2	7.0
			9:16	2.8	1.4	26.10		8.05		29.66		73.80		5.05		2.00		6.8	
	31/5/2022	Rain	9:12	2.8	1.4	27.20	27.30	8.13	8.14	22.76	23.95	93.40	94.30	6.53	6.54	1.36	2.38	3.8	4.0
			9:14	2.8	1.4	27.40		8.14		25.13		95.20		6.55		3.39		4.1	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station SR15 (Middle) - Flood Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
SR15	3/5/2022	Sunny	9:18	2.6	1.3	22.30	22.45	8.16	8.17	32.85	32.82	77.60	80.35	5.57	5.76	5.62	5.07	3.9	4.2
			9:20	2.6	1.3	22.60		8.18		32.79		83.10		5.94		4.52		4.2	
	5/5/2022	Sunny	9:25	2.6	1.3	23.60	23.60	8.27	8.24	32.65	32.65	100.10	95.70	7.04	6.73	2.59	2.39	3.5	3.9
			9:27	2.6	1.3	23.60		8.21		32.64		91.30		6.42		2.18		3.9	
	7/5/2022	cloudy	9:14	2.6	1.3	24.60	24.65	8.42	8.43	32.45	32.44	95.40	103.25	6.60	7.14	1.99	2.03	3.3	3.7
			9:16	2.6	1.3	24.70		8.44		32.42		111.10		7.67		2.01		3.7	
	10/5/2022	Rain	10:42	2.6	1.3	26.22	26.25	8.72	8.77	29.29	29.11	81.50	82.30	8.72	7.21	0.30	0.16	2.2	2.6
			10:44	2.6	1.3	26.28		8.81		28.92		83.10		5.70		0.01		2.6	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	13:08	2.8	1.4	24.70	24.70	8.39	8.39	25.94	25.91	83.60	84.40	5.99	6.05	0.79	1.15	<1.0	1.0
			13:10	2.8	1.4	24.70		8.39		25.88		85.20		6.11		1.50		<1.0	
	16/5/2022	Rain	13:00	2.7	1.4	23.30	23.25	8.29	8.29	31.05	31.10	73.00	71.35	5.21	5.09	6.06	6.06	6.2	6.5
			13:02	2.7	1.4	23.20		8.28		31.14		69.70		4.97		6.05		6.8	
	18/5/2022	Cloudy	9:20	2.8	1.4	23.20	23.35	8.12	8.15	31.60	31.68	76.90	76.40	5.48	5.43	4.85	4.83	2.6	2.7
			9:22	2.8	1.4	23.50		8.17		31.76		75.90		5.37		4.81		2.8	
	20/5/2022	Fine	9:07	2.4	1.2	24.80	24.95	8.05	8.08	30.71	30.64	76.20	75.40	5.31	5.25	1.99	1.88	2.7	2.9
			9:09	2.4	1.2	25.10		8.11		30.56		74.60		5.18		1.76		3.0	
	23/5/2022	Cloudy	9:05	2.3	1.2	24.60	24.60	8.09	8.14	29.27	29.36	90.50	90.15	6.38	6.36	0.78	1.37	3.6	3.4
			9:07	2.3	1.2	24.60		8.19		29.45		89.80		6.33		1.95		3.2	
	25/5/2022	Rain	13:05	2.6	1.3	25.10	25.05	8.40	8.41	30.31	30.28	73.00	72.60	5.07	5.05	1.39	1.62	1.3	1.2
			13:07	2.6	1.3	25.00		8.41		30.25		72.20		5.02		1.84		1.1	
	27/5/2022	Rain	13:00	2.5	1.3	26.20	26.20	8.48	8.48	29.89	29.88	74.00	74.80	5.05	5.11	1.65	1.82	3.6	3.9
			13:02	2.5	1.3	26.20		8.48		29.87		75.60		5.16		1.99		3.9	
31/5/2022	Rain	13:00	2.4	1.2	27.10	27.10	8.65	8.64	22.00	172.05	83.30	86.25	5.86	6.03	8.03	5.03	2.2	2.4	
		13:02	2.4	1.2	27.10		8.62		322.10		89.20		6.20		2.02		2.4		

**Baseline Water Quality Monitoring at Station CE (surface) - Ebb Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU			SS mg/L		
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CE	3/5/2022	Sunny	12:00	8.6	1.0	22.90	23.10	8.42	8.43	32.84	32.72	74.50	85.90	5.30	6.09	1.65	2.14	4.8	4.6		
			12:02	8.6	1.0	23.30		8.44		32.59		97.30		6.88		2.62		4.3			
	5/5/2022	Sunny	12:00	8.6	1.0	23.80	23.85	8.50	8.51	32.81	32.58	103.30	604.95	7.23	7.70	0.01	0.01	2.6	2.6		
			12:02	8.6	1.0	23.90		8.51		32.35		1,106.60		8.17		0.01		2.5			
	7/5/2022	Cloudy	12:00	8.4	1.0	25.30	25.25	8.56	8.57	32.04	32.04	130.60	137.20	8.94	9.41	1.22	1.20	4.3	4.4		
			12:02	8.4	1.0	25.20		8.57		32.04		143.80		9.88		1.21		4.5			
	10/5/2022	Rain	11:55	8.4	1.0	25.97	25.98	8.33	8.33	28.75	28.76	88.30	88.20	6.09	6.09	0.01	0.01	2.3	2.4		
			11:57	8.4	1.0	25.98		8.33		28.77		88.10		6.08		0.01		2.5			
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																		
	14/5/2022	Rain	10:24	8.5	1.0	24.60	24.60	8.34	8.34	22.89	22.85	90.00	85.80	6.58	6.28	1.06	1.08	1.4	1.5		
			10:26	8.5	1.0	24.60		8.34		22.80		81.60		5.97		1.10		1.6			
	16/5/2022	Rain	10:17	8.6	1.0	22.80	22.85	8.34	8.35	29.86	29.92	75.70	75.70	5.48	5.48	2.36	2.46	4.2	4.1		
			10:19	8.6	1.0	22.90		8.35		29.98		75.70		5.48		2.55		3.9			
	18/5/2022	Cloudy	12:00	8.3	1.0	23.00	22.95	8.40	8.40	31.45	31.32	76.10	79.80	5.44	5.72	2.98	2.87	2.6	2.8		
			12:02	8.3	1.0	22.90		8.40		31.19		83.50		6.00		2.76		3.0			
	20/5/2022	Fine	12:00	8.2	1.0	25.50	25.45	8.35	8.35	28.96	29.72	81.80	80.85	5.69	5.60	2.77	2.87	3.8	4.0		
			12:02	8.2	1.0	25.40		8.34		30.47		79.90		5.51		2.97		4.2			
	23/5/2022	Cloudy	12:00	8.7	1.0	24.40	24.55	8.51	8.53	29.32	29.38	86.90	86.25	6.16	6.10	1.00	1.31	2.8	2.8		
			12:02	8.7	1.0	24.70		8.54		29.43		85.60		6.04		1.61		2.8			
	25/5/2022	Rain	10:04	8.1	1.0	25.00	25.00	8.37	8.38	30.13	30.17	72.60	71.10	5.06	4.95	1.99	2.19	2.5	2.7		
			10:06	8.1	1.0	25.00		8.38		30.20		69.60		4.84		2.38		2.8			
	27/5/2022	Rain	10:13	8.6	1.0	26.10	26.10	8.38	8.39	30.18	30.09	78.10	78.40	5.34	5.36	1.25	1.49	1.4	1.6		
			10:15	8.6	1.0	26.10		8.39		30.00		78.70		5.38		1.72		1.7			
	31/5/2022	Rain	10:21	8.7	1.0	28.70	28.10	8.51	8.51	24.15	25.09	65.74	78.27	4.44	5.33	1.86	1.79	3.6	3.5		
			10:23	8.7	1.0	27.50		8.51		26.02		90.80		6.21		1.71		3.4			

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

**Baseline Water Quality Monitoring at Station CE (surface) - Flood Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CE	3/5/2022	Sunny	10:12	8.5	1.0	22.30	22.30	8.37	8.38	32.98	32.96	66.60	77.65	4.79	5.58	2.60	3.77	2.3	2.4
			10:14	8.5	1.0	22.30		8.38		32.94		88.70		6.37		4.94		2.5	
	5/5/2022	Sunny	10:16	8.5	1.0	23.50	23.55	8.45	8.46	32.52	32.56	103.10	98.70	7.27	6.96	2.76	3.28	2.5	2.4
			10:18	8.5	1.0	23.60		8.46		32.60		94.30		6.64		3.79		2.2	
	7/5/2022	cloudy	10:13	8.3	1.0	24.50	24.60	8.55	8.56	31.90	31.90	106.30	109.05	7.41	7.58	1.25	1.22	2.2	2.3
			10:15	8.3	1.0	24.70		8.56		31.89		111.80		7.74		1.24		2.4	
	10/5/2022	Rain	11:42	8.4	1.0	26.00	25.99	8.29	8.34	28.61	28.50	78.40	83.15	5.41	5.75	0.01	0.30	<1.0	1.0
			11:44	8.4	1.0	25.98		8.38		28.38		87.90		6.08		0.58		<1.0	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	12:00	8.4	1.0	24.50	24.50	8.34	8.34	25.53	25.58	82.60	81.80	5.95	5.89	1.10	1.15	1.6	1.8
			12:02	8.4	1.0	24.50		8.34		25.63		81.00		5.83		1.20		1.9	
	16/5/2022	Rain	12:00	8.4	1.0	21.10	21.70	8.40	8.40	26.79	27.28	84.40	80.40	6.43	6.04	3.42	2.96	3.7	3.8
			12:02	8.4	1.0	22.30		8.39		27.77		76.40		5.65		2.49		3.9	
	18/5/2022	Cloudy	10:22	8.4	1.0	22.90	23.00	8.36	8.37	31.11	31.10	78.70	78.90	5.65	5.66	1.61	1.91	1.8	1.8
			10:24	8.4	1.0	23.10		8.37		31.09		79.10		5.66		2.20		1.8	
	20/5/2022	Fine	10:07	8.2	1.0	25.50	25.45	8.35	8.35	28.96	29.72	81.80	80.85	5.69	5.60	2.77	2.87	3.0	3.2
			10:09	8.2	1.0	25.40		8.34		30.47		79.90		5.51		2.97		3.3	
	23/5/2022	Cloudy	10:17	8.4	1.0	24.60	24.60	8.52	8.53	29.22	29.25	87.30	87.45	6.16	6.17	0.92	0.91	1.8	1.8
			10:19	8.4	1.0	24.60		8.54		29.28		87.60		6.17		0.89		1.7	
	25/5/2022	Rain	12:00	8.3	1.0	-	24.70	-	8.37	-	30.77	-	75.20	-	5.24	-	1.98	2.2	2.4
			12:02	8.3	1.0	24.70		8.37		30.77		75.20		5.24		1.98		2.5	
	27/5/2022	Rain	12:00	8.3	1.0	25.80	25.90	8.38	8.38	30.65	30.64	75.90	77.00	5.19	5.26	2.17	2.37	2.2	2.3
			12:02	8.3	1.0	26.00		8.38		30.62		78.10		5.32		2.56		2.4	
31/5/2022	Rain	12:00	8.4	1.0	26.50	26.60	8.54	8.57	25.48	24.15	98.50	95.05	6.87	6.66	3.47	3.26	3.0	3.3	
		12:02	8.4	1.0	26.70		8.60		22.82		91.60		6.45		3.05		3.6		



Lam Environmental Services Limited

Contract No. SD 6/2020  
Construction of San Shek Wan Sewage Treatment Works,  
Associated Submarine Outfall and Pui O Sewerage Works - ET Services (2021 - 2022)

**Baseline Water Quality Monitoring at Station CE (Middle) - Ebb Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CE	3/5/2022	Sunny	12:04	8.6	4.3	22.70	22.70	8.44	8.44	32.65	32.67	84.40	94.60	6.03	6.76	1.09	4.97	3.7	3.5
			12:06	8.6	4.3	22.70		8.44		32.68		104.80		7.49		8.85		3.3	
	5/5/2022	Sunny	12:04	8.6	4.3	23.70	23.70	8.51	8.51	32.68	32.68	120.30	112.70	8.45	7.91	0.01	0.01	2.0	2.2
			12:06	8.6	4.3	23.70		8.51		32.68		105.10		7.36		0.01		2.3	
	7/5/2022	Cloudy	12:04	8.4	4.2	24.90	24.90	8.59	8.59	32.05	32.05	140.20	140.20	9.67	9.67	1.40	1.37	3.9	3.8
			12:06	8.4	4.2	24.90		8.59		32.05		140.20		9.67		1.35		3.6	
	10/5/2022	Rain	12:00	8.4	4.2	25.93	25.93	8.33	8.33	28.76	28.69	86.70	86.90	5.99	6.01	0.01	0.01	1.5	1.6
			12:02	8.4	4.2	25.92		8.32		28.61		87.10		6.02		0.01		1.7	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	10:28	8.5	4.3	24.60	24.60	8.31	8.31	26.33	26.27	78.20	78.90	5.61	5.66	1.29	1.24	1.2	1.2
			10:30	8.5	4.3	24.60		8.30		26.21		79.60		5.71		1.19		1.2	
	16/5/2022	Rain	10:22	8.6	4.3	22.90	22.95	8.35	8.35	29.94	29.95	75.00	76.05	5.43	5.50	2.13	2.38	5.9	6.1
			10:24	8.6	4.3	23.00		8.35		29.96		77.10		5.57		2.62		6.3	
	18/5/2022	Cloudy	12:04	8.3	4.2	22.90	23.00	8.40	8.40	31.16	31.14	78.40	529.80	5.63	5.72	1.99	1.95	4.6	4.5
			12:06	8.3	4.2	23.10		8.39		31.12		981.20		5.80		1.90		4.3	
	20/5/2022	Fine	12:04	8.2	4.1	25.00	24.95	8.36	8.36	30.61	30.62	86.70	84.90	6.02	5.90	2.18	2.69	3.4	3.6
			12:06	8.2	4.1	24.90		8.36		30.63		83.10		5.78		3.19		3.7	
	23/5/2022	Cloudy	12:04	8.7	4.4	24.70	24.70	8.56	8.56	29.52	29.51	86.40	86.80	6.07	6.10	0.74	0.92	3.4	3.3
			12:06	8.7	4.4	24.70		8.55		29.49		87.20		6.13		1.10		3.2	
	25/5/2022	Rain	10:10	8.1	4.1	25.00	25.00	8.38	8.39	30.31	30.32	74.50	73.15	5.18	5.09	1.99	2.60	2.2	2.3
			10:12	8.1	4.1	25.00		8.39		30.32		71.80		5.00		3.21		2.4	
	27/5/2022	Rain	10:17	8.6	4.3	26.10	26.10	8.40	8.40	30.02	30.00	81.50	81.10	5.57	5.55	2.71	2.31	2.8	2.7
			10:19	8.6	4.3	26.10		8.40		29.98		80.70		5.52		1.90		2.5	
	31/5/2022	Rain	10:25	8.7	4.4	26.60	26.75	8.44	8.44	28.57	28.22	79.90	80.75	5.46	5.52	1.64	1.48	3.3	3.2
			10:27	8.7	4.4	26.90		8.44		27.86		81.60		5.57		1.31		3.0	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.



**Baseline Water Quality Monitoring at Station CE (Middle) - Flood Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CE	3/5/2022	Sunny	10:16	8.5	4.3	22.40	22.35	8.38	8.39	32.93	32.94	88.70	91.25	6.36	6.55	4.11	3.66	2.7	2.9
			10:18	8.5	4.3	22.30		8.39		32.94		93.80		6.73		3.20		3.0	
	5/5/2022	Sunny	10:20	8.5	4.3	23.50	23.50	8.46	8.46	23.69	28.17	111.30	108.45	7.84	7.64	2.87	2.53	2.7	2.9
			10:22	8.5	4.3	23.50		8.46		32.65		105.60		7.44		2.19		3.0	
	7/5/2022	cloudy	10:20	8.3	4.2	24.70	24.75	8.56	8.56	31.97	31.96	126.10	126.95	8.73	8.79	1.42	1.36	2.7	2.9
			10:22	8.3	4.2	24.80		8.56		31.95		127.80		8.84		1.28		3.0	
	10/5/2022	Rain	11:46	8.4	4.2	25.91	25.91	8.30	8.30	28.01	28.01	106.20	110.15	7.36	7.63	0.01	0.01	1.5	1.7
			11:48	8.4	4.2	25.90		8.29		28.45		114.10		7.90		0.01		1.9	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	12:04	8.4	4.2	24.40	24.35	8.26	8.24	29.59	30.77	69.10	67.00	4.87	4.70	8.29	7.79	2.5	2.6
			12:06	8.4	4.2	24.30		8.22		31.94		64.90		4.52		7.29		2.7	
	16/5/2022	Rain	12:04	8.4	4.2	23.00	22.95	8.37	8.37	29.76	29.71	78.10	76.85	5.65	5.57	2.41	2.02	2.7	2.9
			12:06	8.4	4.2	22.90		8.37		29.65		75.60		5.48		1.63		3.1	
	18/5/2022	Cloudy	10:26	8.4	4.2	23.00	23.00	8.37	8.37	31.07	31.07	76.90	75.55	5.51	5.42	2.09	1.89	2.2	2.3
			10:28	8.4	4.2	23.00		8.37		31.06		74.20		5.32		1.69		2.4	
	20/5/2022	Fine	10:12	8.2	4.1	25.00	24.95	8.36	8.36	30.61	30.62	86.70	84.90	6.02	5.90	2.18	2.69	3.8	3.9
			10:14	8.2	4.1	24.90		8.36		30.63		83.10		5.78		3.19		4.0	
	23/5/2022	Cloudy	10:22	8.4	4.2	24.60	24.60	8.56	8.56	29.29	29.28	88.20	86.30	6.22	6.08	1.10	1.11	2.4	2.3
			10:24	8.4	4.2	24.60		8.55		29.27		84.40		5.94		1.12		2.2	
	25/5/2022	Rain	12:04	8.3	4.2	24.70	24.70	8.36	8.35	31.20	31.27	73.40	71.65	5.11	4.99	9.72	8.25	5.0	5.2
			12:06	8.3	4.2	24.70		8.34		31.34		69.90		4.86		6.77		5.4	
	27/5/2022	Rain	12:04	8.3	4.2	25.80	25.80	8.39	8.40	30.62	30.60	79.70	77.40	5.46	5.30	2.56	2.66	3.2	3.4
			12:06	8.3	4.2	25.80		8.41		30.57		75.10		5.14		2.76		3.5	
	31/5/2022	Rain	12:04	8.4	4.2	26.10	26.55	8.43	8.52	29.11	26.27	87.80	88.75	6.04	6.16	3.85	2.75	5.1	5.3
12:06			8.4	4.2	27.00	8.61		23.42		89.70		6.27		1.64		5.4			

### Baseline Water Quality Monitoring at Station CE (Bottom) - Ebb Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature		pH		Salinity		DO Saturation		DO		Turbidity			SS	
				m	m	°C		-		ppt		%		mg/L		NTU			mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value
CE	3/5/2022	Sunny	12:06	8.6	7.6	22.60	22.60	8.44	8.44	32.67	32.68	95.40	95.50	6.82	6.83	3.61	3.11	2.6	2.8	
			12:08	8.6	7.6	22.60		8.44		32.68		95.60		6.84		2.61		2.9		
	5/5/2022	Sunny	12:08	8.6	7.6	23.60	23.60	8.51	8.52	32.65	32.64	116.60	118.10	8.19	8.30	0.01	0.01	1.7	1.6	
			12:10	8.6	7.6	23.60		8.52		32.64		119.60		8.40		0.01		1.4		
	7/5/2022	Cloudy	12:08	8.4	7.4	24.70	24.80	8.60	8.60	32.00	32.03	130.40	137.95	9.30	9.67	1.51	1.52	3.1	3.3	
			12:10	8.4	7.4	24.90		8.59		32.05		145.50		10.04		1.47		3.4		
	10/5/2022	Rain	12:04	8.4	7.4	25.91	25.89	8.32	8.35	28.62	27.90	105.50	106.55	7.29	7.38	0.01	0.01	<1.0	1.0	
			12:06	8.4	7.4	25.86		8.37		27.18		107.60		7.46		0.01		<1.0		
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																	
	14/5/2022	Rain	10:32	8.5	7.5	24.60	24.60	8.29	8.29	29.47	29.46	76.00	76.80	5.36	5.42	1.55	1.27	<1.0	1.0	
			10:34	8.5	7.5	24.60		8.28		29.45		77.60		5.47		0.99		<1.0		
	16/5/2022	Rain	10:26	8.6	7.6	22.10	22.30	8.36	8.36	31.00	30.99	78.40	80.30	5.72	5.84	7.72	7.98	7.7	7.9	
			10:28	8.6	7.6	22.50		8.35		30.97		82.20		5.95		8.23		8.0		
	18/5/2022	Cloudy	12:08	8.3	7.3	23.80	23.85	8.39	8.39	31.04	31.05	80.60	79.75	5.39	5.49	1.91	2.03	4.8	4.6	
			12:10	8.3	7.3	23.90		8.39		31.05		78.90		5.59		2.14		4.4		
	20/5/2022	Fine	12:08	8.2	7.2	24.80	24.75	8.36	8.36	30.63	30.66	76.30	79.75	5.32	5.56	3.97	3.71	2.9	3.1	
			12:10	8.2	7.2	24.70		8.36		30.69		83.20		5.80		3.44		3.2		
	23/5/2022	Cloudy	12:08	8.7	7.7	24.60	24.60	8.55	8.55	29.83	29.84	83.50	83.90	5.86	5.89	1.44	1.40	4.1	4.0	
			12:10	8.7	7.7	24.60		8.54		29.84		84.30		5.92		1.35		3.9		
	25/5/2022	Rain	10:15	8.1	7.1	24.80	24.80	8.38	8.38	30.56	30.57	78.00	77.90	5.44	5.43	1.29	1.25	1.4	1.6	
			10:17	8.1	7.1	24.80		8.38		30.57		77.80		5.42		1.20		1.7		
	27/5/2022	Rain	10:25	8.6	7.6	25.50	25.45	8.38	8.38	30.79	30.78	77.60	77.80	5.34	5.36	3.15	3.25	3.7	3.6	
			10:27	8.6	7.6	25.40		8.37		30.77		78.00		5.37		3.34		3.4		
	31/5/2022	Rain	10:30	8.7	7.7	26.80	26.80	8.41	8.42	28.70	28.70	76.10	77.70	5.18	5.29	1.54	1.53	2.8	2.7	
			10:32	8.7	7.7	26.80		8.42		28.69		79.30		5.40		1.52		2.5		

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station CE (Bottom) - Flood Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CE	3/5/2022	Sunny	10:20	8.5	7.5	22.40	22.45	8.39	8.39	32.94	32.92	97.10	89.80	5.67	5.79	2.87	3.51	3.2	3.3
			10:22	8.5	7.5	22.50		8.39		32.90		82.50		5.90		4.14		3.4	
	5/5/2022	Sunny	10:24	8.5	7.5	23.40	23.45	8.47	8.47	32.67	32.66	110.80	108.20	7.81	7.63	2.29	2.24	3.8	3.6
			10:26	8.5	7.5	23.50		8.46		32.65		105.60		7.44		2.19		3.4	
	7/5/2022	cloudy	10:25	8.3	7.3	24.40	24.40	8.55	8.55	32.28	32.28	122.70	122.10	8.53	8.49	1.10	1.06	3.5	3.4
			10:27	8.3	7.3	24.40		8.55		32.28		121.50		8.45		1.03		3.2	
	10/5/2022	Rain	11:50	8.4	7.4	25.81	25.79	8.28	8.28	28.92	28.88	87.10	87.00	6.02	6.02	0.01	0.15	2.8	2.6
			11:52	8.4	7.4	25.76		8.28		28.84		86.90		6.01		0.29		2.3	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	12:08	8.4	7.4	24.50	24.50	8.26	8.26	30.38	30.37	67.30	70.35	4.72	4.94	3.69	3.44	4.2	4.4
			12:10	8.4	7.4	24.50		8.26		30.36		73.40		5.15		3.18		4.6	
	16/5/2022	Rain	12:08	8.4	7.4	23.10	23.05	8.37	8.38	31.18	31.22	71.50	74.85	5.11	5.36	3.21	3.15	2.8	2.7
			12:10	8.4	7.4	23.00		8.38		31.25		78.20		5.60		3.09		2.6	
	18/5/2022	Cloudy	10:30	8.4	7.4	23.30	23.25	8.37	8.37	31.06	31.04	75.80	76.45	5.41	5.46	2.24	2.22	2.6	2.8
			10:32	8.4	7.4	23.20		8.37		31.02		77.10		5.51		2.19		3.0	
	20/5/2022	Fine	10:16	8.2	7.2	24.80	24.75	8.36	8.36	30.63	30.66	76.30	79.75	5.32	5.56	3.97	3.71	4.6	4.5
			10:18	8.2	7.2	24.70		8.36		30.69		83.20		5.80		3.44		4.4	
	23/5/2022	Cloudy	10:28	8.4	7.4	24.50	24.55	8.54	8.54	29.67	29.67	86.10	86.15	6.06	6.06	1.16	1.18	2.5	2.5
			10:30	8.4	7.4	24.60		8.54		29.66		86.20		6.06		1.20		2.4	
	25/5/2022	Rain	12:08	8.3	7.3	24.70	24.70	8.35	8.36	31.01	31.00	75.00	75.70	5.22	5.27	5.61	5.56	9.0	9.2
			12:10	8.3	7.3	24.70		8.36		30.99		76.40		5.32		5.51		9.4	
	27/5/2022	Rain	12:08	8.3	7.3	25.60	25.60	8.40	8.40	30.82	30.83	78.50	78.20	5.38	5.36	2.89	2.64	7.3	7.1
			12:10	8.3	7.3	25.60		8.40		30.83		77.90		5.34		2.39		6.9	
31/5/2022	Rain	12:08	8.4	7.4	25.60	25.55	8.38	8.37	30.75	30.82	86.10	83.65	5.91	5.75	6.01	5.95	6.9	7.1	
		12:10	8.4	7.4	25.50		8.36		30.88		81.20		5.59		5.89		7.3		

### Baseline Water Quality Monitoring at Station CF (surface) - Ebb Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CF	3/5/2022	Sunny	13:13	7.9	1.0	22.00	22.10	8.43	8.43	33.13	33.00	80.00	86.30	5.77	6.22	2.96	3.74	#N/A	1.0
			13:15	7.9	1.0	22.20	8.43	32.87		92.60		6.67		4.52		#N/A			
	5/5/2022	Sunny	13:12	8.4	1.0	23.70	24.05	8.49	8.49	32.60	32.64	108.40	106.60	7.61	7.44	0.01	0.01	3.2	3.4
			13:14	8.4	1.0	24.40	8.48	32.68		104.80		7.27		0.01		3.5			
	7/5/2022	Cloudy	13:13	8.2	1.0	24.80	24.50	3.29	5.91	31.78	32.25	124.90	113.95	8.64	7.90	1.07	1.11	2.7	2.6
			13:15	8.2	1.0	24.20	8.52	32.71		103.00		7.16		1.14		2.5			
	10/5/2022	Rain	14:06	8.3	1.0	26.41	26.37	8.39	8.39	29.07	28.69	84.90	83.75	5.80	5.74	0.01	0.32	1.3	1.5
			14:08	8.3	1.0	26.32	8.39	28.30		82.60		5.68		0.63		1.6			
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	9:09	8.5	1.0	24.20	24.25	7.18	7.52	26.01	26.35	75.90	76.65	5.49	5.53	1.39	1.25	1.0	1.2
			9:11	8.5	1.0	24.30	7.85	26.69		77.40		5.56		1.10		1.3			
	16/5/2022	Rain	9:03	8.6	1.0	22.80	22.80	6.78	7.03	30.93	31.17	86.40	84.60	6.21	6.08	5.63	5.57	5.0	4.9
			9:05	8.6	1.0	22.80	7.28	31.41		82.80		5.95		5.51		4.7			
	18/5/2022	Cloudy	13:15	8.8	1.0	22.60	22.65	8.42	8.42	31.73	31.65	76.30	76.85	5.49	5.53	4.57	3.67	4.1	4.3
			13:17	8.8	1.0	22.70	8.41	31.56		77.40		5.56		2.76		4.5			
	20/5/2022	Fine	13:09	8.6	1.0	25.00	25.40	8.45	8.45	30.76	30.62	83.10	83.30	5.76	5.74	1.80	1.65	3.2	3.1
			13:11	8.6	1.0	25.80	8.45	30.48		83.50		5.72		1.50		2.9			
	23/5/2022	Cloudy	13:15	8.8	1.0	24.70	24.85	8.49	8.50	29.94	29.77	80.70	77.90	5.66	5.45	0.01	0.16	2.6	2.8
			13:17	8.8	1.0	25.00	8.50	29.60		75.10		5.24		0.30		3.0			
	25/5/2022	Rain	8:28	8.7	1.0	24.60	24.60	6.88	7.05	30.28	30.40	78.50	77.15	5.50	5.40	0.72	1.07	1.9	1.8
			8:30	8.7	1.0	24.60	7.21	30.51		75.80		5.30		1.42		1.7			
	27/5/2022	Rain	8:58	8.7	1.0	25.90	25.90	7.19	7.31	29.78	29.85	76.90	78.10	5.23	5.34	2.33	2.67	1.8	1.7
			9:00	8.7	1.0	25.90	7.43	29.92		79.30		5.44		3.00		1.6			
	31/5/2022	Rain	8:56	8.6	1.0	27.40	27.35	7.24	7.41	25.06	24.52	78.36	81.08	5.41	5.61	1.95	1.87	3.4	3.6
			8:58	8.6	1.0	27.30	7.57	23.97		83.80		5.81		1.78		3.8			

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station CF (surface) - Flood Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CF	3/5/2022	Sunny	9:01	8.0	1.0	22.30	22.35	7.11	7.33	32.06	32.20	87.90	86.10	6.34	6.20	4.44	3.99	3.4	3.3
			9:03	8.0	1.0	22.40		7.54		32.34		84.30		6.06		3.54		3.2	
	5/5/2022	Sunny	9:10	8.3	1.0	23.60	23.65	7.17	7.32	32.51	32.53	89.00	90.20	6.26	6.34	2.69	3.23	4.0	4.1
			9:12	8.3	1.0	23.70		7.47		32.54		91.40		6.42		3.77		4.2	
	7/5/2022	cloudy	8:56	8.1	1.0	24.40	24.40	7.13	7.33	31.24	31.38	113.90	68.45	7.93	8.26	0.94	0.91	3.1	3.4
			8:58	8.1	1.0	24.40		7.52		31.51		23.00		8.58		0.91		3.6	
	10/5/2022	Rain	10:27	8.3	1.0	26.40	26.47	9.00	8.72	26.85	27.13	125.20	123.25	8.63	8.49	0.80	0.46	1.5	1.7
			10:29	8.3	1.0	26.54		8.44		27.41		121.30		8.35		0.11		1.8	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	13:24	8.6	1.0	24.70	24.70	8.44	8.44	21.80	21.78	82.40	82.50	6.04	6.05	1.20	1.25	1.4	1.3
			13:26	8.6	1.0	24.70		8.43		21.76		82.60		6.06		1.29		1.2	
	16/5/2022	Rain	13:12	8.9	1.0	23.00	22.95	8.33	8.34	31.10	30.86	74.40	73.20	5.33	5.26	4.81	5.21	5.6	5.5
			13:14	8.9	1.0	22.90		8.34		30.62		72.00		5.18		5.61		5.3	
	18/5/2022	Cloudy	9:02	8.5	1.0	24.10	23.90	7.16	7.41	31.39	30.98	72.00	70.10	5.06	4.95	6.26	6.45	6.6	6.5
			9:04	8.5	1.0	23.70		7.66		30.56		68.20		4.84		6.63		6.3	
	20/5/2022	Fine	8:52	8.8	1.0	24.70	24.65	7.07	7.25	30.48	30.57	75.30	75.85	5.26	5.30	2.57	2.87	5.3	5.4
			8:54	8.8	1.0	24.60		7.42		30.66		76.40		5.34		3.16		5.5	
	23/5/2022	Cloudy	8:49	8.6	1.0	24.70	24.70	6.88	6.92	29.43	29.59	87.90	87.80	6.18	6.17	1.36	1.49	4.2	4.4
			8:51	8.6	1.0	24.70		7.16		29.75		87.70		6.15		1.62		4.5	
	25/5/2022	Rain	13:18	8.3	1.0	24.70	24.65	8.42	8.42	30.57	30.50	68.80	69.65	4.80	4.87	1.37	1.38	1.4	1.4
			13:20	8.3	1.0	24.60		8.42		30.43		70.50		4.93		1.38		1.3	
	27/5/2022	Rain	13:13	8.3	1.0	26.10	26.15	8.48	8.48	28.32	28.62	74.10	74.00	5.12	5.10	2.99	2.47	1.4	1.6
			13:15	8.3	1.0	26.20				28.91		73.90		5.07		1.94		1.7	
31/5/2022	Rain	13:11	8.3	1.0	26.90	26.60	8.65	8.66	23.07	22.77	87.60	86.00	6.15	6.08	1.63	1.58	3.8	4.0	
		13:13	8.3	1.0	26.30		8.67		22.47		84.40		6.00		1.53		4.1		

### Baseline Water Quality Monitoring at Station CF (Middle) - Ebb Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature		pH		Salinity		DO Saturation		DO		Turbidity		SS	
				m	m	°C		-		ppt		%		mg/L		NTU		mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CF	3/5/2022	Sunny	13:18	7.9	4.0	22.00	21.95	8.43	8.43	32.98	33.00	90.70	83.75	6.54	6.05	5.08	4.80	#N/A	1.0
			13:20	7.9	4.0	21.90		8.43		33.01		76.80		5.55		4.52		#N/A	
	5/5/2022	Sunny	12:18	8.4	4.2	23.70	23.70	8.47	8.47	32.94	32.93	105.70	104.20	7.41	7.31	0.01	0.01	4.6	4.4
			12:20	8.4	4.2	23.70		8.47		32.91		102.70		7.20		0.01		4.1	
	7/5/2022	Cloudy	13:17	8.2	4.1	24.80	24.85	7.61	8.11	31.89	31.90	125.14	125.82	8.65	8.65	1.44	1.44	1.8	1.8
			13:19	8.2	4.1	24.90		8.61		31.91		126.50		8.65		1.39		1.7	
	10/5/2022	Rain	14:10	8.3	4.2	26.21	26.18	8.43	8.45	28.65	28.72	85.80	85.00	5.90	5.85	0.01	0.23	2.1	2.2
			14:12	8.3	4.2	26.14		8.46		28.79		84.20		5.79		0.44		2.3	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	9:14	8.5	4.3	24.30	24.30	7.41	7.61	26.02	26.09	82.40	80.85	5.95	5.83	1.63	1.40	1.9	1.8
			9:16	8.5	4.3	24.30		7.81		26.16		79.30		5.71		1.17		1.6	
	16/5/2022	Rain	9:07	8.6	4.3	21.70	21.80	7.94	7.90	31.62	31.56	77.80	79.65	5.70	5.83	6.67	6.29	5.4	5.6
			9:09	8.6	4.3	21.90		7.85		31.50		81.50		5.95		5.90		5.8	
	18/5/2022	Cloudy	13:20	8.8	4.4	22.60	22.55	8.41	8.41	31.52	31.53	76.30	75.30	5.49	5.43	3.61	3.41	3.9	3.8
			13:22	8.8	4.4	22.50		8.41		31.54		74.30		5.36		3.21		3.6	
	20/5/2022	Fine	13:15	8.6	4.3	24.90	24.90	8.44	8.44	30.95	30.95	83.60	83.70	5.81	5.82	2.36	2.23	3.4	3.6
			13:17	8.6	4.3	24.90		8.44		30.95		83.80		5.82		2.09		3.8	
	23/5/2022	Cloudy	13:20	8.8	4.4	24.40	24.40	8.45	8.43	30.06	30.33	79.40	80.00	5.59	5.63	0.25	0.13	3.7	3.6
			13:22	8.8	4.4	24.40		8.41		30.60		80.60		5.66		0.01		3.4	
	25/5/2022	Rain	8:32	8.7	4.4	24.60	24.60	7.41	7.49	30.61	30.35	77.00	75.10	5.38	5.26	1.49	3.16	2.5	2.4
			8:34	8.7	4.4	24.60		7.56		30.09		73.20		5.13		4.82		2.2	
	27/5/2022	Rain	9:02	8.7	4.4	25.90	25.90	7.59	7.65	30.08	30.02	79.90	79.60	5.48	5.46	1.80	2.11	2.4	2.3
			9:04	8.7	4.4	25.90		7.70		29.96		79.30		5.44		2.41		2.2	
	31/5/2022	Rain	9:00	8.6	4.3	27.20	27.20	7.91	7.84	23.95	23.98	87.60	87.00	6.08	6.04	2.43	2.05	4.6	4.7
			9:02	8.6	4.3	27.20		7.77		24.00		86.40		6.00		1.67		4.8	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

### Baseline Water Quality Monitoring at Station CF (Middle) - Flood Tide

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth	Sampling Depth	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
				m	m	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CF	3/5/2022	Sunny	9:05	8.0	4.0	22.30	22.25	7.93	7.96	23.53	27.95	83.90	89.15	6.04	6.43	3.52	4.05	3.8	3.9
			9:07	8.0	4.0	22.20		7.98		32.37		94.40		6.82		4.58		4.0	
	5/5/2022	Sunny	9:14	8.3	4.2	23.50	23.50	7.80	7.73	32.71	32.82	83.20	88.30	5.85	6.22	2.99	4.08	4.6	4.5
			9:16	8.3	4.2	23.50		7.66		32.92		93.40		6.58		5.16		4.4	
	7/5/2022	cloudy	9:00	8.1	4.1	24.30	24.35	7.96	7.92	31.47	31.56	119.60	115.05	8.36	8.04	0.84	0.81	2.8	2.7
			9:02	8.1	4.1	24.40		7.87		31.64		110.50		7.71		0.77		2.6	
	10/5/2022	Rain	10:31	8.3	4.2	26.41	26.34	8.11	8.30	28.46	28.81	115.80	115.35	7.94	7.91	0.59	0.30	2.3	2.4
			10:33	8.3	4.2	26.27		8.49		29.16		114.90		7.88		0.01		2.4	
	12/5/2022	Rainstrom	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	13:30	8.6	4.3	24.70	24.70	8.42	8.43	22.26	22.06	86.30	86.45	6.31	6.33	1.20	1.70	2.4	2.3
			13:32	8.6	4.3	24.70		8.43		21.85		86.60		6.35		2.19		2.3	
	16/5/2022	Rain	13:18	8.9	4.5	23.20	23.15	8.33	8.34	31.14	31.09	74.20	73.50	5.30	5.26	4.68	5.17	6.0	6.3
			13:20	8.9	4.5	23.10		8.34		31.03		72.80		5.22		5.66		6.3	
	18/5/2022	Cloudy	9:06	8.5	4.3	23.50	23.45	7.88	7.84	31.62	31.63	77.20	77.65	5.47	5.51	6.60	6.60	6.0	5.8
			9:08	8.5	4.3	23.40		7.79		31.63		78.10		5.55		6.60		5.6	
	20/5/2022	Fine	8:56	8.8	4.4	24.50	24.50	7.75	7.70	30.79	30.80	74.20	73.40	5.18	5.13	2.60	2.52	4.0	4.2
			8:58	8.8	4.4	24.50		7.64		30.81		72.60		5.07		2.44		4.3	
	23/5/2022	Cloudy	8:53	8.6	4.3	24.70	24.65	7.47	7.55	29.82	29.84	78.70	79.10	5.52	5.55	1.51	1.71	5.2	5.1
			8:55	8.6	4.3	24.60		7.63		29.85		79.50		5.58		1.90		5.0	
	25/5/2022	Rain	13:22	8.3	4.2	24.70	24.70	8.43	8.43	30.54	30.57	74.20	74.05	5.18	5.17	2.37	1.94	2.3	2.2
			13:24	8.3	4.2	24.70		8.43		30.59		73.90		5.16		1.50		2.1	
	27/5/2022	Rain	13:17	8.3	4.2	26.00	26.00	8.48	8.48	28.23	28.25	73.10	73.85	5.05	5.10	2.13	2.52	2.1	2.2
			13:19	8.3	4.2	26.00		8.48		28.27		74.60		5.15		2.91		2.3	
31/5/2022	Rain	13:15	8.3	4.2	27.00	26.95	8.67	8.68	22.83	22.86	88.50	89.20	6.21	6.27	1.84	1.69	4.3	4.7	
		13:17	8.3	4.2	26.90		8.68		22.89		89.90		6.32		1.53		4.7		



**Baseline Water Quality Monitoring at Station CF (Bottom) - Ebb Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CF	3/5/2022	Sunny	13:25	7.9	6.9	22.40	22.45	8.43	8.43	32.87	32.91	88.90	92.20	6.38	6.61	4.18	5.34	#N/A	1.0
			13:27	7.9	6.9	22.50		8.43		32.94		95.50		6.83		6.50		#N/A	
			12:22	8.4	7.4	23.50	23.50	8.45	8.45	32.93	32.94	90.50	93.30	6.36	6.56	0.01	0.01	5.1	5.3
	5/5/2022	Sunny	12:24	8.4	7.4	23.50		8.45		32.95		96.10		6.75		0.01		5.5	
			13:22	8.2	7.2	24.30	24.75	8.54	8.57	32.69	32.33	102.80	111.20	7.14	7.67	1.43	1.40	1.3	1.3
	7/5/2022	Cloudy	13:24	8.2	7.2	25.20		8.60		31.97		119.60		8.20		1.37		1.3	
			14:14	8.3	7.3	26.00	26.07	8.39	8.40	28.71	28.87	100.70	94.10	6.94	6.48	0.01	0.01	2.6	2.8
	10/5/2022	Rain	14:16	8.3	7.3	26.14		8.40		29.03		87.50		6.01		0.01		3.0	
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	9:18	8.5	7.5	24.30	24.30	7.91	7.93	28.02	28.01	68.60	75.35	4.89	5.37	1.61	1.76	11.8	11.6
			9:20	8.5	7.5	24.30		7.94		28.00		82.10		5.85		1.91		11.4	
	16/5/2022	Rain	9:11	8.6	7.6	21.50	21.65	8.05	8.03	31.63	31.63	75.20	74.40	5.52	5.45	6.99	7.18	6.1	6.1
			9:13	8.6	7.6	21.80		8.01		31.63		73.60		5.37		7.37		6.1	
	18/5/2022	Cloudy	13:25	8.8	7.8	23.00	23.10	8.41	8.41	31.57	31.57	71.90	71.65	5.14	5.11	3.51	4.15	3.3	3.2
			13:27	8.8	7.8	23.20		8.41		31.57		71.40		5.08		4.78		3.0	
	20/5/2022	Fine	13:20	8.6	7.6	24.90	24.90	8.44	8.44	30.94	30.95	78.30	75.50	5.44	5.25	2.45	2.35	4.0	4.2
			13:22	8.6	7.6	24.90		8.44		30.96		72.70		5.05		2.25		4.4	
	23/5/2022	Cloudy	13:24	8.8	7.8	24.40	24.40	8.41	8.41	30.73	30.75	82.10	78.45	5.76	5.51	0.29	0.16	4.4	4.2
			13:26	8.8	7.8	24.40		8.40		30.76		74.80		5.25		0.02		4.0	
	25/5/2022	Rain	8:36	8.7	7.7	24.70	24.70	7.81	7.79	31.01	31.21	75.00	70.95	5.22	4.94	1.00	1.15	2.6	2.8
			8:38	8.7	7.7	24.70		7.76		31.40		66.90		4.66		1.29		3.0	
	27/5/2022	Rain	9:06	8.7	7.7	25.60	25.60	7.80	7.83	30.00	30.00	74.00	71.40	5.10	4.92	2.47	2.45	2.6	2.8
			9:08	8.7	7.7	25.60		7.86		30.00		68.80		4.74		2.43		2.9	
	31/5/2022	Rain	9:04	8.6	7.6	25.70	25.75	7.83	7.81	31.67	31.67	76.30	77.40	5.20	5.28	6.76	6.60	7.6	7.4
			9:06	8.6	7.6	25.80		7.79		31.66		78.50		5.35		6.44		7.2	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.

**Baseline Water Quality Monitoring at Station CF (Bottom) - Flood Tide**

Station Reference	Sampling Date	Weather	Sampling Time	Water Depth m	Sampling Depth m	Temperature °C		pH -		Salinity ppt		DO Saturation %		DO mg/L		Turbidity NTU		SS mg/L	
						Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG	Value	AVG
CF	3/5/2022	Sunny	9:09	8.0	7.0	22.30	22.35	8.10	8.09	32.98	32.95	83.40	86.25	5.99	6.19	7.10	6.87	4.8	5.0
			9:11	8.0	7.0	22.40		8.07		32.91		89.10		6.39		6.64		5.2	
			9:18	8.3	7.3	23.30	23.30	7.91	7.94	33.25	33.26	75.20	77.85	5.30	5.49	9.45	9.26	5.5	5.4
	5/5/2022	Sunny	9:20	8.3	7.3	23.30		7.97		33.26		80.50		5.67		9.06		5.3	
			9:05	8.1	7.1	24.40	24.40	8.14	8.19	32.04	32.06	106.20	102.40	7.39	7.13	1.10	1.08	2.3	2.2
	7/5/2022	cloudy	9:07	8.1	7.1	24.40		8.23		32.08		98.60		6.86		1.05		2.1	
			10:35	8.3	7.3	26.17	26.20	8.54	8.39	29.18	29.19	79.60	78.15	5.46	5.36	0.19	0.21	2.5	2.6
	10/5/2022	Rain	10:37	8.3	7.3	26.23		8.24		29.19		76.70		5.26		0.22		2.7	
	12/5/2022	Rainstorm	Sampling was cancelled due to adverse weather																
	14/5/2022	Rain	13:35	8.6	7.6	24.40	24.40	8.28	8.28	31.09	31.16	82.20	81.30	5.74	5.68	6.47	7.01	3.0	3.2
			13:37	8.6	7.6	24.40		8.28		31.23		80.40		5.62		7.55		3.3	
	16/5/2022	Rain	13:25	8.9	7.9	22.60	22.55	8.33	8.34	31.60	31.42	72.70	73.40	5.25	5.30	4.93	4.78	9.6	9.8
			13:27	8.9	7.9	22.50		8.34		31.24		74.10		5.35		4.63		10.0	
	18/5/2022	Cloudy	9:10	8.5	7.5	23.40	23.45	7.95	7.98	31.76	31.81	78.90	78.50	5.59	5.56	5.38	5.72	5.1	5.3
			9:12	8.5	7.5	23.50		8.01		31.86		78.10		5.52		6.05		5.4	
	20/5/2022	Fine	9:00	8.8	7.8	24.50	24.50	7.86	7.80	31.04	31.05	71.20	72.55	4.98	5.08	2.79	2.77	3.5	3.4
			9:02	8.8	7.8	24.50		7.92		31.06		73.90		5.17		2.74		3.2	
	23/5/2022	Cloudy	8:58	8.6	7.6	24.50	24.50	7.74	7.78	30.26	30.27	79.20	78.15	5.56	5.49	2.18	2.24	5.4	5.6
			9:00	8.6	7.6	24.50		7.82		30.28		77.10		5.41		2.30		5.8	
	25/5/2022	Rain	13:28	8.3	7.3	24.50	24.50	8.39	8.40	30.79	30.79	69.60	70.90	4.87	4.96	2.60	2.43	5.2	5.4
			13:30	8.3	7.3	24.50		8.40		30.79		72.20		5.05		2.25		5.5	
	27/5/2022	Rain	13:22	8.3	7.3	26.10	26.10	8.48	8.48	28.30	28.31	73.00	72.95	5.04	5.04	1.94	2.00	2.8	2.9
			13:24	8.3	7.3	26.10		8.47		28.32		72.90		5.04		2.06		3.0	
	31/5/2022	Rain	13:19	8.3	7.3	25.70	25.75	8.41	8.43	29.21	29.18	88.00	83.00	6.09	5.74	8.12	8.60	6.8	6.9
			13:21	8.3	7.3	25.80		8.44		29.14		78.00		5.39		9.08		7.0	

General Note: For calculation of average concentration of SS, the minimum value for "NOT DETECTED" is treated as 1.0mg/L according to reporting limit.



***Appendix 4.5***

***Monthly Summary Waste Flow Table***

**Drainage Services Department**  
**Contract No. DC/2020/02**  
**Construction of San Shek Wan Sewage Treatment Works,**  
**Associated Submarine Outfall and Pui O Sewerage Works**

**Monthly Summary Waste Flow Table for 2022**

Month	Actual Quantities of Inert C&D Material Generated Monthly						Actual Quantities of C&D Wastes Generated Monthly				
	Total Quantity Generated (a)	Hard Rocks and Large Broken Concrete (b)	Reused in the Contract (c)	Reused in other Projects (d)	Disposed as Public Fill (a-b-c-d)	Imported Fill	Metals	Paper/card-board packaging	Plastics [see Note 3]	Chemical waste	Others. e.g. general refuse
	(in '000m <sup>3</sup> )	(in '000m <sup>3</sup> )	(in '000m <sup>3</sup> )	(in '000m <sup>3</sup> )	(in '000m <sup>3</sup> )	(in '000m <sup>3</sup> )	(in '000kg)	(in '000kg)	(in '000kg)	(in '000kg)	(in '000kg)
<b>Jan</b>	0.02	0.00	0.00	0.00	0.02	0.00	0.00	0.01	0.00	0.00	58.35
<b>Feb</b>	2.37	0.00	0.00	0.00	2.37	0.00	0.00	0.00	0.00	0.00	52.60
<b>Mar</b>	2.51	0.00	0.00	0.00	2.51	0.00	1.55	0.00	0.00	0.00	34.82
<b>Apr</b>	0.62	0.00	0.00	0.00	0.62	0.00	0.00	0.05	0.00	0.00	9.74
<b>May</b>	0.21	0.00	0.00	0.00	0.21	0.00	0.00	0.00	0.00	0.00	17.38
<b>Jun</b>											
<b>Sub-total</b>	5.73	0.00	0.00	0.00	5.73	0.00	1.56	0.06	0.01	0.00	172.89
<b>July</b>											
<b>Aug</b>											
<b>Sept</b>											
<b>Oct</b>											
<b>Nov</b>											
<b>Dec</b>											
<b>Total</b>	5.73	0.00	0.00	0.00	5.73	0.00	1.56	0.06	0.01	0.00	172.89

Notes:

- (1) The inert C&D material except slurry and bentonite are disposed at Mui Wo Temporary Public Fill Bank (MW-PFRF)
- (2) The slurry and bentonite are disposed at Tseung Kwan O Area 137 Fill Bank (TKO137FB)
- (3) The non-inert waste is disposed at NENT or Outlying Islands Transfer Facilities
- (4) The waste flow table shall also include C&D materials that are specified in the Contract to be imported for use at the Site.
- (5) Plastics refer to plastic bottles/containers, plastic sheets/foam from packaging material
- (6) Assume the density of fill material is 2 tonne/m<sup>3</sup>.



***Appendix 6.1***

***Three Months Rolling Programme – June 2022 to August 2022***

## KL-CW JV

<b>Tentative Three Months Construction Rolling Program</b> <b>Contract No.: DC/2020/02</b> <b>Construction of San Shek Wan Sewage Treatment Works,</b> <b>Associated Submarine Outfall and Pui O Sewerage Works</b>	<b>Reference No. : DC/2020/02</b> <b>Revision No. : -</b>
--	--

### **Tentative Three Months (June, July & August 2022) Construction Rolling Program**

<b>Item</b>	<b>Construction Activities</b>
1	Excavation, sewer laying, construction of manhole at Pui O Lo Uk Tsuen
2	SSWSTW and HDD works
3	Site formation works for POSPS
4	Drilling works
5	Excavation works
6	ELS works
7	Piling Works